

RIED IM INNKREIS, Austria

WMO: 110530

Lat: 48.217N

Lon: 13.475E

Elev: 1408

StdP: 13.96

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.3	15.7	5.9	7.8	11.2	11.3	10.3	17.5	12.1	42.8	10.5	39.3	2.2	90	0.440

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.3	87.3	69.4	83.8	68.0	80.9	66.8	70.7	83.9	69.1	81.1	67.6	78.6	2.6	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.2	101.7	76.8	64.7	96.5	74.5	63.5	92.4	73.1	35.4	84.1	34.0	81.5	32.8	78.8	76.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.5	7.8	7.0	6.8	91.7	6.6	2.4	2.0	93.5	-1.8	94.9	-5.5	96.3	-10.3	98.0		
(5)			5.4	73.9	6.8	1.7	0.5	75.1	-3.5	76.1	-7.4	77.1	-12.3	78.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	49.4	30.5	33.7	41.1	50.2	57.0	64.5	67.3	66.1	57.7	49.7	40.0	33.6		
	DBStd	14.52	8.20	8.31	7.61	6.99	6.62	6.62	5.85	5.71	5.99	6.23	6.46	7.15		
	HDD50	2351	604	457	285	82	15	1	0	0	7	85	305	510		
	HDD65	6012	1069	876	741	446	260	89	46	56	230	475	750	974		
	CDD50	2118	1	1	8	86	232	435	536	501	238	75	5	0		
	CDD65	305	0	0	0	1	11	73	117	92	11	0	0	0		
	CDH74	2958	0	0	0	22	159	731	1103	842	100	1	0	0		
	CDH80	824	0	0	0	3	23	191	343	252	12	0	0	0		
	WSAvg	2.9	3.7	3.7	3.7	3.2	2.5	2.4	2.5	2.3	2.2	2.3	3.2	3.5		
	PrecAvg	41.2	2.5	2.2	3.1	2.6	4.1	5.0	5.1	4.6	3.7	2.8	2.7	2.7		
(15) Precipitation	PrecMax	50.4	5.4	5.6	5.7	6.7	7.8	10.9	11.1	11.1	7.7	5.3	6.5	4.9		
	PrecMin	29.1	0.5	0.4	0.7	0.2	1.0	1.8	1.0	1.3	1.4	0.7	0.1	0.6		
	PrecStd	4.8	1.4	1.3	1.5	1.5	1.7	2.0	2.2	2.0	1.5	1.3	1.3	1.3		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.0	57.3	66.2	76.8	83.2	89.4	91.8	91.5	80.9	71.9	61.0	53.8		
		MCWB	47.2	46.9	52.7	60.1	66.0	71.2	70.3	70.0	66.8	59.8	53.2	47.9		
	2%	DB	49.3	52.3	61.5	72.1	78.6	85.2	87.4	86.3	76.9	66.8	56.3	49.5		
		MCWB	44.8	45.4	50.6	56.7	64.1	68.7	69.3	69.1	65.2	58.2	50.8	45.7		
	5%	DB	44.9	48.7	57.4	68.1	74.5	81.8	83.7	82.2	72.7	63.2	52.7	46.4		
		MCWB	41.7	43.5	48.3	55.0	61.3	66.8	68.0	67.8	62.7	56.1	49.1	42.8		
	10%	DB	41.6	45.2	53.4	64.2	70.3	78.4	80.5	78.7	68.8	60.0	49.5	43.3		
		MCWB	39.0	40.9	46.3	52.9	58.7	64.9	67.1	66.1	60.5	55.0	46.5	40.8		
	0.4%	WB	48.6	48.6	53.9	61.1	68.1	73.0	73.0	72.2	67.8	61.4	54.3	48.8		
		MCDB	52.4	55.2	65.0	74.9	80.5	86.2	87.7	87.2	78.3	68.5	59.3	52.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	44.9	46.0	51.2	57.8	64.7	70.2	70.4	70.1	65.6	59.0	51.3	46.1		
		MCDB	48.6	51.2	59.7	70.0	76.8	81.9	83.8	83.4	75.8	64.8	55.3	49.5		
	5%	WB	42.2	43.6	49.2	55.7	62.4	68.0	69.0	68.4	63.7	57.2	49.2	43.1		
		MCDB	45.0	48.3	56.1	66.4	73.0	79.6	81.2	80.0	71.3	62.0	52.5	45.5		
	10%	WB	39.1	41.2	46.9	53.5	60.0	66.1	67.4	66.9	61.7	55.5	46.8	40.8		
		MCDB	41.5	44.8	52.7	62.3	68.5	75.8	78.3	76.9	67.2	59.6	49.3	43.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	9.2	12.0	15.6	18.4	17.4	17.9	18.3	17.9	15.8	14.0	9.6	9.0		
		MCDBR	13.5	18.4	24.8	27.1	26.1	24.8	25.5	25.3	22.3	20.4	15.8	14.4		
		MCWBR	10.1	12.3	14.8	13.9	12.7	10.7	10.3	10.8	11.4	12.6	11.1	10.8		
		MCDBR	13.1	17.4	23.1	25.1	24.1	22.3	22.7	23.3	20.4	18.5	14.4	13.8		
	5% WB	MCWBR	10.2	11.9	14.2	13.3	12.0	10.3	9.6	10.4	10.9	12.0	10.5	10.7		
(40) Clear-Sky Solar Irradiance	taub		0.297	0.322	0.361	0.394	0.402	0.406	0.412	0.406	0.380	0.350	0.323	0.296		
	taud		2.407	2.349	2.309	2.265	2.279	2.304	2.283	2.319	2.364	2.435	2.462	2.446		
	Ebn at Noon		246	263	270	271	273	272	268	265	260	251	234	232		
	Edh at Noon		21	28	34	40	41	40	40	37	32	26	20	18		
(44) All-Sky Solar Radiation	RadAvg		344	639	969	1352	1564	1726	1689	1487	1067	692	363	266		
	RadStd		53	85	117	171	187	159	161	161	141	75	48	35		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (96 neighbors)	+0.86	N/A	N/A	N/A	+0.68	+0.68	N/A	N/A	+122	+49	

Nomenclature: See separate page