

SCHAERDING, Austria

WMO: 110550

Lat: 48.464N

Lon: 13.434E

Elev: 1026

StdP: 14.16

Time Zone: 1.00 (EUC)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.0	16.9	7.6	8.4	13.4	12.7	10.9	18.2	14.2	41.1	12.3	41.6	2.7	340	0.450

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.0	87.8	69.4	84.3	67.9	81.2	66.6	70.9	84.1	69.3	81.4	67.8	78.5	3.5	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.7	101.9	75.2	65.3	97.2	73.5	64.0	92.8	72.2	35.3	84.1	34.0	82.0	32.7	78.7	77.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.2	9.3	7.6	DB	7.2	94.0	6.4	2.8	2.6	96.0	-1.1	97.6	-4.7	99.2	-9.3	101.2	(4)
(5)			WB	6.1	74.3	6.2	1.6	1.6	75.4	-2.0	76.4	-5.5	77.3	-10.0	78.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	50.2	31.0	34.3	42.1	51.4	59.0	65.4	67.6	67.3	58.9	50.4	40.4	34.0		
	DBStd	14.57	7.55	7.52	7.11	7.13	6.56	6.31	5.80	5.73	5.76	6.29	6.29	6.37		
	HDD50	2224	590	441	255	66	8	0	0	0	3	73	292	496		
	HDD65	5746	1055	861	711	409	207	73	41	42	197	452	737	961		
	CDD50	2310	0	0	9	109	285	462	545	537	271	87	5	0		
	CDD65	358	0	0	0	2	20	85	121	115	15	0	0	0		
	CDH74	3183	0	0	0	42	241	817	1037	920	123	3	0	0		
	CDH80	941	0	0	0	4	43	237	341	295	21	0	0	0		
(14) Wind	WSAvg	3.2	3.7	3.5	4.1	3.7	3.2	2.8	2.7	2.7	2.7	3.1	3.1	3.3		
(15) Precipitation	PrecAvg	35.7	2.3	2.0	2.6	2.2	3.6	4.2	4.4	3.9	3.0	2.5	2.4	2.5		
	PrecMax	47.9	5.4	4.4	5.7	5.2	7.2	8.6	9.7	10.0	6.0	5.0	4.9	4.4		
	PrecMin	24.6	0.4	0.4	0.4	0.2	0.7	1.2	0.8	0.7	1.0	0.8	0.1	0.6		
	PrecStd	4.6	1.3	1.1	1.5	1.2	1.7	1.7	2.0	1.8	1.3	1.2	1.1	1.2		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.7	55.5	66.6	79.1	84.9	90.0	92.3	92.4	82.6	72.7	60.9	51.9		
		MCWB	47.2	47.4	52.1	60.2	65.8	70.5	71.2	70.2	67.3	59.9	52.9	47.6		
	2%	DB	46.6	51.0	61.6	73.6	80.4	86.0	87.5	86.9	77.3	67.3	55.6	47.8		
		MCWB	43.5	45.0	50.5	57.7	64.5	68.5	69.5	69.3	65.0	58.0	50.3	44.9		
	5%	DB	43.5	47.4	57.4	69.6	76.3	82.5	83.6	82.9	73.2	63.5	51.8	44.6		
		MCWB	40.9	42.5	48.4	55.8	61.8	67.3	67.9	67.9	63.0	56.7	48.4	42.1		
	10%	DB	40.4	44.0	53.2	65.5	72.3	78.9	79.9	79.0	69.2	59.8	48.8	42.1		
		MCWB	38.3	40.5	46.7	53.7	59.6	65.5	66.7	66.3	61.0	55.0	46.3	40.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.7	48.7	53.6	61.4	68.2	72.9	73.2	72.5	68.4	62.0	53.9	48.4		
		MCDB	51.5	54.3	63.3	76.3	81.8	86.2	87.6	86.3	78.8	68.1	59.4	51.3		
	2%	WB	43.6	45.6	51.3	58.8	65.4	70.0	71.0	70.3	66.1	59.4	51.3	45.4		
		MCDB	46.1	50.3	59.6	72.3	77.6	83.3	84.1	83.2	75.4	65.2	54.7	47.6		
	5%	WB	41.1	43.0	49.3	56.5	63.1	68.1	69.2	68.8	64.1	57.4	48.7	42.4		
		MCDB	43.3	46.7	56.0	67.9	73.7	79.6	80.9	80.4	71.6	62.5	51.2	44.2		
	10%	WB	38.5	40.7	47.3	54.3	60.9	66.4	67.5	67.2	62.0	55.5	46.5	40.3		
		MCDB	40.2	43.8	52.6	63.8	69.9	76.4	77.4	77.0	67.6	59.4	48.7	42.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	9.0	12.2	16.0	19.2	18.6	19.3	19.0	19.2	17.0	14.5	9.2	7.9		
		MCDBR	12.5	18.5	25.1	28.0	27.3	26.9	26.7	26.8	23.8	20.6	15.4	12.2		
	5% WB	MCWBR	9.3	12.4	14.1	13.2	11.9	11.0	10.2	10.3	11.4	11.9	10.2	9.3		
		MCWBR	12.1	17.3	22.9	26.5	25.1	24.1	24.4	24.8	22.0	19.0	14.5	11.9		
(40) Clear-Sky Solar Irradiance	taub		0.303	0.328	0.369	0.403	0.410	0.413	0.422	0.414	0.388	0.357	0.329	0.302		
	taud		2.389	2.336	2.288	2.236	2.255	2.282	2.259	2.296	2.340	2.411	2.442	2.434		
	Ebn at Noon		242	260	266	268	270	270	265	262	257	247	230	227		
	Edh at Noon		21	28	35	41	42	41	41	38	33	26	21	18		
(44) All-Sky Solar Radiation	RadAvg		323	617	955	1371	1594	1759	1700	1490	1064	669	342	245		
	RadStd		53	84	117	175	191	154	160	154	140	74	40	29		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (92 neighbors)		+0.86	N/A	N/A	N/A	+0.68	+0.68	N/A	N/A	+119	+45

Nomenclature: See separate page