

SCHAERDING, Austria

WMO: 110550

Lat: 48.464N

Lon: 13.434E

Elev: 313

StdP: 97.62

Time Zone: 1.00 (EUC)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.1	-8.4	-13.6	1.2	-10.3	-10.7	1.6	-7.6	6.3	5.1	5.5	5.3	1.2	340	0.450

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.5	31.0	20.8	29.1	20.0	27.4	19.2	21.6	28.9	20.7	27.5	19.9	25.8	1.6	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.3	14.6	24.0	18.5	13.9	23.1	17.8	13.3	22.3	64.2	29.0	61.1	27.8	58.2	26.0	25.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
5.0	4.1	3.4	-13.8	34.4	3.5	1.6	-16.3	35.5	-18.4	36.4	-20.4	37.3	-23.0	38.4		
			-14.4	23.5	3.4	0.9	-16.9	24.1	-18.9	24.7	-20.8	25.2	-23.3	25.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.1	-0.6	1.3	5.6	10.8	15.0	18.6	19.8	19.6	15.0	10.2	4.7	1.1
	DBStd	8.09	4.20	4.18	3.95	3.96	3.65	3.51	3.22	3.18	3.20	3.49	3.50	3.54
	HDD10.0	1236	328	245	142	37	4	0	0	0	2	41	162	276
	HDD18.3	3192	586	478	395	227	115	41	23	23	109	251	409	534
	CDD10.0	1283	0	0	5	61	158	257	303	298	151	48	3	0
	CDD18.3	199	0	0	0	1	11	47	67	64	8	0	0	0
	CDH23.3	1768	0	0	0	23	134	454	576	511	68	2	0	0
	CDH26.7	523	0	0	0	2	24	132	189	164	12	0	0	0
Wind	WSAvg	1.4	1.6	1.6	1.8	1.6	1.4	1.2	1.2	1.2	1.2	1.4	1.4	1.5
Precipitation	PrecAvg	906	58	51	66	56	92	106	113	99	76	64	62	63
	PrecMax	1216	138	113	146	133	182	219	246	255	152	127	124	111
	PrecMin	625	9	11	9	6	18	30	21	17	25	21	2	15
	PrecStd	116	33	28	38	30	43	43	50	45	33	31	29	30
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.5	13.1	19.2	26.1	29.4	32.2	33.5	33.6	28.1	22.6	16.1	11.1
		MCWB	8.5	8.5	11.2	15.7	18.8	21.4	21.8	21.2	19.6	15.5	11.6	8.7
	2%	DB	8.1	10.6	16.4	23.1	26.9	30.0	30.9	30.5	25.2	19.6	13.1	8.8
		MCWB	6.4	7.2	10.3	14.3	18.1	20.3	20.9	20.7	18.3	14.4	10.2	7.2
	5%	DB	6.4	8.6	14.1	20.9	24.6	28.1	28.7	28.3	22.9	17.5	11.0	7.0
		MCWB	4.9	5.8	9.1	13.2	16.6	19.6	19.9	19.9	17.2	13.7	9.1	5.6
	10%	DB	4.7	6.6	11.8	18.6	22.4	26.1	26.6	26.1	20.7	15.5	9.3	5.6
		MCWB	3.5	4.7	8.2	12.0	15.4	18.6	19.3	19.1	16.1	12.8	8.0	4.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.7	9.3	12.0	16.3	20.1	22.7	22.9	22.5	20.2	16.7	12.2	9.1
		MCDB	10.8	12.4	17.4	24.6	27.6	30.1	30.9	30.2	26.0	20.1	15.2	10.7
	2%	WB	6.4	7.5	10.7	14.9	18.6	21.1	21.6	21.3	19.0	15.2	10.7	7.4
		MCDB	7.8	10.1	15.3	22.4	25.3	28.5	28.9	28.4	24.1	18.5	12.6	8.7
	5%	WB	5.0	6.1	9.6	13.6	17.3	20.1	20.7	20.5	17.8	14.1	9.3	5.8
		MCDB	6.3	8.2	13.3	20.0	23.2	26.4	27.2	26.9	22.0	17.0	10.7	6.8
	10%	WB	3.6	4.8	8.5	12.4	16.1	19.1	19.7	19.6	16.7	13.1	8.0	4.6
		MCDB	4.6	6.5	11.5	17.7	21.1	24.6	25.2	25.0	19.8	15.2	9.3	5.6
Mean Daily Temperature Range	5% DB	MDBR	5.0	6.8	8.9	10.7	10.3	10.7	10.5	10.7	9.5	8.0	5.1	4.4
		MCDBR	7.0	10.3	13.9	15.6	15.2	15.0	14.9	14.9	13.2	11.5	8.5	6.8
		MCWBR	5.2	6.9	7.9	7.3	6.6	6.1	5.7	5.7	6.4	6.6	5.7	5.1
	5% WB	MCDBR	6.7	9.6	12.7	14.7	13.9	13.4	13.5	13.8	12.2	10.5	8.1	6.6
		MCWBR	5.2	6.7	7.4	7.2	6.4	5.8	5.5	5.5	6.0	6.4	5.5	5.2
Clear-Sky Solar Irradiance	taub	0.303	0.328	0.369	0.403	0.410	0.413	0.422	0.414	0.388	0.357	0.329	0.302	
	taud	2.389	2.336	2.288	2.236	2.255	2.282	2.259	2.296	2.340	2.411	2.442	2.434	
	Ebn at Noon	762	820	839	845	852	850	836	825	811	778	725	717	
	Edh at Noon	67	89	110	128	131	128	129	120	104	82	65	58	
All-Sky Solar Radiation	RadAvg	1.02	1.94	3.01	4.32	5.03	5.55	5.36	4.70	3.35	2.11	1.08	0.77	
	RadStd	0.17	0.26	0.37	0.55	0.60	0.48	0.50	0.48	0.44	0.23	0.13	0.09	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (92 neighbors)	+0.48	N/A	N/A	N/A	+0.38	+0.38	N/A	N/A	+66	+25

Nomenclature: See separate page