

LINZ STADT, Austria

WMO: 110600

Lat: 48.296N

Lon: 14.285E

Elev: 859

StdP: 14.25

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	15.7	19.4	9.5	9.2	17.6	13.9	11.5	21.8	7.8	35.1	7.5	35.0	2.8	220	0.419

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.7	88.3	69.7	84.8	68.4	81.8	67.0	71.3	84.2	69.6	81.8	68.1	79.0	3.4	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.0	102.7	76.9	65.6	97.5	74.5	64.3	93.0	73.0	35.6	84.1	34.1	82.1	32.9	79.1	78.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.8	7.1	6.0	12.0	93.4	6.0	2.7	7.7	95.4	4.2	97.0	0.9	98.5	-3.5	100.5		
			11.3	74.1	5.8	1.9	7.1	75.5	3.7	76.6	0.4	77.6	-3.8	79.0		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	51.3	31.8	35.8	43.0	52.7	60.1	66.1	69.0	68.5	59.9	51.0	41.9	34.6	
	DBStd	14.64	7.01	7.24	7.11	7.65	6.74	6.87	6.03	6.09	5.90	6.37	6.31	6.53	
	HDD50	2057	564	399	232	60	4	0	0	0	2	66	253	477	
	HDD65	5459	1029	818	681	373	182	70	30	33	175	433	694	941	
	CDD50	2526	0	1	16	141	317	482	589	575	298	98	9	0	
	CDD65	453	0	0	0	4	30	101	154	143	21	0	0	0	
	CDH74	3599	0	0	0	49	252	840	1229	1106	121	2	0	0	
	CDH80	1056	0	0	0	5	40	248	397	349	17	0	0	0	
Wind	WSAvg	2.7	2.7	2.8	2.9	3.0	3.0	2.8	2.7	2.7	2.5	2.6	2.5	2.5	
Precipitation	PrecAvg	33.1	1.5	2.1	2.2	2.4	3.8	4.6	3.8	3.5	2.4	2.0	2.4	2.4	
	PrecMax	42.6	3.3	7.6	4.3	3.9	6.7	6.7	7.5	7.4	3.7	5.5	3.8	6.2	
	PrecMin	21.1	0.2	0.6	0.6	0.8	1.7	2.0	1.4	0.8	1.1	0.1	1.0	0.2	
	PrecStd	6.3	1.1	1.7	1.1	1.0	1.7	1.3	1.8	1.9	0.8	1.5	0.8	1.9	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.0	56.9	67.0	79.6	84.3	90.5	92.5	92.5	82.1	72.1	62.6	52.1	
		MCWB	47.3	47.7	52.6	60.2	66.4	70.0	70.7	69.5	66.7	59.8	53.7	48.0	
	2%	DB	47.6	52.1	62.0	74.0	80.4	86.3	88.1	87.6	77.5	66.8	57.1	48.2	
		MCWB	43.7	45.7	51.0	58.5	64.7	69.5	69.6	69.2	64.7	58.1	51.5	44.7	
	5%	DB	44.1	48.7	57.6	70.0	76.7	82.6	84.4	83.7	73.6	63.4	53.4	45.1	
		MCWB	41.2	43.5	48.5	56.4	62.8	67.4	68.6	68.0	63.1	56.8	49.5	42.5	
	10%	DB	41.0	45.2	53.7	66.0	72.9	79.0	81.0	80.3	70.1	60.3	50.1	42.8	
		MCWB	38.7	41.3	46.6	54.5	60.3	65.8	67.0	66.6	61.2	55.4	47.1	40.8	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.2	49.5	54.1	61.6	68.5	73.3	73.7	73.0	68.0	61.9	54.8	48.4
			MCDB	51.8	55.3	64.4	76.4	80.4	86.2	87.5	86.9	77.5	67.9	60.6	51.2
2%		WB	44.2	46.5	51.6	59.2	65.7	70.7	71.4	70.5	65.8	59.5	52.1	45.4	
		MCDB	47.2	51.6	60.0	72.5	77.7	83.0	84.1	83.8	75.2	64.5	56.2	47.7	
5%		WB	41.5	43.9	49.5	57.1	63.7	68.7	69.6	68.8	64.1	57.7	49.7	42.9	
		MCDB	43.9	48.0	56.1	68.1	74.6	79.9	81.5	81.0	71.9	62.3	53.2	44.7	
10%		WB	38.8	41.6	47.4	55.0	61.6	66.9	68.0	67.4	62.4	55.8	47.4	40.8	
		MCDB	40.8	44.9	52.9	64.8	71.0	76.8	78.4	78.0	68.6	59.7	49.9	42.8	
Mean Daily Temperature Range	5% DB	MDBR	7.3	10.5	13.8	16.5	16.2	16.1	16.7	16.6	14.3	12.3	8.1	6.9	
		MCDBR	10.7	17.0	21.9	23.8	23.1	22.7	22.8	22.8	19.9	16.9	14.1	10.9	
		MCWBR	7.6	10.8	12.0	11.1	10.2	9.1	8.4	8.4	8.7	9.4	8.9	8.2	
	5% WB	MCDBR	10.4	15.6	19.9	22.1	21.2	20.9	20.4	20.6	17.8	15.3	13.1	10.4	
		MCWBR	7.8	10.5	11.4	10.7	9.9	8.8	8.1	8.2	8.5	9.0	8.7	8.3	
Clear-Sky Solar Irradiance	taub	0.300	0.326	0.367	0.403	0.411	0.414	0.422	0.416	0.388	0.356	0.329	0.300		
	taud	2.387	2.339	2.294	2.250	2.270	2.294	2.275	2.307	2.357	2.429	2.455	2.438		
	Ebn at Noon	244	261	267	268	270	270	265	261	258	248	231	230		
	Edh at Noon	22	28	35	40	41	40	41	37	32	26	20	18		
All-Sky Solar Radiation	RadAvg	331	614	948	1356	1569	1717	1671	1486	1063	677	352	262		
	RadStd	49	80	117	164	183	150	160	155	138	75	41	31		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+1.19	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (104 neighbors)		+0.94	N/A	N/A	N/A	+0.70	+0.61	N/A	-254	+126	+56

Nomenclature: See separate page