

LILIENFELD TARSCHBERG, Austria

WMO: 110780

Lat: 48.028N

Lon: 15.588E

Elev: 2282

StdP: 13.52

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.9	14.8	5.0	7.7	13.8	9.6	9.8	17.4	24.0	35.7	22.4	34.9	5.5	220	0.523

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.8	82.7	67.3	79.3	66.0	76.3	64.5	68.8	79.6	66.9	77.3	65.2	74.9	4.9	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
64.7	99.6	75.5	62.8	93.1	73.0	61.3	88.1	70.9	34.3	79.9	32.7	77.1	31.4	75.2	77.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
19.9	17.1	14.7	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			7.9	87.8	5.7	2.9	3.8	89.9	0.5	91.6	-2.7	93.2	-6.8	95.3
			7.3	72.8	5.4	1.9	3.4	74.2	0.3	75.3	-2.7	76.4	-6.6	77.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	47.4	29.4	32.4	38.2	47.4	54.8	61.1	64.3	64.3	55.8	48.4	39.4	32.5	(6)
	DBStd	14.60	8.84	9.27	8.36	8.65	7.36	7.36	6.52	6.65	6.91	7.80	8.26	8.49	(7)
	HDD50	2721	640	495	373	146	36	7	0	1	23	126	331	543	(8)
	HDD65	6629	1105	914	832	529	324	160	94	95	284	516	768	1008	(9)
	CDD50	1772	0	1	6	68	185	339	442	444	198	76	13	0	(10)
	CDD65	203	0	0	0	1	8	41	71	73	8	1	0	0	(11)
	CDH74	1195	0	0	0	4	26	243	436	456	29	1	0	0	(12)
	CDH80	231	0	0	0	0	0	41	90	98	2	0	0	0	(13)
	WSAvg	6.6	7.8	7.6	7.4	6.9	6.1	5.9	5.9	5.6	5.5	6.1	6.9	7.3	(14)
(15) Precipitation	PrecAvg	33.7	1.7	1.7	2.4	2.3	3.7	4.3	4.4	3.9	3.1	2.2	2.2	1.9	(15)
	PrecMax	44.5	4.3	4.0	5.2	4.8	9.4	11.6	12.1	10.3	9.1	5.4	3.9	3.9	(16)
	PrecMin	22.6	0.1	0.3	0.4	0.2	1.1	1.5	1.5	1.0	0.6	0.2	0.0	0.5	(17)
	PrecStd	5.4	0.9	1.0	1.2	1.1	2.0	2.2	2.4	2.2	1.9	1.5	1.0	0.8	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.3	56.3	62.1	72.9	77.0	84.4	86.7	87.0	77.3	69.6	62.6	54.8	(19)
		MCWB	44.2	44.6	48.6	56.7	63.5	67.9	68.5	66.8	63.7	57.5	52.2	45.3	(20)
	2%	DB	49.0	51.3	57.6	68.1	73.6	80.2	82.4	82.7	73.3	65.8	58.8	50.3	(21)
		MCWB	42.4	42.6	47.0	54.7	61.7	67.3	67.4	66.9	62.6	56.1	50.1	43.4	(22)
	5%	DB	45.4	48.1	53.9	64.0	70.3	76.5	78.7	79.0	69.6	62.3	55.5	47.4	(23)
		MCWB	40.4	41.2	45.2	52.5	59.8	64.9	65.8	65.7	60.3	54.5	48.1	41.7	(24)
	10%	DB	41.8	44.9	50.3	60.3	66.7	73.2	75.5	75.6	66.4	59.2	51.7	44.5	(25)
		MCWB	37.7	39.4	43.5	50.3	57.5	62.9	64.3	64.2	58.9	53.0	46.2	40.0	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.8	46.3	50.2	58.2	65.9	70.9	71.4	70.8	66.0	59.6	53.3	46.7	(27)
		MCDB	50.2	53.4	59.3	71.2	74.6	80.7	82.7	81.8	74.5	66.5	60.3	51.3	(28)
	2%	WB	42.9	43.6	47.8	55.4	63.0	67.8	68.8	68.1	63.3	57.4	50.7	44.8	(29)
		MCDB	48.1	49.8	55.7	66.2	71.6	78.1	79.6	79.4	71.3	63.3	57.7	49.4	(30)
	5%	WB	40.7	41.7	45.9	53.1	60.5	65.6	66.7	66.3	61.1	55.6	48.7	42.6	(31)
		MCDB	45.0	47.5	52.3	62.6	68.7	75.4	76.9	77.1	68.1	60.2	54.6	47.1	(32)
	10%	WB	37.9	39.6	44.1	51.0	58.1	63.5	65.0	64.6	59.4	53.8	46.5	39.9	(33)
		MCDB	41.3	44.8	49.9	59.2	65.9	72.2	74.2	74.4	65.4	58.5	50.9	43.9	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	7.9	9.0	10.7	13.1	13.1	13.6	13.8	14.0	11.5	10.7	8.5	8.2	(35)
		MCDBR	11.5	13.7	16.6	18.0	18.2	18.6	19.3	19.2	16.3	14.7	13.7	13.5	(36)
	5% WB	MCWBR	7.6	8.5	9.9	10.2	11.1	10.5	9.7	9.0	9.1	8.9	8.1	9.1	(37)
		MCWBR	10.9	12.4	15.3	16.5	17.1	17.8	17.9	18.0	15.3	13.0	12.4	12.8	(38)
(40) Clear-Sky Solar Irradiance	taub		0.287	0.311	0.349	0.387	0.390	0.396	0.401	0.398	0.372	0.343	0.316	0.287	(40)
		taud	2.418	2.373	2.328	2.277	2.307	2.320	2.304	2.329	2.379	2.446	2.474	2.459	(41)
	Ebn at Noon		252	269	274	273	277	275	272	267	264	254	238	238	(42)
		Edh at Noon	21	27	34	39	39	39	39	37	32	25	20	18	(43)
(44) All-Sky Solar Radiation	RadAvg		343	620	955	1346	1561	1704	1669	1491	1071	696	371	277	(44)
	RadStd		44	79	115	152	178	141	157	159	136	73	45	35	(45)

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (100 neighbors)		+0.95	N/A	N/A	N/A	+0.77	+0.70	-209	-263	+142	+67

Nomenclature: See separate page