

FELDKIRCH, Austria

WMO: 111050

Lat: 47.271N

Lon: 9.610E

Elev: 436

StdP: 96.20

Time Zone: 1.00 (EUC)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -9.6	(c) -7.6	(d) -11.4	(e) 1.5	(f) -8.6	(g) -9.5	(h) 1.8	(i) -6.3	(j) 5.5	(k) 6.8	(l) 4.6	(m) 5.2	(n) 1.0	(o) 20	(p) 0.435

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 8.9	(c) 30.1	(d) 21.0	(e) 28.2	(f) 20.2	(g) 26.5	(h) 19.5	(i) 21.8	(j) 28.6	(k) 20.8	(l) 26.9	(m) 20.0	(n) 25.6	(o) 1.8	(p) 0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.4	14.9	25.9	18.5	14.1	24.6	17.8	13.5	23.3	65.7	28.7	62.1	27.1	59.1	25.7	25.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 4.6	(b) 3.8	(c) 3.2	(e) -11.6	(f) 32.8	(g) 2.8	(h) 2.0	(i) -13.6	(j) 34.3	(k) -15.2	(l) 35.5	(m) -16.8	(n) 36.6	(o) -18.8	(p) 38.1		
(a) 4.6	(b) 3.8	(c) 3.2	(e) -11.6	(f) 23.5	(g) 2.7	(h) 1.0	(i) -13.6	(j) 24.2	(k) -15.2	(l) 24.7	(m) -16.7	(n) 25.3	(o) -18.7	(p) 26.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.2	0.2	2.1	6.1	10.2	14.5	18.1	19.5	19.0	14.6	11.0	5.2	1.5
	DBStd	7.82	4.32	4.53	4.19	4.16	3.85	3.99	3.48	3.20	3.26	3.71	4.16	4.17
	HDD10.0	1162	303	221	131	47	6	1	0	0	3	34	153	264
	HDD18.3	3137	561	453	378	243	128	52	28	31	118	229	395	521
	CDD10.0	1246	1	1	11	54	147	245	293	279	142	63	8	2
	CDD18.3	179	0	0	0	1	11	46	63	52	7	1	0	0
	CDH23.3	1359	0	0	0	8	94	384	471	358	38	5	0	0
	CDH26.7	340	0	0	0	1	14	107	129	86	2	0	0	0
Wind	WSAvg	1.3	1.2	1.3	1.5	1.6	1.4	1.4	1.3	1.2	1.1	1.1	1.2	1.2
Precipitation	PrecAvg	1400	69	77	88	101	138	171	168	170	124	96	104	91
	PrecMax	1799	150	210	177	188	321	314	311	291	200	208	238	192
	PrecMin	1067	7	21	30	32	19	65	65	49	57	9	7	10
	PrecStd	155	40	41	37	42	67	61	65	60	39	43	50	43
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.5	15.9	19.7	24.3	28.6	32.5	32.5	31.8	26.6	23.8	19.8	17.0
		MCWB	8.2	9.0	11.7	14.5	18.5	21.0	22.3	21.8	19.3	14.6	11.3	9.0
	2%	DB	9.5	12.9	17.2	22.2	26.0	29.5	30.0	29.1	24.4	20.5	16.6	11.0
		MCWB	6.2	7.2	10.5	13.8	17.5	20.3	21.1	21.4	18.5	14.9	10.5	7.3
	5%	DB	7.6	10.6	15.1	20.1	23.8	27.4	27.8	27.0	22.4	18.4	13.3	8.5
		MCWB	5.3	6.5	9.6	13.1	16.3	19.7	20.4	20.4	17.4	13.9	9.7	6.4
	10%	DB	5.7	8.5	13.0	17.8	21.7	25.4	25.9	25.2	20.5	16.6	10.7	6.9
		MCWB	4.2	5.4	8.6	11.8	15.3	18.7	19.5	19.5	16.4	13.3	8.6	5.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.0	9.7	12.5	15.9	19.7	22.5	22.9	23.0	20.3	16.7	12.4	9.6
		MCDB	11.5	14.4	18.2	22.8	26.7	29.8	30.6	29.9	24.9	20.2	17.0	14.5
	2%	WB	6.8	8.0	11.1	14.4	18.1	21.1	21.8	21.8	18.9	15.6	11.0	8.0
		MCDB	8.9	11.7	16.2	20.9	24.5	27.8	28.8	28.0	23.2	18.7	15.0	11.0
	5%	WB	5.4	6.8	10.0	13.3	16.8	20.0	20.8	20.7	17.8	14.5	9.9	6.7
		MCDB	7.2	10.1	14.2	19.3	22.6	26.4	27.0	26.2	21.6	17.5	13.1	8.4
	10%	WB	4.2	5.5	8.9	12.1	15.7	19.0	19.8	19.8	16.7	13.6	8.7	5.3
		MCDB	5.7	8.3	12.5	17.2	20.8	24.8	25.2	24.7	19.9	16.3	10.7	6.7
Mean Daily Temperature Range	5% DB	MDBR	5.5	7.3	8.8	9.4	9.2	8.9	8.9	8.7	8.4	7.9	6.2	5.4
		MCDBR	7.9	11.3	12.7	12.7	12.7	12.3	12.0	11.8	10.9	10.8	10.3	7.9
		MCWBR	5.2	6.9	7.4	6.8	6.4	6.0	5.8	6.3	6.1	6.2	5.9	5.0
	5% WB	MCDBR	7.0	10.3	11.5	11.9	11.3	11.2	11.0	11.0	10.1	9.6	8.8	7.4
		MCWBR	4.8	6.5	6.9	6.7	6.2	5.8	5.6	6.1	6.0	6.0	5.4	4.8
Clear-Sky Solar Irradiance	taub	0.285	0.312	0.356	0.402	0.418	0.425	0.427	0.417	0.383	0.350	0.315	0.282	
	taud	2.367	2.290	2.246	2.208	2.229	2.258	2.255	2.298	2.371	2.443	2.462	2.404	
	Ebn at Noon	803	847	858	850	848	841	834	826	823	799	762	763	
	Edh at Noon	70	94	116	133	135	132	131	120	102	82	65	61	
All-Sky Solar Radiation	RadAvg	1.26	2.13	3.33	4.35	4.93	5.67	5.53	4.83	3.65	2.34	1.34	1.04	
	RadStd	0.14	0.28	0.45	0.63	0.50	0.53	0.50	0.49	0.38	0.26	0.17	0.15	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (113 neighbors)		N/A	N/A	N/A	+0.66	+0.44	+0.37	N/A	N/A	+56	+14

Nomenclature: See separate page