

LANDECK, Austria

WMO: 111120

Lat: 47.140N

Lon: 10.564E

Elev: 2654

StdP: 13.34

Time Zone: 1.00 (EUC)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.2	16.5	7.0	8.7	16.3	9.7	10.0	19.2	16.2	37.6	14.4	35.3	4.0	260	0.488

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.2	86.3	65.4	82.7	64.0	79.4	62.9	67.0	81.5	65.5	78.8	64.1	76.1	4.1	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.6	93.9	70.0	61.1	88.7	68.6	59.8	84.7	67.7	33.0	81.6	31.7	78.9	30.6	76.3	76.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.1	10.0	8.6	9.3	91.3	4.5	3.4	6.1	93.7	3.5	95.7	1.0	97.6	-2.3	100.1		
(5)			8.3	70.4	4.2	2.1	5.2	71.9	2.7	73.1	0.4	74.3	-2.7	75.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	48.8	30.2	34.2	42.4	49.4	56.5	62.7	65.4	64.6	57.0	50.1	39.3	32.3		
	DBStd	14.00	6.71	7.61	7.02	6.84	6.41	7.33	6.27	6.13	6.01	6.27	7.02	6.70		
	HDD50	2378	613	444	247	93	16	3	0	1	11	76	324	550		
	HDD65	6161	1078	863	702	469	271	127	73	84	247	462	770	1015		
	CDD50	1921	0	0	10	74	218	385	478	453	220	79	4	0		
	CDD65	231	0	0	0	0	8	59	86	71	7	0	0	0		
	CDH74	2213	0	0	0	6	124	637	766	620	60	0	0	0		
	CDH80	622	0	0	0	0	18	199	228	172	5	0	0	0		
	WSAvg	3.7	4.5	4.2	4.0	3.5	3.4	3.4	3.4	3.2	3.0	3.5	3.6	4.3		
	PrecAvg	36.6	2.1	2.0	2.3	2.0	3.2	4.3	5.0	5.3	3.1	2.6	2.5	2.3		
(15) Precipitation	PrecMax	45.6	6.1	8.0	5.4	4.2	6.4	6.8	7.6	9.3	5.4	5.7	5.6	5.7		
	PrecMin	29.6	0.3	0.4	0.6	0.6	1.3	2.4	3.0	1.9	1.4	0.2	0.2	0.4		
	PrecStd	4.1	1.5	1.7	1.3	0.8	1.3	1.1	1.3	1.5	1.0	1.3	1.3	1.3		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.3	55.6	66.8	74.5	83.0	90.4	90.4	89.7	79.9	70.7	60.9	50.4		
		MCWB	42.0	44.0	49.4	56.7	62.1	65.7	66.6	67.6	62.8	56.0	48.8	43.0		
	2%	DB	44.1	50.5	62.5	70.7	77.9	85.4	86.0	84.7	75.2	66.2	55.1	45.1		
		MCWB	39.2	41.1	47.9	53.9	59.5	64.5	65.7	65.7	60.8	55.1	47.7	40.5		
	5%	DB	41.2	47.1	58.4	66.9	73.9	81.5	81.9	80.9	71.4	62.7	51.4	42.7		
		MCWB	37.1	39.3	45.9	51.9	57.8	63.0	64.4	64.1	58.8	53.5	45.5	39.2		
	10%	DB	38.8	43.8	54.1	63.0	70.0	77.1	78.0	77.0	67.9	59.5	48.3	40.5		
		MCWB	35.6	37.7	43.9	49.9	55.6	61.5	63.1	62.9	57.4	52.1	44.1	37.4		
	0.4%	WB	43.3	45.1	51.3	57.7	63.5	68.5	68.9	69.2	64.2	58.6	50.8	44.0		
		MCDB	46.6	53.0	63.5	72.6	79.4	84.5	85.2	84.4	75.8	66.0	56.9	47.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	39.7	42.1	48.7	55.1	61.0	65.9	67.0	66.9	62.0	56.6	48.3	41.5		
		MCDB	43.1	49.1	59.9	68.8	74.5	80.7	81.4	80.7	72.3	63.3	53.7	44.5		
	5%	WB	37.8	40.1	46.7	52.6	58.7	64.1	65.5	65.2	60.2	54.7	46.4	39.8		
		MCDB	40.5	45.8	56.8	64.9	70.8	78.1	78.5	77.6	69.1	61.1	50.7	42.2		
	10%	WB	36.0	38.0	44.6	50.6	56.8	62.4	64.0	63.7	58.5	52.8	44.5	37.9		
		MCDB	38.4	42.9	52.6	61.2	67.6	74.6	75.3	74.6	65.9	58.5	47.9	39.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	9.4	13.7	18.4	19.9	19.9	20.5	20.2	19.1	17.5	16.2	11.3	8.2		
		MCDBR	10.9	17.9	25.6	26.8	26.9	28.4	27.2	26.6	23.1	20.1	15.3	10.7		
		MCWBR	7.5	10.6	13.3	12.7	11.6	10.8	9.9	10.3	10.2	10.3	9.1	7.4		
		MCDBR	9.8	16.1	23.7	24.6	23.6	25.6	24.0	23.5	20.5	18.1	14.2	9.6		
	5% WB	MCWBR	7.2	10.1	12.6	12.0	10.9	10.2	9.6	9.9	9.5	9.8	8.8	7.1		
(40) Clear-Sky Solar Irradiance	taub		0.256	0.281	0.323	0.368	0.384	0.392	0.391	0.383	0.349	0.321	0.288	0.256		
	taud		2.362	2.293	2.255	2.259	2.302	2.326	2.329	2.370	2.442	2.494	2.489	2.413		
	Ebn at Noon		268	282	284	280	279	277	275	273	273	266	255	256		
	Edh at Noon		22	30	36	40	40	39	38	36	30	24	20	19		
(44) All-Sky Solar Radiation	RadAvg		456	753	1109	1382	1532	1730	1728	1524	1150	785	463	376		
	RadStd		52	90	128	185	173	161	153	156	131	93	72	50		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (108 neighbors)		+0.61	N/A	N/A	+1.13	+0.76	+0.70	N/A	N/A	+106	+29	

Nomenclature: See separate page