

LANDECK, Austria

WMO: 111120

Lat: 47.140N

Lon: 10.564E

Elev: 809

StdP: 91.98

Time Zone: 1.00 (EUC)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-10.5	-8.6	-13.9	1.2	-8.7	-12.4	1.4	-7.1	7.2	3.1	6.5	1.8	1.8	260	0.488

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.2	30.2	18.5	28.2	17.8	26.3	17.2	19.5	27.5	18.6	26.0	17.8	24.5	1.8	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.0	13.4	21.1	16.2	12.7	20.3	15.5	12.1	19.8	58.9	27.6	56.0	26.1	53.4	24.6	24.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.4	4.5	3.8	-12.6	32.9	2.5	1.9	-14.4	34.3	-15.8	35.4	-17.2	36.4	-19.0	37.8		
(5)			-13.2	21.3	2.4	1.2	-14.9	22.2	-16.3	22.9	-17.6	23.5	-19.3	24.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	9.3	-1.0	1.2	5.8	9.7	13.6	17.1	18.6	18.1	13.9	10.1	4.1	0.1
	DBStd	7.78	3.73	4.23	3.90	3.80	3.56	4.07	3.48	3.41	3.34	3.48	3.90	3.72
	HDD10.0	1321	341	247	137	52	9	2	0	1	6	42	180	306
	HDD18.3	3423	599	479	390	261	151	71	41	47	137	257	428	564
	CDD10.0	1067	0	0	6	41	121	214	266	252	122	44	2	0
	CDD18.3	128	0	0	0	0	4	33	48	39	4	0	0	0
	CDH23.3	1229	0	0	0	3	69	354	426	344	33	0	0	0
	CDH26.7	346	0	0	0	0	10	111	127	96	3	0	0	0
Wind	WSAvg	1.6	2.0	1.9	1.8	1.6	1.5	1.5	1.5	1.4	1.4	1.6	1.6	1.9
Precipitation	PrecAvg	930	54	51	58	50	81	109	127	134	79	65	64	58
	PrecMax	1158	154	203	138	107	163	172	194	235	136	144	143	144
	PrecMin	751	8	10	15	14	34	60	75	47	36	6	6	9
	PrecStd	105	37	43	34	21	32	27	32	39	26	33	34	33
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.0	13.1	19.3	23.6	28.3	32.4	32.4	32.0	26.6	21.5	16.0	10.2
		MCWB	5.6	6.7	9.6	13.7	16.7	18.7	19.2	19.8	17.1	13.3	9.3	6.1
	2%	DB	6.7	10.3	16.9	21.5	25.5	29.6	30.0	29.3	24.0	19.0	12.8	7.3
		MCWB	4.0	5.1	8.9	12.2	15.3	18.0	18.7	18.7	16.0	12.8	8.7	4.7
	5%	DB	5.1	8.4	14.7	19.4	23.3	27.5	27.7	27.2	21.9	17.1	10.8	6.0
		MCWB	2.8	4.1	7.7	11.0	14.3	17.2	18.0	17.9	14.9	11.9	7.5	4.0
	10%	DB	3.8	6.6	12.3	17.2	21.1	25.1	25.6	25.0	20.0	15.3	9.1	4.7
		MCWB	2.0	3.2	6.6	10.0	13.1	16.4	17.3	17.2	14.1	11.2	6.7	3.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.3	7.3	10.7	14.3	17.5	20.3	20.5	20.6	17.9	14.8	10.5	6.6
		MCDB	8.1	11.7	17.5	22.5	26.3	29.2	29.5	29.1	24.3	18.9	13.9	8.9
	2%	WB	4.3	5.6	9.3	12.9	16.1	18.8	19.4	19.4	16.7	13.6	9.0	5.3
		MCDB	6.2	9.5	15.5	20.5	23.6	27.0	27.5	27.1	22.4	17.4	12.1	6.9
	5%	WB	3.2	4.5	8.2	11.5	14.9	17.8	18.6	18.4	15.7	12.6	8.0	4.3
		MCDB	4.7	7.7	13.8	18.3	21.6	25.6	25.8	25.3	20.6	16.2	10.4	5.7
	10%	WB	2.2	3.4	7.0	10.3	13.8	16.9	17.8	17.6	14.7	11.6	6.9	3.3
		MCDB	3.6	6.0	11.4	16.2	19.8	23.7	24.1	23.7	18.8	14.7	8.8	4.4
Mean Daily Temperature Range	5% DB	MDBR	5.2	7.6	10.2	11.0	11.1	11.4	11.2	10.6	9.7	9.0	6.3	4.6
		MCDBR	6.1	10.0	14.2	14.9	14.9	15.8	15.1	14.8	12.8	11.2	8.5	6.0
		MCWBR	4.2	5.9	7.4	7.0	6.4	6.0	5.5	5.7	5.7	5.7	5.0	4.1
	5% WB	MCDBR	5.4	9.0	13.1	13.6	13.1	14.2	13.4	13.0	11.4	10.0	7.9	5.3
		MCWBR	4.0	5.6	7.0	6.7	6.1	5.6	5.3	5.5	5.3	5.4	4.9	3.9
Clear-Sky Solar Irradiance	taub	0.256	0.281	0.323	0.368	0.384	0.392	0.391	0.383	0.349	0.321	0.288	0.256	
	taud	2.362	2.293	2.255	2.259	2.302	2.326	2.329	2.370	2.442	2.494	2.489	2.413	
	Ebn at Noon	846	889	896	884	880	872	868	860	862	838	804	806	
	Edh at Noon	70	93	114	126	125	123	121	112	95	77	63	59	
All-Sky Solar Radiation	RadAvg	1.44	2.37	3.50	4.36	4.83	5.45	5.45	4.80	3.62	2.48	1.46	1.19	
	RadStd	0.17	0.28	0.40	0.58	0.54	0.51	0.48	0.49	0.41	0.29	0.23	0.16	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (108 neighbors)	+0.34	N/A	N/A	+0.63	+0.42	+0.39	N/A	N/A	+59	+16

Nomenclature: See separate page