

INNSBRUCK, Austria

WMO: 111200

Lat: 47.260N

Lon: 11.344E

Elev: 1946

StdP: 13.69

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.7	15.6	7.0	8.5	17.8	10.8	10.3	21.1	21.7	41.2	18.4	42.3	2.6	260	0.513

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.6	87.5	67.1	84.1	65.8	80.7	64.2	68.9	83.1	67.3	80.3	65.8	77.4	8.3	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
64.4	97.5	72.6	62.9	92.1	71.0	61.7	88.5	69.8	34.2	83.6	32.8	80.2	31.6	77.7	74.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.6	15.4	12.8	DB	7.4	92.7	4.7	2.6	4.0	94.5	1.2	96.0	-1.5	97.4	-4.9	99.3
			WB	6.9	71.4	4.7	2.2	3.6	73.0	0.9	74.2	-1.8	75.5	-5.1	77.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	49.8	30.9	34.7	42.9	50.3	58.2	64.3	66.8	66.0	58.5	51.2	40.5	32.5	(6)
	DBStd	14.31	6.78	7.39	6.92	7.01	6.56	6.82	5.72	5.73	5.87	6.42	7.30	6.61	(7)
	HDD50	2254	592	428	231	82	10	1	0	0	6	65	295	544	(8)
	HDD65	5838	1056	848	684	443	226	95	48	58	206	429	736	1009	(9)
	CDD50	2184	0	0	12	89	264	430	522	497	260	101	9	0	(10)
	CDD65	295	0	0	0	1	15	74	104	90	11	0	0	0	(11)
	CDH74	2863	0	0	0	26	237	750	933	796	117	4	0	0	(12)
	CDH80	843	0	0	0	2	50	236	299	246	10	0	0	0	(13)
(14) Wind	WSAvg	4.5	3.9	4.4	5.2	5.6	5.3	4.8	4.5	4.2	3.9	4.2	4.3	3.9	(14)
(15) Precipitation	PrecAvg	36.0	1.8	1.7	2.1	2.4	3.6	4.3	5.5	4.7	3.1	2.2	2.4	2.3	(15)
	PrecMax	52.9	4.8	5.9	4.9	4.4	7.7	7.8	11.3	11.5	6.5	7.1	6.3	6.7	(16)
	PrecMin	28.7	0.1	0.1	0.2	0.7	0.4	2.0	2.4	1.6	0.8	0.0	0.7	0.4	(17)
	PrecStd	5.8	1.2	1.3	1.1	1.0	1.6	1.5	1.8	2.0	1.3	1.5	1.3	1.4	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.6	59.2	68.2	77.2	85.3	91.0	91.3	90.4	81.0	73.6	64.7	55.2	(19)
		MCWB	43.0	45.6	51.3	57.8	63.8	67.1	68.5	68.3	64.2	57.6	51.2	45.8	(20)
	2%	DB	48.1	53.7	64.3	72.3	80.4	86.2	86.8	86.1	77.3	69.8	61.0	47.9	(21)
		MCWB	40.9	42.9	49.4	54.9	61.1	65.8	67.2	67.4	62.5	56.3	49.8	42.0	(22)
	5%	DB	42.7	50.1	60.5	68.4	75.6	82.4	83.4	82.4	73.8	66.3	56.9	43.4	(23)
		MCWB	38.2	40.7	47.8	53.3	58.7	64.1	66.2	65.8	60.8	54.8	48.0	39.9	(24)
	10%	DB	39.1	46.1	56.2	64.6	71.8	78.5	79.2	78.5	70.1	62.6	51.3	40.7	(25)
		MCWB	36.2	39.4	45.7	51.1	57.1	62.9	64.5	64.5	58.9	53.3	45.9	38.3	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.0	46.9	52.8	58.8	65.4	70.1	71.0	70.8	66.2	60.3	52.8	46.4	(27)
		MCDB	51.7	56.6	65.5	74.9	82.3	85.2	86.4	85.7	77.5	69.4	61.4	52.8	(28)
	2%	WB	41.1	44.0	50.2	56.3	62.6	67.9	68.8	68.7	63.8	58.1	50.6	43.2	(29)
		MCDB	46.1	51.4	61.6	70.8	76.3	81.6	83.0	82.6	74.1	66.0	58.7	46.5	(30)
	5%	WB	38.7	41.8	48.5	53.9	60.4	66.0	67.2	67.0	62.1	56.5	48.7	40.5	(31)
		MCDB	41.9	48.4	58.6	66.4	72.5	78.8	79.8	79.4	71.0	63.8	55.0	42.6	(32)
	10%	WB	36.5	39.4	46.6	52.1	58.5	64.1	65.6	65.4	60.3	54.6	46.3	38.3	(33)
		MCDB	38.5	44.8	54.6	63.0	69.1	75.1	76.5	76.1	67.8	61.0	51.0	40.0	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	14.0	16.7	19.8	20.7	20.9	20.6	20.6	19.8	18.7	18.7	14.7	12.8	(35)
		MCDBR	18.1	24.0	28.5	29.3	28.8	28.8	27.7	27.3	25.0	24.4	21.5	17.0	(36)
		MCWBR	11.5	13.8	14.9	14.1	11.9	10.8	10.5	10.7	11.6	12.3	11.9	11.4	(37)
	5% WB	MCDBR	15.4	21.8	25.8	26.6	26.1	25.5	25.0	25.0	22.7	21.3	18.8	14.4	(38)
		MCWBR	10.3	13.1	14.0	13.2	11.5	10.6	10.5	10.6	11.2	11.4	11.1	10.1	(39)
(40) Clear-Sky Solar Irradiance	taub		0.271	0.297	0.339	0.384	0.400	0.408	0.407	0.400	0.364	0.334	0.302	0.271	(40)
	taud		2.391	2.319	2.283	2.267	2.289	2.315	2.317	2.357	2.433	2.489	2.498	2.445	(41)
	Ebn at Noon		262	276	279	275	274	272	271	268	268	260	248	249	(42)
	Edh at Noon		22	29	35	40	40	40	39	36	30	25	20	18	(43)
(44) All-Sky Solar Radiation	RadAvg		443	739	1088	1371	1526	1720	1713	1514	1136	779	456	366	(44)
	RadStd		52	90	123	182	174	166	157	159	133	91	69	50	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+139	+74
(47)	Regional (89 neighbors)	+0.67	N/A	N/A	+1.13	+0.77	+0.76	N/A	N/A	+108	+22

Nomenclature: See separate page