

INNSBRUCK, Austria

WMO: 111200

Lat: 47.260N

Lon: 11.344E

Elev: 593

StdP: 94.40

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.3	-9.1	-13.9	1.2	-7.9	-11.8	1.5	-6.1	9.7	5.1	8.2	5.7	1.2	260	0.513

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.4	30.8	19.5	29.0	18.8	27.1	17.9	20.5	28.4	19.6	26.8	18.8	25.2	3.7	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.0	13.9	22.6	17.1	13.2	21.7	16.5	12.6	21.0	61.6	28.7	58.4	26.8	55.7	25.4	23.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.3	6.9	5.7	-13.7	33.7	2.6	1.4	-15.6	34.7	-17.1	35.6	-18.6	36.4	-20.5	37.4		
(5)			-13.9	21.9	2.6	1.2	-15.8	22.8	-17.3	23.5	-18.8	24.1	-20.6	25.0	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	9.9	-0.6	1.5	6.1	10.1	14.6	17.9	19.3	18.9	14.7	10.7	4.7	0.3	(6)
(7)		DBStd	7.95	3.76	4.11	3.84	3.90	3.65	3.79	3.18	3.18	3.26	3.57	4.05	3.67	(7)
(8)		HDD10.0	1252	329	238	128	46	6	1	0	0	3	36	164	302	(8)
(9)		HDD18.3	3243	587	471	380	246	126	53	27	32	114	238	409	561	(9)
(10)		CDD10.0	1213	0	0	7	49	147	239	290	276	144	56	5	0	(10)
(11)		CDD18.3	164	0	0	0	1	8	41	58	50	6	0	0	0	(11)
(12)		CDH23.3	1591	0	0	0	14	132	417	518	442	65	2	0	0	(12)
(13)		CDH26.7	468	0	0	0	1	28	131	166	137	6	0	0	0	(13)
(14)	Wind	WSAvg	2.0	1.8	2.0	2.3	2.5	2.4	2.1	2.0	1.9	1.8	1.9	1.9	1.7	(14)
(15)	Precipitation	PrecAvg	914	46	43	53	60	91	110	139	119	80	56	61	58	(15)
(16)		PrecMax	1343	122	151	124	112	195	199	287	291	164	181	159	169	(16)
(17)		PrecMin	728	3	3	4	18	11	50	61	40	20	1	18	9	(17)
(18)		PrecStd	147	31	33	28	26	41	37	46	50	32	39	33	35	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.5	15.1	20.1	25.1	29.6	32.8	33.0	32.4	27.2	23.1	18.1	12.9	(19)
(20)			MCWB	6.1	7.5	10.7	14.3	17.7	19.5	20.3	20.2	17.9	14.2	10.7	7.6	(20)
(21)		2%	DB	8.9	12.1	17.9	22.4	26.9	30.1	30.5	30.1	25.2	21.0	16.1	8.8	(21)
(22)			MCWB	4.9	6.1	9.7	12.7	16.2	18.8	19.6	19.7	16.9	13.5	9.9	5.5	(22)
(23)		5%	DB	5.9	10.1	15.8	20.2	24.2	28.0	28.6	28.0	23.2	19.1	13.8	6.3	(23)
(24)			MCWB	3.4	4.9	8.8	11.8	14.8	17.8	19.0	18.8	16.0	12.7	8.9	4.4	(24)
(25)		10%	DB	4.0	7.8	13.5	18.1	22.1	25.8	26.2	25.8	21.2	17.0	10.7	4.8	(25)
(26)			MCWB	2.3	4.1	7.6	10.6	13.9	17.2	18.1	18.1	15.0	11.8	7.7	3.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.2	8.3	11.5	14.9	18.5	21.2	21.7	21.6	19.0	15.7	11.6	8.0	(27)
(28)			MCDWB	10.9	13.7	18.6	23.8	27.9	29.6	30.2	29.9	25.3	20.8	16.3	11.6	(28)
(29)		2%	WB	5.1	6.7	10.1	13.5	17.0	20.0	20.5	20.4	17.7	14.5	10.3	6.2	(29)
(30)			MCDWB	7.9	10.8	16.4	21.6	24.6	27.5	28.3	28.1	23.4	18.9	14.8	8.1	(30)
(31)		5%	WB	3.7	5.4	9.1	12.2	15.8	18.9	19.6	19.4	16.7	13.6	9.3	4.7	(31)
(32)			MCDWB	5.5	9.1	14.8	19.1	22.5	26.0	26.6	26.3	21.7	17.7	12.8	5.9	(32)
(33)		10%	WB	2.5	4.1	8.1	11.2	14.7	17.8	18.7	18.6	15.7	12.6	8.0	3.5	(33)
(34)			MCDWB	3.6	7.1	12.6	17.2	20.6	23.9	24.7	24.5	19.9	16.1	10.6	4.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.8	9.3	11.0	11.5	11.6	11.4	11.0	10.4	10.4	8.2	7.1	(35)	
(36)			MCDBR	10.1	13.3	15.8	16.3	16.0	16.0	15.4	15.2	13.9	13.5	11.9	9.4	(36)
(37)			MCWBR	6.4	7.7	8.3	7.8	6.6	6.0	5.9	5.9	6.5	6.9	6.6	6.4	(37)
(38)		5% WB	MCDWB	8.6	12.1	14.4	14.8	14.5	14.2	13.9	13.9	12.6	11.8	10.5	8.0	(38)
(39)			MCWBR	5.7	7.3	7.8	7.4	6.4	5.9	5.9	5.9	6.2	6.3	6.1	5.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.271	0.297	0.339	0.384	0.400	0.408	0.407	0.400	0.364	0.334	0.302	0.271	(40)	
(41)		taud	2.391	2.319	2.283	2.267	2.289	2.315	2.317	2.357	2.433	2.489	2.498	2.445	(41)	
(42)		Ebn at Noon	825	869	878	868	865	858	853	844	845	820	783	785	(42)	
(43)		Edh at Noon	68	91	111	125	127	125	123	113	96	78	63	58	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.40	2.33	3.43	4.32	4.81	5.42	5.40	4.77	3.58	2.46	1.44	1.15	(44)	
(45)		RadStd	0.16	0.28	0.39	0.57	0.55	0.52	0.49	0.50	0.42	0.29	0.22	0.16	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) +77	(m) +41	(46)
(47)	Regional (89 neighbors)	+0.37	N/A	N/A	+0.63	+0.43	+0.42	N/A	N/A	+60	+12	(47)

Nomenclature: See separate page