

PATSCHERKOFEL, Austria

WMO: 111260

Lat: 47.2089N

Lon: 11.4622E

Elev: 2252

StdP: 77.04

Time Zone: 1.00 (EUC)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-18.2	-16.0	-24.9	0.5	-11.8	-21.7	0.7	-9.6	31.0	-3.9	28.3	-4.9	3.9	320	0.929

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.3	17.6	11.5	16.2	11.0	15.0	10.4	12.7	15.8	11.8	14.9	11.0	14.0	4.6	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.5	11.1	14.0	10.5	10.4	13.1	9.7	9.8	12.4	43.1	15.8	40.6	15.0	38.3	14.2	20.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 26.0	22.0	18.5	DB	-20.9	20.1	4.6	2.5	-24.2	21.8	-26.9	23.3	-29.4	24.7	-32.8	26.5	(4)
(5)			WB	-20.5	14.4	3.0	2.0	-22.7	15.8	-24.5	16.9	-26.2	18.0	-28.4	19.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	1.0	-6.8	-7.2	-4.5	-0.7	3.0	7.5	9.1	9.4	5.7	2.6	-1.8	-4.9	(6)	
	DBStd	7.36	4.51	5.13	4.72	4.33	4.34	4.42	4.05	3.76	4.01	4.59	5.06	4.80	(7)	
	HDD10.0	3392	519	481	449	321	219	98	63	57	136	231	356	462	(8)	
	HDD18.3	6327	778	714	707	571	475	326	287	277	379	488	606	720	(9)	
	CDD10.0	107	0	0	0	0	3	23	35	39	6	1	0	0	(10)	
	CDD18.3	1	0	0	0	0	0	0	1	0	0	0	0	0	(11)	
	CDH23.3	2	0	0	0	0	0	0	2	0	0	0	0	0	(12)	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14) Wind	WSAvg	6.5	7.3	7.2	6.4	7.4	5.9	5.0	4.8	5.0	5.2	7.6	8.5	7.6	(14)	
(15) Precipitation	PrecAvg	989	42	40	53	64	93	130	138	136	89	81	74	48	(15)	
	PrecMax	1297	94	135	146	122	167	203	225	226	147	163	193	133	(16)	
	PrecMin	787	5	11	14	9	14	69	68	45	34	2	3	1	(17)	
	PrecStd	127	24	28	27	27	39	33	38	41	30	40	44	27	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	4.5	5.6	6.7	10.2	15.0	19.3	20.2	19.2	15.6	13.2	8.9	5.9	(19)	
		MCWB	0.2	-1.0	0.4	4.6	8.3	11.0	14.9	11.4	10.0	6.2	3.3	-0.7	(20)	
	2%	DB	2.7	3.2	4.8	8.2	12.9	16.8	17.5	17.5	13.8	11.3	7.5	4.2	(21)	
		MCWB	-1.0	-2.0	0.1	3.9	8.0	10.9	12.1	11.3	8.9	5.3	2.2	-1.5	(22)	
	5%	DB	1.1	1.5	3.2	6.5	10.9	15.2	15.9	16.1	12.3	9.8	6.0	2.9	(23)	
		MCWB	-2.1	-2.6	-0.8	3.2	7.0	10.5	11.3	10.8	8.4	5.1	1.3	-2.3	(24)	
	10%	DB	-0.7	-0.7	1.7	5.0	9.0	13.6	14.5	14.7	11.0	8.3	4.4	1.3	(25)	
		MCWB	-3.0	-3.2	-1.3	2.4	6.0	9.8	10.7	10.4	7.7	4.6	0.6	-2.5	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	1.5	0.2	2.6	5.6	9.8	13.1	15.2	13.4	11.4	8.5	5.3	1.0	(27)	
		MCDB	2.9	2.9	4.7	8.4	12.3	16.2	18.9	16.8	13.3	10.2	7.8	2.8	(28)	
	2%	WB	-0.2	-0.9	1.0	4.6	8.4	12.0	13.0	12.2	10.1	7.1	3.5	0.0	(29)	
		MCDB	1.7	1.3	3.3	7.2	11.6	15.2	16.0	15.5	12.5	9.3	5.9	1.6	(30)	
	5%	WB	-1.4	-1.9	-0.1	3.7	7.3	11.1	12.0	11.5	9.0	6.1	2.3	-0.8	(31)	
		MCDB	0.4	0.8	2.2	6.0	10.3	14.1	15.1	14.8	11.4	8.3	4.2	1.0	(32)	
	10%	WB	-2.6	-3.1	-0.9	2.6	6.3	10.2	11.1	10.7	8.2	5.2	1.4	-1.7	(33)	
		MCDB	-0.9	-0.9	1.1	4.8	8.8	13.1	13.9	14.0	10.5	7.6	3.2	0.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	4.2	4.2	4.4	4.5	4.9	5.5	5.8	5.3	4.6	4.4	4.0	4.2	(35)	
		MCDBR	5.9	5.2	5.5	5.6	6.7	7.3	7.1	6.4	5.9	5.5	4.6	5.2	(36)	
	5% WB	MCWBR	3.9	3.0	3.4	3.1	3.6	3.8	3.7	3.3	3.5	3.4	2.9	3.1	(37)	
		MCWBR	5.4	5.1	4.9	5.1	6.2	6.8	6.7	6.1	5.2	4.8	4.1	4.6	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.216	0.234	0.264	0.296	0.308	0.315	0.314	0.309	0.285	0.266	0.241	0.216	(40)	
		taud	2.457	2.414	2.418	2.452	2.474	2.484	2.478	2.510	2.570	2.605	2.588	2.507	(41)	
	Ebn at Noon		920	962	972	963	956	947	943	937	938	915	882	883	(42)	
		Edh at Noon	62	81	96	103	105	105	104	97	83	68	55	53	(43)	
(44) All-Sky Solar Radiation	RadAvg		1.41	2.35	3.46	4.34	4.82	5.43	5.42	4.79	3.60	2.46	1.45	1.17	(44)	
	RadStd		0.16	0.28	0.40	0.58	0.55	0.52	0.49	0.50	0.42	0.29	0.22	0.16	(45)	

Historical Trends

		DBAvg	Heating		Cooling		Degree-Days					
			99% DB	99% DP	1% DB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47) Regional (89 neighbors)		+0.37	N/A	N/A	+0.63	+0.43	+0.42	N/A	N/A	+60	+12	(47)

Nomenclature: See separate page