

OBERGURGL, Austria

WMO: 111270

Lat: 46.8668N

Lon: 11.0246E

Elev: 6363

StdP: 11.62

Time Zone: 1.00 (EUC)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.4	5.3	-8.3	4.5	5.1	-5.2	5.3	9.0	25.1	17.3	21.9	17.8	3.0	210	0.672

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.7	71.2	55.3	68.4	54.1	65.7	52.7	56.6	67.9	55.1	65.8	53.6	63.6	4.7	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
52.3	73.9	59.1	50.6	69.3	58.0	49.2	65.8	56.9	27.0	68.1	25.9	66.1	24.9	63.7	64.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.0	14.2	11.7	DB	-2.4	75.9	5.2	2.6	-6.1	77.7	-9.1	79.2	-12.0	80.7	-15.8	82.5	(4)
(5)			WB	-3.5	59.3	4.8	2.3	-7.0	61.0	-9.8	62.4	-12.5	63.7	-16.1	65.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	37.9	21.7	23.4	28.9	35.7	42.8	50.8	53.4	53.1	46.1	40.5	31.6	25.7	(6)	
	DBStd	13.40	7.94	8.79	8.15	6.83	6.99	7.14	6.27	6.20	6.46	7.79	8.68	8.16	(7)	
	HDD50	4860	877	744	655	429	240	77	42	42	148	300	553	753	(8)	
	HDD65	9896	1342	1164	1120	878	688	426	360	370	568	759	1003	1218	(9)	
	CDD50	439	0	0	0	0	17	101	147	138	30	6	0	0	(10)	
	CDD65	1	0	0	0	0	0	0	1	0	0	0	0	0	(11)	
	CDH74	21	0	0	0	0	0	10	6	5	0	0	0	0	(12)	
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14) Wind	WSAvg	3.9	4.3	4.1	3.9	3.9	4.2	4.1	4.1	3.7	3.5	3.5	3.6	3.8	(14)	
(15) Precipitation	PrecAvg	36.9	1.8	1.9	2.1	2.3	3.1	4.6	4.7	4.6	3.2	3.3	3.3	2.1	(15)	
	PrecMax	48.5	3.7	5.0	5.3	4.1	5.8	7.2	6.9	9.0	5.3	7.6	10.9	4.3	(16)	
	PrecMin	30.3	0.5	0.5	0.3	0.3	0.7	2.3	3.1	1.8	1.2	0.2	0.3	0.2	(17)	
	PrecStd	4.9	0.9	1.1	1.1	0.9	1.5	1.1	1.0	1.5	1.1	1.8	2.2	1.0	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.3	44.9	49.7	56.8	66.4	75.1	74.7	74.7	66.4	61.5	51.8	42.9	(19)	
		MCWB	34.1	33.8	36.9	43.8	50.6	54.1	56.7	56.6	51.5	47.0	41.1	34.2	(20)	
	2%	DB	37.9	40.5	45.8	52.4	61.9	69.6	71.1	70.8	62.9	56.9	46.9	39.6	(21)	
		MCWB	31.4	32.3	35.5	40.9	48.4	53.9	55.9	55.5	50.3	45.0	38.2	32.6	(22)	
	5%	DB	35.1	36.9	42.5	49.0	58.0	66.6	68.1	67.5	59.4	53.0	43.9	37.3	(23)	
		MCWB	29.5	30.4	33.7	39.3	46.2	52.8	54.4	54.1	48.9	43.1	36.8	31.6	(24)	
	10%	DB	32.8	34.2	39.3	45.8	54.6	63.2	65.1	64.2	56.0	49.8	41.3	34.9	(25)	
		MCWB	28.1	28.5	32.4	37.6	44.3	50.7	52.9	52.7	47.5	42.1	35.3	29.5	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	36.1	35.8	38.4	44.8	51.8	56.6	59.7	58.5	54.5	49.0	42.7	35.9	(27)	
		MCDB	41.2	42.2	47.1	55.3	64.1	68.7	69.4	70.0	62.3	57.2	49.9	39.9	(28)	
	2%	WB	32.4	33.1	36.4	42.1	49.3	54.9	57.1	56.4	51.8	46.3	39.6	34.4	(29)	
		MCDB	36.0	38.7	43.7	50.7	60.0	67.0	68.4	67.6	59.3	53.5	44.7	38.3	(30)	
	5%	WB	30.5	31.0	34.6	39.9	47.0	53.3	55.3	54.8	50.1	44.6	37.7	32.3	(31)	
		MCDB	34.4	36.3	40.9	47.6	56.2	65.1	65.9	65.1	57.3	50.7	42.3	36.1	(32)	
	10%	WB	28.4	28.9	33.0	38.0	45.1	51.6	53.6	53.3	48.3	43.0	36.1	30.3	(33)	
		MCDB	32.2	33.8	38.5	45.0	53.1	61.7	63.1	62.4	54.9	48.9	40.7	34.0	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	10.4	12.9	14.5	14.1	15.2	16.4	16.7	16.3	14.8	13.9	10.6	9.9	(35)	
		MCDBR	12.4	15.3	17.0	17.3	20.3	21.3	21.5	20.7	19.3	17.4	12.2	11.3	(36)	
	5% WB	MCWBR	9.4	10.6	11.1	10.2	10.7	9.8	9.7	9.9	10.2	10.0	7.9	7.9	(37)	
		MCWBR	11.4	14.1	15.3	16.1	19.2	19.8	19.8	19.4	17.0	15.8	10.8	10.9	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.224	0.246	0.284	0.324	0.339	0.346	0.343	0.337	0.309	0.288	0.255	0.225	(40)	
		taud	2.384	2.333	2.309	2.336	2.373	2.389	2.392	2.428	2.497	2.532	2.529	2.445	(41)	
	Ebn at Noon	Ebn at Noon	287	299	300	295	293	291	290	288	289	280	272	274	(42)	
		Edh at Noon	21	28	34	37	37	37	36	33	28	23	19	18	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	485	785	1158	1408	1544	1754	1762	1545	1182	801	481	400	(44)	
	RadStd	RadStd	54	91	136	192	170	148	143	149	126	99	76	51	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)	
(47)	Regional (95 neighbors)	+0.63	N/A	N/A	+1.15	+0.74	+0.67	N/A	N/A	+110	+27	(47)

Nomenclature: See separate page