

RUDOLFSHUETTE ALPINZENTRUM, Austria

WMO: 111380

Lat: 47.135N

Lon: 12.626E

Elev: 7611

StdP: 11.08

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-1.8	1.9	-13.2	3.6	15.0	-8.6	4.6	13.0	51.2	20.2	48.3	19.7	11.3	340	0.911

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.4	62.1	51.4	59.4	50.2	56.9	49.0	53.0	59.0	51.4	57.4	50.0	55.6	8.6	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
50.5	72.4	55.3	48.7	67.6	53.8	47.2	63.9	52.5	25.1	59.1	24.0	57.7	23.0	55.8	62.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 45.0	40.1	35.2	-5.7	66.4	5.0	2.8	-9.4	68.4	-12.3	70.0	-15.1	71.6	-18.8	73.6		
(5)			-6.1	56.7	5.0	2.8	-9.7	58.7	-12.7	60.3	-15.5	61.8	-19.2	63.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	32.5	19.1	18.7	23.1	28.9	36.5	43.0	46.8	47.2	40.2	35.9	27.2	22.0		
	DBStd	12.87	8.28	8.98	8.72	7.75	6.95	7.53	6.81	6.99	7.31	7.92	8.96	8.84		
	HDD50	6515	958	877	833	634	420	229	141	136	298	437	684	868		
	HDD65	11869	1423	1297	1298	1084	883	659	564	550	743	901	1134	1333		
	CDD50	119	0	0	0	0	1	20	42	50	5	1	0	0		
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	12.2	14.0	13.8	12.4	13.5	12.0	8.9	8.6	9.3	9.4	14.1	16.0	13.9		
	PrecAvg	44.7	2.1	2.1	2.6	2.9	4.2	5.6	6.1	5.7	3.9	3.7	3.1	2.5		
(15) Precipitation	PrecMax	55.9	4.7	5.2	7.7	5.4	6.1	8.2	9.0	8.9	6.5	7.3	6.4	7.6		
	PrecMin	36.1	0.4	0.4	0.6	0.4	1.3	3.2	2.1	3.5	1.9	0.4	0.0	0.3		
	PrecStd	3.9	1.1	1.3	1.5	1.3	1.5	1.3	1.7	1.4	1.1	1.7	1.5	1.5		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	40.1	40.5	43.3	48.0	55.5	62.4	65.5	65.8	58.6	54.4	47.2	40.7		
		MCWB	30.7	28.9	32.9	38.8	44.0	50.0	53.1	52.0	48.0	42.2	37.9	30.0		
	2%	DB	36.8	36.1	39.7	44.5	52.0	59.1	62.2	62.4	54.9	50.8	44.0	37.9		
		MCWB	28.5	27.6	31.5	36.4	43.4	48.7	51.9	51.5	46.0	40.8	34.7	28.4		
	5%	DB	33.2	33.4	36.8	41.6	49.1	55.9	59.1	59.5	52.1	48.1	40.9	35.3		
		MCWB	27.0	26.6	30.1	35.3	41.8	47.6	50.7	50.4	45.0	39.8	33.5	27.6		
	10%	DB	30.2	30.3	34.2	39.1	46.3	53.1	56.4	56.8	49.8	45.8	38.1	33.2		
		MCWB	25.6	25.9	28.8	33.7	40.5	46.4	49.3	49.4	44.0	38.9	32.6	27.6		
	0.4%	WB	32.8	31.3	35.4	39.7	46.6	53.1	55.9	54.9	50.2	45.2	40.2	33.2		
		MCDB	36.4	35.2	40.7	45.6	52.1	58.3	61.9	61.2	54.6	50.2	45.4	35.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	30.3	29.5	33.0	38.0	44.3	50.3	53.3	52.9	48.0	43.1	37.1	31.7		
		MCDB	34.9	33.6	37.2	43.1	49.8	56.3	59.4	59.0	52.8	47.4	40.4	34.4		
	5%	WB	28.3	27.8	31.3	36.0	42.7	48.5	51.6	51.4	46.4	41.6	35.1	29.9		
		MCDB	32.1	32.0	35.1	40.3	47.8	54.2	57.6	57.6	50.6	46.0	38.2	33.0		
	10%	WB	26.2	25.9	29.8	34.2	41.1	47.0	50.0	50.0	44.9	40.1	33.6	28.2		
		MCDB	29.5	29.9	33.4	38.1	45.8	52.3	55.3	56.0	48.9	44.5	37.0	32.1		
	5% DB	MDBR	8.2	8.8	9.1	8.8	8.9	9.2	9.8	9.4	8.3	8.2	7.4	8.4		
		MCDBR	10.5	10.2	11.6	10.7	11.3	12.1	13.0	12.1	10.4	9.7	8.9	9.7		
		MCWBR	7.3	7.2	7.8	6.7	6.8	7.4	7.8	7.4	7.5	6.3	5.4	6.4		
		MCWBR	9.7	10.3	10.4	9.8	10.8	11.2	12.1	11.3	9.6	9.0	7.7	9.0		
(35) Mean Daily Temperature Range	5% WB	MCWBR	8.0	8.3	7.5	6.5	7.0	7.5	8.0	7.5	7.1	6.3	5.9	7.7		
(40) Clear-Sky Solar Irradiance	taub		0.214	0.233	0.266	0.298	0.311	0.318	0.316	0.312	0.287	0.268	0.242	0.217		
	taud		2.436	2.387	2.395	2.431	2.456	2.462	2.459	2.490	2.551	2.586	2.577	2.502		
	Ebn at Noon		292	305	307	305	303	299	298	296	297	289	279	280		
	Edh at Noon		20	26	31	34	34	34	34	31	27	22	18	17		
(44) All-Sky Solar Radiation	RadAvg		431	719	1044	1315	1514	1684	1715	1518	1120	770	438	356		
	RadStd		51	92	125	169	184	162	153	170	142	85	76	53		

Historical Trends

		Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (86 neighbors)		+0.76	N/A	N/A	N/A	+0.72	+0.67	N/A	N/A	+131	+65

Nomenclature: See separate page