

RUDOLFSHUETTE ALPINZENTRUM, Austria

WMO: 111380

Lat: 47.135N

Lon: 12.626E

Elev: 2320

StdP: 76.39

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-18.8	-16.7	-25.1	0.5	-9.4	-22.5	0.7	-10.6	22.9	-6.5	21.6	-6.9	5.0	340	0.911

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.2	16.7	10.8	15.2	10.1	13.8	9.4	11.7	15.0	10.8	14.1	10.0	13.1	3.9	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.3	10.3	12.9	9.3	9.7	12.1	8.4	9.1	11.4	40.4	15.1	37.9	14.3	35.6	13.2	17.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.1	17.9	15.8	-21.0	19.1	2.8	1.5	-23.0	20.2	-24.6	21.1	-26.2	22.0	-28.2	23.1		
(5)			-21.2	13.7	2.8	1.5	-23.2	14.8	-24.8	15.7	-26.4	16.6	-28.4	17.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	0.3	-7.2	-7.4	-4.9	-1.7	2.5	6.1	8.2	8.5	4.6	2.2	-2.7	-5.6
	DBStd	7.15	4.60	4.99	4.84	4.30	3.86	4.18	3.78	3.88	4.06	4.40	4.98	4.91
	HDD10.0	3619	532	487	463	352	233	127	78	76	166	243	380	482
	HDD18.3	6594	791	721	721	602	491	366	313	306	413	501	630	741
	CDD10.0	66	0	0	0	0	1	11	23	28	3	1	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	5.4	6.2	6.2	5.6	6.1	5.4	4.0	3.9	4.1	4.2	6.3	7.2	6.2
Precipitation	PrecAvg	1135	53	54	67	74	107	142	156	145	100	95	79	64
	PrecMax	1421	119	133	195	136	156	208	229	226	165	186	162	193
	PrecMin	918	9	9	16	10	34	82	54	89	48	11	0	8
	PrecStd	99	28	32	39	34	37	32	43	36	29	43	39	37
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	4.5	4.7	6.3	8.9	13.0	16.9	18.6	18.8	14.8	12.4	8.5	4.9
		MCWB	-0.7	-1.7	0.5	3.8	6.7	10.0	11.7	11.1	8.9	5.7	3.3	-1.1
	2%	DB	2.7	2.3	4.3	6.9	11.1	15.1	16.8	16.9	12.7	10.5	6.6	3.3
		MCWB	-1.9	-2.4	-0.3	2.4	6.3	9.3	11.1	10.8	7.8	4.9	1.5	-2.0
	5%	DB	0.7	0.8	2.7	5.3	9.5	13.3	15.1	15.3	11.2	8.9	4.9	1.9
		MCWB	-2.8	-3.0	-1.0	1.8	5.5	8.7	10.4	10.2	7.2	4.3	0.8	-2.5
	10%	DB	-1.0	-0.9	1.2	3.9	7.9	11.7	13.6	13.8	9.9	7.6	3.4	0.7
		MCWB	-3.6	-3.4	-1.8	0.9	4.7	8.0	9.6	9.7	6.7	3.9	0.3	-2.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	0.4	-0.4	1.9	4.3	8.1	11.7	13.3	12.7	10.1	7.3	4.6	0.7
		MCDB	2.4	1.8	4.8	7.6	11.2	14.6	16.6	16.2	12.6	10.1	7.5	2.0
	2%	WB	-0.9	-1.4	0.6	3.3	6.8	10.2	11.8	11.6	8.9	6.2	2.8	-0.2
		MCDB	1.6	0.9	2.9	6.2	9.9	13.5	15.2	15.0	11.6	8.6	4.7	1.3
	5%	WB	-2.1	-2.3	-0.4	2.2	5.9	9.2	10.9	10.8	8.0	5.4	1.7	-1.2
		MCDB	0.1	0.0	1.7	4.6	8.8	12.3	14.2	14.2	10.3	7.8	3.5	0.6
	10%	WB	-3.2	-3.4	-1.2	1.2	5.0	8.3	10.0	10.0	7.2	4.5	0.9	-2.1
		MCDB	-1.4	-1.1	0.8	3.4	7.7	11.3	12.9	13.3	9.4	6.9	2.8	0.0
Mean Daily Temperature Range	5% DB	MDBR	4.6	4.9	5.1	4.9	5.0	5.1	5.4	5.2	4.6	4.6	4.1	4.7
		MCDBR	5.8	5.7	6.4	5.9	6.3	6.7	7.2	6.7	5.8	5.4	4.9	5.4
		MCWBR	4.1	4.0	4.3	3.7	3.8	4.1	4.3	4.1	4.2	3.5	3.0	3.6
	5% WB	MCDBR	5.4	5.7	5.8	5.4	6.0	6.2	6.7	6.3	5.3	5.0	4.3	5.0
		MCWBR	4.4	4.6	4.2	3.6	3.9	4.2	4.4	4.2	3.9	3.5	3.3	4.3
Clear-Sky Solar Irradiance	taub	0.214	0.233	0.266	0.298	0.311	0.318	0.316	0.312	0.287	0.268	0.242	0.217	
	taud	2.436	2.387	2.395	2.431	2.456	2.462	2.459	2.490	2.551	2.586	2.577	2.502	
	Ebn at Noon	922	962	969	960	954	944	941	934	935	911	881	882	
	Edh at Noon	63	83	98	106	107	107	106	99	84	69	56	53	
All-Sky Solar Radiation	RadAvg	1.36	2.27	3.29	4.15	4.77	5.31	5.41	4.78	3.53	2.43	1.38	1.12	
	RadStd	0.16	0.29	0.40	0.53	0.58	0.51	0.48	0.54	0.45	0.27	0.24	0.17	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (86 neighbors)		+0.42	N/A	N/A	N/A	+0.40	+0.37	N/A	N/A	+73	+36

Nomenclature: See separate page