

RADSTADT, Austria

WMO: 111470

Lat: 47.385N

Lon: 13.456E

Elev: 2825

StdP: 13.26

Time Zone: 1.00 (EUC)

Period: 97-15

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	4.8	9.1	2.3	6.9	5.7	6.3	8.4	10.2	11.8	27.2	9.9	28.1	1.0	230	0.530

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.0	85.0	65.4	81.4	64.3	78.0	63.0	66.9	81.1	65.4	78.5	63.9	75.8	4.5	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
62.0	92.4	71.3	60.7	88.1	70.2	59.4	84.1	68.5	33.0	81.1	31.8	79.3	30.6	75.9	72.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.7	9.2	7.7	-0.6	91.0	6.5	2.3	-5.3	92.7	-9.1	94.0	-12.7	95.2	-17.4	96.9		
			-1.3	70.0	6.2	1.2	-5.8	70.9	-9.4	71.6	-12.8	72.2	-17.3	73.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	45.6	25.4	29.2	37.2	46.2	54.2	60.0	63.2	63.1	55.1	47.2	36.9	28.0	
	DBStd	15.04	7.26	7.69	7.30	6.84	6.62	7.44	6.50	5.96	6.44	6.92	7.54	7.42	
	HDD50	3181	763	583	398	150	37	11	1	1	26	132	396	683	
	HDD65	7237	1228	1003	862	565	338	182	113	106	298	551	843	1148	
	CDD50	1559	0	0	0	35	166	311	409	407	181	47	3	0	
	CDD65	139	0	0	0	0	3	31	56	47	2	0	0	0	
	CDH74	1692	0	0	0	5	95	389	624	526	53	0	0	0	
	CDH80	429	0	0	0	0	15	94	178	137	5	0	0	0	
Wind	WSAvg	2.6	2.2	2.7	2.8	3.1	3.0	2.7	2.8	2.6	2.4	2.6	2.3	2.2	
Precipitation	PrecAvg	51.9	2.7	2.5	3.5	3.2	4.8	6.6	7.6	6.7	4.9	3.5	3.1	2.8	
	PrecMax	59.2	6.1	7.1	7.4	4.9	6.9	9.1	11.7	9.7	8.0	5.6	5.9	9.1	
	PrecMin	43.5	0.3	0.7	1.3	1.1	1.4	4.8	3.6	4.1	2.6	0.9	0.5	0.9	
	PrecStd	3.8	1.4	1.5	1.7	1.1	1.6	1.3	2.3	1.4	1.3	1.3	1.2	1.5	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	45.6	52.5	63.0	73.2	82.5	87.5	89.7	88.8	79.8	71.4	62.0	47.4	
		MCWB	41.0	43.1	47.4	55.5	63.4	65.8	66.8	66.1	63.2	58.4	51.7	41.2	
	2%	DB	39.3	46.9	58.2	68.4	76.6	82.9	84.8	84.1	74.7	66.0	56.1	42.0	
		MCWB	36.4	39.5	46.1	53.1	59.8	64.5	66.0	65.3	60.9	55.5	48.0	38.9	
	5%	DB	36.5	42.6	53.8	64.6	72.5	78.9	81.0	80.0	71.1	62.1	51.5	39.0	
		MCWB	34.7	37.3	43.9	51.3	57.8	63.0	64.6	64.2	58.8	53.3	45.9	36.9	
	10%	DB	34.6	39.1	48.9	60.6	68.5	74.6	76.8	76.1	67.2	58.5	47.3	36.2	
		MCWB	33.3	35.5	41.6	49.1	55.7	61.1	63.1	62.9	57.5	51.6	44.0	34.5	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	41.4	43.9	48.9	56.6	64.1	68.2	69.1	68.2	64.4	59.0	52.3	41.9
			MCDB	44.7	51.3	59.3	71.4	79.1	83.6	83.7	83.3	75.8	69.0	60.2	45.2
2%		WB	36.7	40.2	46.6	54.0	60.8	65.6	67.0	66.5	62.1	56.4	48.7	39.5	
		MCDB	38.5	45.7	57.1	67.2	73.5	78.6	81.4	80.3	73.2	64.2	54.7	42.0	
5%		WB	35.0	37.7	44.5	52.0	58.4	64.0	65.4	64.9	60.0	54.4	46.5	36.9	
		MCDB	36.3	41.7	52.7	63.3	70.5	76.2	78.7	77.7	68.7	60.7	50.7	38.7	
10%		WB	33.5	35.7	42.0	49.7	56.5	62.0	63.9	63.3	58.1	52.4	44.0	34.7	
		MCDB	34.5	38.7	48.1	58.9	66.5	72.3	75.1	74.6	65.4	57.4	47.2	36.0	
Mean Daily Temperature Range	5% DB	MDBR	12.4	15.5	18.5	20.7	20.5	19.9	20.0	20.7	19.1	18.6	13.4	11.3	
		MCDBR	12.3	20.9	27.7	29.7	29.7	29.1	28.7	29.1	26.9	24.1	20.8	14.8	
		MCWBR	9.8	14.1	15.9	15.1	13.8	12.0	11.4	11.8	13.3	14.0	13.4	11.0	
	5% WB	MCDBR	10.9	18.7	25.8	27.9	27.6	26.3	26.0	26.9	24.5	21.9	18.7	13.6	
		MCWBR	8.9	12.7	15.3	14.3	13.2	11.2	10.8	11.6	12.4	13.1	12.3	10.2	
Clear-Sky Solar Irradiance	taub	0.277	0.308	0.354	0.397	0.410	0.416	0.417	0.408	0.373	0.342	0.310	0.279		
	taud	2.374	2.289	2.237	2.211	2.231	2.261	2.262	2.304	2.378	2.435	2.458	2.435		
	Ebn at Noon	258	270	272	271	271	269	267	265	264	256	243	244		
	Edh at Noon	22	30	37	42	43	42	41	38	32	26	21	19		
All-Sky Solar Radiation	RadAvg	414	710	1022	1302	1487	1646	1675	1490	1091	763	429	337		
	RadStd	50	89	121	164	179	171	161	177	145	81	71	53		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (95 neighbors)	+0.83	N/A	N/A	+1.31	+0.79	+0.63	N/A	N/A	+140	+74

Nomenclature: See separate page