

RADSTADT, Austria

WMO: 111470

Lat: 47.385N

Lon: 13.456E

Elev: 861

StdP: 91.40

Time Zone: 1.00 (EUC)

Period: 97-15

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-15.1	-12.7	-16.5	1.0	-14.6	-14.3	1.2	-12.1	5.3	-2.7	4.4	-2.2	0.5	230	0.530

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.1	29.4	18.6	27.4	18.0	25.6	17.2	19.4	27.3	18.5	25.8	17.7	24.3	2.0	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
16.7	13.2	21.8	16.0	12.6	21.2	15.2	12.0	20.3	58.9	27.3	56.0	26.3	53.4	24.4	22.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
Mean		Standard Deviation	n=5 years		n=10 years		n=20 years		n=50 years							
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max					
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
4.8	4.1	3.4	-18.1	32.8	3.6	1.3	-20.7	33.7	-22.8	34.4	-24.8	35.1	-27.4	36.0		
			-18.5	21.1	3.4	0.7	-21.0	21.6	-23.0	22.0	-24.9	22.3	-27.4	22.8		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.5	-3.7	-1.6	2.9	7.9	12.3	15.5	17.3	17.3	12.9	8.5	2.7	-2.2
	DBStd	8.36	4.03	4.27	4.06	3.80	3.68	4.13	3.61	3.31	3.58	3.85	4.19	4.12
	HDD10.0	1767	424	324	221	83	21	6	1	1	14	73	220	379
	HDD18.3	4021	682	557	479	314	188	101	63	59	166	306	468	638
	CDD10.0	866	0	0	0	19	92	173	227	226	101	26	2	0
	CDD18.3	77	0	0	0	0	2	17	31	26	1	0	0	0
	CDH23.3	940	0	0	0	3	53	216	347	292	29	0	0	0
	CDH26.7	238	0	0	0	0	8	52	99	76	3	0	0	0
(14) Wind	WSAvg	1.2	1.0	1.2	1.3	1.4	1.3	1.2	1.3	1.2	1.1	1.2	1.1	1.0
(15) Precipitation	PrecAvg	1318	68	64	88	81	123	168	192	170	124	90	79	71
	PrecMax	1504	154	180	188	124	174	232	298	246	204	142	150	230
	PrecMin	1104	8	19	33	28	36	121	91	105	65	22	12	22
	PrecStd	97	36	38	43	27	40	32	58	36	34	32	31	38
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.5	11.4	17.2	22.9	28.0	30.8	32.1	31.6	26.6	21.9	16.7	8.5
		MCWB	5.0	6.2	8.6	13.1	17.5	18.8	19.3	19.0	17.3	14.6	10.9	5.1
	2%	DB	4.1	8.3	14.6	20.2	24.8	28.3	29.3	28.9	23.7	18.9	13.4	5.6
		MCWB	2.5	4.1	7.8	11.7	15.4	18.0	18.9	18.5	16.0	13.1	8.9	3.8
	5%	DB	2.5	5.9	12.1	18.1	22.5	26.0	27.2	26.7	21.7	16.7	10.8	3.9
		MCWB	1.5	2.9	6.6	10.7	14.3	17.2	18.1	17.9	14.9	11.9	7.7	2.7
	10%	DB	1.5	4.0	9.4	15.9	20.3	23.6	24.9	24.5	19.6	14.7	8.5	2.3
		MCWB	0.7	2.0	5.3	9.5	13.2	16.2	17.3	17.2	14.1	10.9	6.6	1.4
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.2	6.6	9.4	13.7	17.8	20.1	20.6	20.1	18.0	15.0	11.3	5.5
		MCDB	7.1	10.7	15.2	21.9	26.2	28.7	28.7	28.5	24.4	20.5	15.7	7.4
	2%	WB	2.6	4.5	8.1	12.2	16.0	18.7	19.4	19.1	16.7	13.6	9.3	4.2
		MCDB	3.6	7.6	14.0	19.6	23.1	25.9	27.4	26.8	22.9	17.9	12.6	5.5
	5%	WB	1.6	3.2	6.9	11.1	14.7	17.8	18.6	18.3	15.5	12.5	8.0	2.7
		MCDB	2.4	5.4	11.5	17.4	21.4	24.5	25.9	25.4	20.4	15.9	10.4	3.7
	10%	WB	0.8	2.1	5.5	9.8	13.6	16.7	17.7	17.4	14.5	11.4	6.7	1.5
		MCDB	1.4	3.7	9.0	14.9	19.2	22.4	23.9	23.7	18.6	14.1	8.5	2.2
(35) Mean Daily Temperature Range	5% DB	MDBR	6.9	8.6	10.3	11.5	11.4	11.1	11.1	11.5	10.6	10.3	7.4	6.3
		MCDBR	6.8	11.6	15.4	16.5	16.5	16.2	15.9	16.2	14.9	13.4	11.5	8.2
	5% WB	MCWBR	5.4	7.8	8.8	8.4	7.7	6.7	6.3	6.6	7.4	7.8	7.5	6.1
		MCWBR	6.1	10.4	14.3	15.5	15.3	14.6	14.4	14.9	13.6	12.2	10.4	7.5
(40) Clear-Sky Solar Irradiance	taub	taub	0.277	0.308	0.354	0.397	0.410	0.416	0.417	0.408	0.373	0.342	0.310	0.279
		taud	2.374	2.289	2.237	2.211	2.231	2.261	2.262	2.304	2.378	2.435	2.458	2.435
	Edn at Noon	Edn at Noon	813	851	859	854	855	849	843	834	833	806	767	770
		Edh at Noon	69	94	117	132	135	132	130	119	101	82	65	59
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.31	2.24	3.22	4.10	4.69	5.19	5.28	4.70	3.44	2.40	1.35	1.06
	RadStd	RadStd	0.16	0.28	0.38	0.52	0.56	0.54	0.51	0.56	0.46	0.26	0.23	0.17

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (95 neighbors)	+0.46	N/A	N/A	N/A	+0.73	+0.44	+0.35	N/A	N/A	+78	+41

Nomenclature: See separate page