

OBERTAUERN, Austria

WMO: 111490

Lat: 47.249N

Lon: 13.560E

Elev: 5725

StdP: 11.90

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	3.7	7.3	-6.1	4.9	11.9	-1.6	6.2	14.3	25.0	18.1	23.1	19.1	10.9	310	0.718

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.9	71.3	56.5	68.1	55.3	65.2	54.1	58.2	67.7	56.6	65.4	55.2	63.1	6.2	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
54.7	78.9	61.0	53.1	74.2	59.5	51.8	70.7	58.3	27.9	67.3	26.7	65.8	25.7	63.2	71.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
21.4	19.1	17.2	2.1	76.4	5.1	2.8	-1.6	78.4	-4.6	80.0	-7.5	81.6	-11.2	83.6		
			0.7	61.2	5.2	1.6	-3.0	62.3	-6.0	63.3	-8.9	64.2	-12.7	65.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	37.7	22.6	23.5	28.5	35.3	43.2	49.9	53.3	53.3	45.4	40.5	31.0	25.4
	DBStd	13.54	7.98	8.84	8.51	7.92	7.54	7.98	6.96	6.83	7.34	8.04	8.49	8.31
	HDD50	4940	851	742	666	443	235	100	49	46	171	303	572	762
	HDD65	9956	1316	1162	1131	892	677	454	366	365	587	758	1021	1227
	CDD50	462	0	0	0	1	23	97	150	147	34	10	0	0
	CDD65	5	0	0	0	0	0	1	2	2	0	0	0	0
	CDH74	24	0	0	0	0	0	5	10	9	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	8.3	9.8	10.1	9.4	8.6	7.3	6.8	6.9	6.7	7.3	8.3	8.8	9.4
Precipitation	PrecAvg	39.6	1.5	1.4	2.0	2.2	3.6	5.2	5.9	5.6	3.9	3.5	3.0	1.8
	PrecMax	46.9	3.0	4.7	4.4	3.7	5.2	8.4	10.4	8.8	6.3	8.4	7.0	5.7
	PrecMin	32.6	0.3	0.2	0.4	0.8	1.8	2.8	1.0	3.3	2.2	0.6	0.0	0.3
	PrecStd	4.4	0.9	1.1	1.0	0.7	0.9	1.4	2.2	1.3	1.1	1.7	1.7	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.4	45.5	49.4	57.5	67.8	74.3	75.3	75.1	67.1	62.2	52.1	44.7
		MCWB	34.4	33.3	38.8	44.5	52.3	57.0	58.9	57.5	53.9	50.0	41.5	33.8
	2%	DB	39.7	41.3	45.8	53.3	62.5	69.7	71.2	70.5	62.6	57.8	48.2	41.3
		MCWB	32.2	32.3	36.6	42.8	49.9	55.6	57.0	56.4	51.9	48.0	40.2	32.5
	5%	DB	36.7	38.2	42.8	49.4	58.5	66.0	67.5	67.2	58.9	54.3	44.9	38.7
		MCWB	31.4	31.3	35.1	40.8	48.1	53.9	55.6	55.4	50.1	46.2	38.1	32.1
	10%	DB	33.7	34.7	39.9	46.2	54.7	62.2	64.2	63.9	55.6	50.9	42.0	36.0
		MCWB	29.1	29.6	33.7	39.1	46.2	52.5	54.4	54.1	48.7	44.3	37.4	30.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	36.9	35.9	40.3	46.0	53.8	59.4	60.8	60.0	55.4	54.7	44.4	37.2
		MCDB	40.7	40.7	47.2	55.1	63.7	69.4	71.4	69.7	63.2	57.5	49.1	40.3
	2%	WB	34.1	33.7	37.7	43.5	51.0	56.8	58.4	57.8	53.3	49.5	41.4	35.4
		MCDB	37.8	38.8	43.5	51.5	60.1	66.5	67.8	67.4	60.4	55.1	45.7	38.8
	5%	WB	32.0	32.0	36.0	41.6	48.9	54.9	56.7	56.3	51.3	47.1	39.6	33.3
		MCDB	35.7	36.9	41.1	48.3	56.8	63.4	65.1	65.0	56.9	52.1	43.4	36.5
	10%	WB	29.9	30.3	34.4	39.8	46.9	53.2	55.1	54.8	49.7	45.2	37.8	31.3
		MCDB	33.1	34.4	38.9	45.4	53.6	60.9	62.7	62.3	54.5	49.7	41.3	34.8
Mean Daily Temperature Range	5% DB	MDBR	8.4	9.1	10.2	11.1	12.7	12.8	12.9	12.9	11.3	11.2	8.4	8.2
		MCDBR	11.2	11.6	13.9	16.7	18.8	19.2	18.8	18.3	16.5	15.7	12.1	11.1
		MCWBR	7.7	7.4	8.1	8.6	8.6	8.2	8.1	7.6	8.1	8.6	7.2	7.5
	5% WB	MCDBR	10.3	10.7	12.9	15.3	17.9	17.5	17.3	17.0	15.1	13.9	10.5	10.2
		MCWBR	8.1	7.5	8.0	8.1	8.7	8.1	8.2	7.9	7.8	8.5	7.0	7.9
Clear-Sky Solar Irradiance	taub	0.242	0.268	0.307	0.344	0.355	0.361	0.361	0.354	0.325	0.301	0.273	0.244	
	taud	2.422	2.363	2.344	2.336	2.352	2.368	2.362	2.400	2.469	2.520	2.530	2.483	
	Ebn at Noon	277	289	291	288	288	286	284	282	282	274	262	264	
	Edh at Noon	21	28	33	37	38	37	37	34	29	23	19	17	
All-Sky Solar Radiation	RadAvg	421	711	1032	1309	1504	1669	1697	1505	1105	765	433	346	
	RadStd	50	90	123	165	181	164	156	173	143	82	73	53	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
Station Only		(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
Regional (93 neighbors)		+0.83	N/A	N/A	+1.33	+0.81	+0.61	N/A	N/A	+146	+85

Nomenclature: See separate page