

OBERTAUERN, Austria

WMO: 111490

Lat: 47.249N

Lon: 13.560E

Elev: 1745

StdP: 82.05

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-15.7	-13.7	-21.1	0.7	-11.1	-18.7	0.9	-9.8	11.2	-7.7	10.3	-7.1	4.9	310	0.718

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.2	21.8	13.6	20.1	12.9	18.4	12.3	14.6	19.8	13.7	18.6	12.9	17.3	2.8	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
12.6	11.3	16.1	11.7	10.6	15.3	11.0	10.1	14.6	47.0	19.6	44.3	18.8	41.9	17.4	21.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 9.6	8.5	7.7		-16.6	24.7	2.8	1.6	-18.7	25.8	-20.3	26.7	-21.9	27.6	-24.0	28.7	
(5)			DB	-17.4	16.2	2.9	0.9	-19.4	16.8	-21.1	17.4	-22.7	17.9	-24.8	18.5	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	3.2	-5.2	-4.7	-1.9	1.8	6.2	9.9	11.8	11.8	7.5	4.7	-0.6	-3.7
	DBStd	7.52	4.43	4.91	4.73	4.40	4.19	4.43	3.86	3.79	4.08	4.47	4.72	4.61
	HDD10.0	2744	473	412	370	246	131	56	27	26	95	168	318	423
	HDD18.3	5531	731	646	628	496	376	252	203	203	326	421	567	682
	CDD10.0	257	0	0	0	1	13	54	83	82	19	6	0	0
	CDD18.3	3	0	0	0	0	0	1	1	1	0	0	0	0
	CDH23.3	13	0	0	0	0	0	3	6	5	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
(14) Wind	WSAvg	3.7	4.4	4.5	4.2	3.8	3.3	3.0	3.1	3.0	3.3	3.7	3.9	4.2
(15) Precipitation	PrecAvg	1007	38	35	52	57	91	132	151	141	99	88	76	46
	PrecMax	1190	76	120	113	94	131	213	264	223	161	214	177	145
	PrecMin	828	7	5	11	21	46	72	26	85	56	16	0	7
	PrecStd	112	23	27	25	18	23	35	56	34	27	42	43	28
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.3	7.5	9.6	14.1	19.9	23.5	24.0	24.0	19.5	16.8	11.2	7.0
		MCWB	1.3	0.7	3.8	6.9	11.3	13.9	14.9	14.2	12.2	10.0	5.3	1.0
	2%	DB	4.3	5.1	7.7	11.8	16.9	20.9	21.8	21.4	17.0	14.4	9.0	5.2
		MCWB	0.1	0.2	2.5	6.0	9.9	13.1	13.9	13.6	11.0	8.9	4.6	0.3
	5%	DB	2.6	3.4	6.0	9.7	14.7	18.9	19.7	19.6	15.0	12.4	7.2	3.7
		MCWB	-0.3	-0.4	1.7	4.9	9.0	12.2	13.1	13.0	10.1	7.9	3.4	0.0
	10%	DB	1.0	1.5	4.4	7.9	12.6	16.8	17.9	17.7	13.1	10.5	5.5	2.2
		MCWB	-1.6	-1.3	0.9	4.0	7.9	11.4	12.5	12.3	9.3	6.8	3.0	-0.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.7	2.2	4.6	7.8	12.1	15.2	16.0	15.5	13.0	12.6	6.9	2.9
		MCDB	4.8	4.8	8.5	12.8	17.6	20.8	21.9	21.0	17.4	14.1	9.5	4.6
	2%	WB	1.2	1.0	3.2	6.4	10.5	13.8	14.7	14.3	11.8	9.7	5.2	1.9
		MCDB	3.2	3.8	6.4	10.8	15.6	19.1	19.9	19.7	15.8	12.8	7.6	3.8
	5%	WB	0.0	0.0	2.2	5.3	9.4	12.7	13.7	13.5	10.7	8.4	4.2	0.7
		MCDB	2.1	2.7	5.1	9.1	13.8	17.4	18.4	18.3	13.9	11.2	6.4	2.5
	10%	WB	-1.2	-0.9	1.3	4.3	8.3	11.8	12.9	12.7	9.9	7.3	3.2	-0.4
		MCDB	0.6	1.3	3.9	7.4	12.0	16.1	17.1	16.8	12.5	9.8	5.2	1.6
(35) Mean Daily Temperature Range	MDBR		4.6	5.0	5.7	6.2	7.0	7.1	7.2	7.1	6.3	6.2	4.7	4.6
	5% DB	MCDBR	6.2	6.5	7.7	9.3	10.5	10.7	10.4	10.1	9.1	8.7	6.7	6.2
		MCWBR	4.3	4.1	4.5	4.8	4.8	4.6	4.5	4.2	4.5	4.8	4.0	4.2
	5% WB	MCDBR	5.7	6.0	7.2	8.5	9.9	9.7	9.6	9.5	8.4	7.7	5.8	5.7
		MCWBR	4.5	4.2	4.4	4.5	4.8	4.5	4.5	4.4	4.3	4.7	3.9	4.4
(40) Clear-Sky Solar Irradiance	taub		0.242	0.268	0.307	0.344	0.355	0.361	0.361	0.354	0.325	0.301	0.273	0.244
	taud		2.422	2.363	2.344	2.336	2.352	2.368	2.362	2.400	2.469	2.520	2.530	2.483
	Ebn at Noon		872	910	917	909	908	901	896	889	889	864	827	832
	Edh at Noon		65	87	104	116	119	118	117	108	92	74	60	55
(44) All-Sky Solar Radiation	RadAvg		1.33	2.24	3.25	4.13	4.74	5.26	5.35	4.75	3.48	2.41	1.36	1.09
	RadStd		0.16	0.28	0.39	0.52	0.57	0.52	0.49	0.55	0.45	0.26	0.23	0.17

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (93 neighbors)	+0.46	N/A	N/A	+0.74	+0.45	+0.34	N/A	N/A	+81	+47

Nomenclature: See separate page