

MATTSEE, Austria

WMO: 111520

Lat: 47.977N

Lon: 13.106E

Elev: 1654

StdP: 13.84

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.2	16.1	7.8	8.7	11.9	12.8	11.2	17.6	26.1	42.9	21.5	39.2	4.2	70	0.492

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.5	84.6	70.1	81.4	68.7	78.4	67.1	71.5	82.0	69.7	79.6	67.9	76.9	4.5	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
68.0	109.2	78.0	66.1	102.1	75.6	64.5	96.5	73.5	36.3	82.1	34.7	79.5	33.2	77.1	78.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
19.8	16.9	14.6	DB	7.9	90.2	8.1	3.1	2.1	92.5	-2.6	94.3	-7.1	96.0	-13.0	98.3
			WB	7.4	74.9	7.6	2.4	1.9	76.6	-2.5	77.9	-6.8	79.3	-12.4	81.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	49.2	30.9	33.4	40.0	49.0	57.1	63.7	66.6	66.0	57.8	50.0	40.7	34.4	(6)
	DBStd	14.35	7.91	8.36	7.70	7.38	6.64	6.96	5.95	6.00	5.84	6.52	6.69	7.18	(7)
	HDD50	2356	593	465	317	105	14	1	0	0	7	83	287	484	(8)
	HDD65	6046	1058	884	775	480	257	107	54	61	226	466	729	949	(9)
	CDD50	2067	0	0	7	76	234	412	514	495	240	82	7	0	(10)
	CDD65	284	0	0	0	0	12	68	103	91	10	0	0	0	(11)
	CDH74	1827	0	0	0	10	94	473	645	569	36	0	0	0	(12)
	CDH80	410	0	0	0	1	10	105	152	139	3	0	0	0	(13)
(14) Wind	WSAvg	5.5	6.6	6.4	6.9	5.9	5.5	4.6	4.6	4.2	4.6	5.1	5.5	6.0	(14)
(15) Precipitation	PrecAvg	53.3	2.9	2.7	4.2	3.2	5.4	6.5	6.5	6.3	5.4	3.6	3.4	3.2	(15)
	PrecMax	63.7	7.0	7.8	7.6	8.4	9.4	12.2	13.7	14.0	10.6	6.6	8.3	6.8	(16)
	PrecMin	38.9	0.1	0.6	1.8	0.2	0.9	2.6	1.9	2.8	2.2	0.9	0.1	0.5	(17)
	PrecStd	5.8	1.8	1.7	1.9	1.8	2.2	2.3	2.6	2.4	2.0	1.5	1.7	1.6	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.1	56.4	64.1	74.5	81.3	87.7	89.0	88.5	77.6	70.4	63.3	54.7	(19)
		MCWB	45.8	45.8	50.5	58.6	65.5	71.5	72.1	71.1	66.8	60.2	52.6	46.4	(20)
	2%	DB	48.8	51.3	58.7	69.4	76.7	82.9	84.1	84.1	74.0	65.7	57.2	50.0	(21)
		MCWB	43.2	44.1	48.4	56.1	63.6	69.3	70.4	70.1	65.1	58.4	50.5	44.4	(22)
	5%	DB	45.1	47.8	54.6	65.5	72.7	79.5	80.7	80.3	70.4	62.3	53.2	47.0	(23)
		MCWB	41.1	42.2	46.8	54.1	61.3	67.4	68.6	68.8	63.0	56.3	49.0	43.0	(24)
	10%	DB	41.9	44.5	50.8	61.7	69.0	76.1	77.4	76.7	67.1	59.3	50.0	44.1	(25)
		MCWB	39.1	40.0	44.9	52.1	59.3	65.5	67.0	66.9	61.1	54.8	47.1	41.0	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.3	47.3	52.0	60.5	67.5	74.0	74.4	73.7	68.3	61.8	53.3	47.5	(27)
		MCDB	51.4	53.5	60.5	71.1	79.2	83.9	85.5	84.4	76.3	68.1	59.6	52.6	(28)
	2%	WB	43.9	44.7	49.5	57.3	64.5	70.6	71.5	70.9	65.7	59.2	51.2	45.5	(29)
		MCDB	48.0	50.1	57.0	67.5	74.6	81.1	81.5	81.6	72.8	64.4	56.2	49.6	(30)
	5%	WB	41.4	42.7	47.4	54.8	62.2	68.4	69.5	69.2	63.7	57.1	49.2	43.3	(31)
		MCDB	44.8	47.7	53.4	63.9	71.3	77.9	79.0	78.9	69.4	61.3	52.9	46.5	(32)
	10%	WB	39.2	40.4	45.5	52.7	60.1	66.2	67.6	67.4	61.8	55.2	47.2	41.1	(33)
		MCDB	41.7	44.1	50.4	60.5	67.7	74.4	76.0	75.7	66.3	58.9	50.1	43.9	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	8.6	11.4	13.4	15.7	15.6	15.6	15.5	15.2	12.8	11.9	9.0	8.4	(35)
		MCDBR	12.4	17.3	21.0	23.5	22.5	22.5	21.9	21.3	17.9	16.8	15.2	13.6	(36)
		MCWBR	8.6	10.9	11.8	11.5	11.3	11.1	10.6	10.2	10.3	10.4	9.8	9.2	(37)
	5% WB	MCDBR	11.6	15.6	19.5	21.9	20.9	21.0	20.7	20.2	16.4	15.7	13.7	12.6	(38)
		MCWBR	8.3	10.0	11.5	11.3	10.9	11.2	10.6	10.3	9.9	10.0	9.2	8.9	(39)
(40) Clear-Sky Solar Irradiance	taub		0.295	0.321	0.360	0.392	0.403	0.407	0.412	0.405	0.378	0.347	0.320	0.293	(40)
	taud		2.422	2.352	2.310	2.263	2.275	2.299	2.285	2.320	2.369	2.440	2.469	2.451	(41)
	Ebn at Noon		249	265	270	272	273	272	268	265	262	252	237	235	(42)
	Edh at Noon		21	28	34	40	41	40	40	37	32	26	20	18	(43)
(44) All-Sky Solar Radiation	RadAvg		365	662	984	1333	1534	1693	1678	1484	1071	715	384	287	(44)
	RadStd		52	86	118	168	184	165	162	167	143	76	55	41	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (89 neighbors)	+0.81	N/A	N/A	N/A	+0.63	+0.67	N/A	N/A	+115	+47

Nomenclature: See separate page