

MATTSEE, Austria

WMO: 111520

Lat: 47.977N

Lon: 13.106E

Elev: 504

StdP: 95.42

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.5	-8.8	-13.4	1.2	-11.2	-10.7	1.6	-8.0	11.7	6.1	9.6	4.0	1.9	70	0.492

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.6	29.2	21.2	27.4	20.4	25.8	19.5	22.0	27.8	20.9	26.5	20.0	25.0	2.0	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.0	15.6	25.5	18.9	14.6	24.2	18.0	13.8	23.0	66.6	27.8	62.8	26.4	59.4	25.1	25.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.8	7.6	6.5	-13.4	32.3	4.5	1.7	-16.6	33.6	-19.2	34.6	-21.7	35.6	-25.0	36.8		
(5)			-13.7	23.8	4.2	1.3	-16.7	24.8	-19.2	25.5	-21.6	26.3	-24.6	27.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.6	-0.6	0.8	4.4	9.5	13.9	17.6	19.2	18.9	14.3	10.0	4.8	1.3		
	DBStd	7.97	4.39	4.64	4.28	4.10	3.69	3.87	3.30	3.33	3.25	3.62	3.72	3.99		
	HDD10.0	1309	329	258	176	58	8	1	0	0	4	46	159	269		
	HDD18.3	3359	588	491	431	267	143	59	30	34	126	259	405	527		
	CDD10.0	1148	0	0	4	42	130	229	286	275	133	46	4	0		
	CDD18.3	158	0	0	0	0	7	38	57	51	6	0	0	0		
	CDH23.3	1015	0	0	0	6	52	263	358	316	20	0	0	0		
	CDH26.7	228	0	0	0	1	6	58	84	77	2	0	0	0		
(14) Wind	WSAvg	2.5	3.0	2.9	3.1	2.6	2.5	2.1	2.0	1.9	2.0	2.3	2.5	2.7		
(15) Precipitation	PrecAvg	1353	73	68	106	82	136	165	166	159	136	92	87	82		
	PrecMax	1619	178	198	193	214	240	309	349	356	270	168	212	172		
	PrecMin	989	2	16	45	6	22	67	48	70	56	22	3	12		
	PrecStd	147	46	43	47	45	56	59	66	62	51	39	44	41		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.7	13.5	17.8	23.6	27.4	30.9	31.7	31.4	25.3	21.3	17.4	12.6		
		MCWB	7.6	7.7	10.3	14.8	18.6	21.9	22.3	21.7	19.3	15.7	11.4	8.0		
	2%	DB	9.3	10.7	14.8	20.8	24.8	28.3	28.9	29.0	23.4	18.7	14.0	10.0		
		MCWB	6.2	6.7	9.1	13.4	17.6	20.7	21.3	21.2	18.4	14.7	10.3	6.9		
	5%	DB	7.3	8.8	12.6	18.6	22.6	26.4	27.1	26.8	21.4	16.9	11.8	8.3		
		MCWB	5.1	5.7	8.2	12.3	16.3	19.7	20.4	20.5	17.2	13.5	9.4	6.1		
	10%	DB	5.5	7.0	10.4	16.5	20.5	24.5	25.2	24.9	19.5	15.2	10.0	6.7		
		MCWB	4.0	4.4	7.2	11.2	15.2	18.6	19.4	19.4	16.2	12.7	8.4	5.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.5	8.5	11.1	15.8	19.7	23.3	23.5	23.2	20.2	16.6	11.8	8.6		
		MCDB	10.8	11.9	15.8	21.7	26.2	28.9	29.7	29.1	24.6	20.1	15.3	11.5		
	2%	WB	6.6	7.0	9.7	14.1	18.1	21.4	22.0	21.6	18.7	15.1	10.7	7.5		
		MCDB	8.9	10.0	13.9	19.7	23.6	27.3	27.5	27.6	22.7	18.0	13.4	9.8		
	5%	WB	5.2	5.9	8.6	12.7	16.8	20.2	20.8	20.6	17.6	13.9	9.6	6.3		
		MCDB	7.1	8.7	11.9	17.7	21.9	25.5	26.1	26.1	20.8	16.3	11.6	8.1		
	10%	WB	4.0	4.7	7.5	11.5	15.6	19.0	19.8	19.6	16.6	12.9	8.4	5.0		
		MCDB	5.4	6.7	10.2	15.8	19.8	23.5	24.5	24.3	19.1	14.9	10.0	6.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	4.8	6.3	7.5	8.7	8.7	8.7	8.6	8.5	7.1	6.6	5.0	4.7		
		MCDBR	6.9	9.6	11.7	13.0	12.5	12.5	12.2	11.8	9.9	9.3	8.5	7.5		
	5% WB	MCWBR	4.8	6.0	6.6	6.4	6.3	6.2	5.9	5.7	5.7	5.8	5.5	5.1		
		MCWBR	6.4	8.7	10.8	12.2	11.6	11.7	11.5	11.2	9.1	8.7	7.6	7.0		
(40) Clear-Sky Solar Irradiance	taub		0.295	0.321	0.360	0.392	0.403	0.407	0.412	0.405	0.378	0.347	0.320	0.293		
		taud	2.422	2.352	2.310	2.263	2.275	2.299	2.285	2.320	2.369	2.440	2.469	2.451		
	Ebn at Noon		784	834	852	857	860	857	846	836	825	795	747	742		
		Edh at Noon	66	88	108	125	128	126	126	117	101	81	64	58		
(44) All-Sky Solar Radiation	RadAvg		1.15	2.09	3.10	4.20	4.84	5.34	5.29	4.68	3.38	2.25	1.21	0.91		
	RadStd		0.16	0.27	0.37	0.53	0.58	0.52	0.51	0.53	0.45	0.24	0.17	0.13		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (89 neighbors)	+0.45	N/A	N/A	N/A	+0.35	+0.37	N/A	N/A	+64	+26

Nomenclature: See separate page