

FEUERKOGEL, Austria

WMO: 111550

Lat: 47.817N

Lon: 13.718E

Elev: 1620

StdP: 83.32

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-14.6	-12.8	-22.3	0.6	-6.4	-19.2	0.8	-5.0	21.8	-0.8	19.5	0.8	3.8	310	0.741

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.0	21.8	15.1	20.3	14.4	18.9	13.7	16.3	20.2	15.3	19.1	14.4	18.0	3.0	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
14.9	12.9	18.5	13.8	12.0	17.4	12.8	11.2	16.5	52.3	20.2	49.0	19.2	46.0	18.1	24.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.9	14.2	12.0	-16.6	24.7	2.9	1.7	-18.7	25.9	-20.5	26.9	-22.1	27.9	-24.2	29.2
			-16.9	18.5	3.0	1.8	-19.0	19.8	-20.8	20.8	-22.5	21.8	-24.7	23.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	4.3	-3.3	-3.6	-1.2	2.6	6.9	10.5	12.2	12.3	8.5	6.1	1.7	-1.7		
	DBStd	7.42	4.79	5.37	4.85	4.94	4.51	4.50	4.00	4.09	4.37	5.04	5.47	5.17		
	HDD10.0	2407	411	381	348	226	117	48	24	23	79	138	250	363		
	HDD18.3	5128	669	614	606	472	354	236	194	190	294	379	498	621		
	CDD10.0	330	0	0	0	3	21	64	92	95	34	18	2	0		
	CDD18.3	8	0	0	0	0	0	2	3	4	0	0	0	0		
	CDH23.3	9	0	0	0	0	0	2	4	3	0	0	0	0		
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0		
(14) Wind	WSAvg	4.8	5.9	5.7	5.4	4.4	4.3	4.1	4.3	3.9	4.1	4.9	5.4	5.7		
(15) Precipitation	PrecAvg	1416	91	81	109	85	138	164	174	161	131	94	92	95		
	PrecMax	1700	218	188	205	170	267	338	361	343	269	167	246	198		
	PrecMin	1075	10	25	41	15	33	65	58	65	44	22	1	26		
	PrecStd	143	52	41	53	39	54	58	65	55	56	40	51	41		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.0	9.0	10.1	15.2	19.8	23.0	23.8	23.5	19.6	18.1	14.7	10.3		
		MCWB	2.6	1.3	3.5	7.8	12.6	16.3	16.5	15.5	13.2	8.8	6.8	2.8		
	2%	DB	6.7	7.0	8.3	12.7	17.3	20.8	21.7	21.6	17.5	15.9	12.1	8.2		
		MCWB	1.4	0.9	3.0	6.9	11.3	14.9	15.3	14.9	11.9	8.2	5.8	2.0		
	5%	DB	5.1	5.2	6.9	10.9	15.5	19.1	19.9	20.0	16.0	14.4	10.4	6.6		
		MCWB	0.8	0.4	2.5	6.1	10.4	13.9	14.6	14.3	11.2	8.0	5.0	1.0		
	10%	DB	3.5	3.4	5.6	9.2	13.5	17.4	18.4	18.5	14.6	12.9	8.9	5.2		
		MCWB	-0.1	-0.3	1.8	5.1	9.4	13.0	14.0	13.6	10.5	7.4	4.1	0.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.7	3.1	5.2	9.1	14.2	17.4	18.1	17.3	14.4	11.0	8.0	4.2		
		MCDB	6.1	5.7	8.1	13.3	17.6	21.4	22.1	21.4	17.3	14.4	12.5	7.4		
	2%	WB	2.5	2.0	4.1	7.6	12.2	15.8	16.3	16.0	13.2	9.9	6.7	3.3		
		MCDB	5.3	4.9	6.7	11.8	16.0	19.8	20.1	19.9	16.0	13.6	10.8	6.1		
	5%	WB	1.5	1.1	3.2	6.6	10.9	14.6	15.4	15.0	12.2	9.1	5.6	2.5		
		MCDB	4.3	4.2	5.9	10.2	14.5	18.1	19.1	18.9	15.1	12.6	9.2	5.3		
	10%	WB	0.4	0.2	2.3	5.6	9.8	13.3	14.3	14.1	11.1	8.2	4.7	1.4		
		MCDB	2.9	3.1	4.9	8.8	13.0	16.7	17.8	17.7	13.9	12.0	8.1	4.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	4.6	4.6	4.5	4.7	5.2	5.4	5.5	5.0	4.6	5.0	4.7	4.6		
		MCDBR	6.2	6.1	5.5	5.9	7.0	7.0	7.3	6.6	6.2	6.2	5.7	5.8		
	5% WB	MCWBR	3.7	3.4	3.7	4.1	5.2	5.6	5.5	5.3	5.0	4.0	3.3	3.3		
		MCWBR	5.7	5.6	5.1	5.7	6.2	6.5	6.7	6.1	5.4	5.6	5.5	5.6		
(40) Clear-Sky Solar Irradiance	taub	taub	0.243	0.265	0.296	0.321	0.331	0.335	0.339	0.333	0.312	0.289	0.268	0.244		
		taud	2.471	2.437	2.437	2.437	2.436	2.445	2.427	2.462	2.508	2.563	2.568	2.512		
	Ebn at Noon	Ebn at Noon	869	915	931	934	932	926	917	910	902	877	833	828		
		Edh at Noon	61	80	94	105	109	109	109	101	88	70	57	52		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.18	2.11	3.11	4.17	4.79	5.27	5.26	4.67	3.38	2.29	1.25	0.94		
	RadStd	RadStd	0.16	0.27	0.37	0.51	0.57	0.51	0.51	0.54	0.45	0.24	0.18	0.14		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	+0.90	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (94 neighbors)	+0.50	N/A	N/A	+0.75	+0.42	+0.36	N/A	N/A	+74	+32

Nomenclature: See separate page