

ZELTWEG, Austria

WMO: 111650

Lat: **47.200N**Lon: **14.750E**Elev: **2238**StdP: **13.55**Time Zone: **1.00 (EUC)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	4.1	8.6	0.9	6.2	5.7	5.1	7.7	9.7	22.4	38.3	19.6	37.3	2.1	260	0.532

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.5	85.6	66.2	82.1	65.2	78.7	64.0	68.1	81.2	66.4	78.9	65.0	76.4	7.9	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
63.3	94.4	73.2	62.1	90.7	71.5	60.7	86.2	69.6	33.7	81.3	32.3	79.1	31.1	76.4	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.2	15.2	12.7	-1.5	90.4	5.7	3.3	-5.7	92.8	-9.0	94.7	-12.2	96.5	-16.4	98.9		
(5)			-1.7	71.1	5.5	2.3	-5.6	72.7	-8.8	74.0	-11.9	75.3	-15.9	76.9	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	46.8	26.0	31.3	38.9	46.8	55.6	62.2	65.1	64.2	56.2	47.7	38.0	28.1	(6)	
	DBStd	15.18	8.19	8.17	7.38	6.52	5.89	6.29	5.45	5.43	5.87	6.79	7.50	7.55	(7)	
	HDD50	2946	745	524	346	133	16	2	0	1	14	123	364	678	(8)	
	HDD65	6836	1210	944	808	545	297	126	67	81	267	538	810	1143	(9)	
	CDD50	1760	0	0	2	39	188	367	469	439	201	51	4	0	(10)	
	CDD65	172	0	0	0	0	4	41	70	54	3	0	0	0	(11)	
	CDH74	1908	0	0	0	4	104	475	690	579	55	1	0	0	(12)	
	CDH80	487	0	0	0	0	15	117	185	166	4	0	0	0	(13)	
(14) Wind	WSAvg	4.3	3.5	4.1	5.3	5.2	5.1	4.8	4.7	4.1	3.8	3.6	3.7	3.1	(14)	
(15) Precipitation	PrecAvg	37.1	1.4	1.5	1.9	2.2	3.6	4.9	5.7	5.1	3.7	3.1	2.4	1.7	(15)	
	PrecMax	44.5	2.6	3.7	4.7	4.1	5.4	6.8	12.4	8.3	5.0	5.6	5.1	3.8	(16)	
	PrecMin	28.1	0.3	0.3	0.5	0.6	1.7	2.7	1.0	2.6	2.0	0.4	0.0	0.2	(17)	
	PrecStd	3.8	0.7	0.9	0.9	0.7	1.1	1.2	2.3	1.6	0.9	1.2	1.1	0.8	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.6	57.4	64.8	73.8	81.9	87.8	89.8	89.6	79.1	71.4	62.2	50.8	(19)	
		MCWB	40.7	46.1	50.0	56.0	62.3	66.4	67.4	67.9	64.1	59.4	52.0	44.3	(20)	
	2%	DB	43.6	51.4	60.9	69.4	76.7	83.7	85.3	84.5	75.1	66.5	56.8	45.0	(21)	
		MCWB	38.7	42.2	48.4	53.5	60.3	65.5	66.4	66.6	62.1	56.8	49.4	40.0	(22)	
	5%	DB	40.1	46.6	56.7	65.0	73.0	79.8	81.7	80.7	71.4	62.6	52.2	40.9	(23)	
		MCWB	36.1	39.6	46.2	51.6	58.5	64.0	65.2	65.5	60.3	54.6	47.4	37.2	(24)	
	10%	DB	37.0	42.8	52.1	61.0	68.8	75.6	78.0	76.8	67.7	58.7	48.8	37.5	(25)	
		MCWB	33.8	37.0	43.5	50.0	56.7	62.3	63.9	63.8	58.6	52.8	45.2	35.1	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	42.2	45.9	51.6	57.6	64.2	69.2	70.5	70.1	65.4	60.4	53.1	45.4	(27)	
		MCDB	46.6	55.9	62.4	71.3	77.8	82.9	83.8	83.9	76.6	69.4	59.5	50.3	(28)	
	2%	WB	39.0	42.4	48.8	54.7	61.5	66.8	68.2	67.8	63.0	57.8	50.5	40.8	(29)	
		MCDB	42.6	49.6	59.3	66.3	74.0	79.7	81.2	80.7	72.8	64.7	55.5	44.0	(30)	
	5%	WB	36.4	40.0	46.7	52.6	59.4	65.0	66.4	66.1	61.2	55.5	48.1	37.7	(31)	
		MCDB	39.7	46.2	55.6	63.0	70.5	77.1	78.8	78.4	69.4	61.3	52.3	40.1	(32)	
	10%	WB	34.0	37.4	44.1	50.7	57.4	63.0	64.8	64.5	59.3	53.3	45.6	35.4	(33)	
		MCDB	36.2	42.0	51.2	59.7	67.1	73.6	75.7	75.4	65.9	58.0	48.6	37.0	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	15.3	18.4	20.8	21.4	21.5	21.3	21.5	21.1	19.6	18.9	14.6	13.7	(35)	
		MCDBR	17.8	23.9	29.6	30.3	29.5	28.7	28.0	28.7	25.8	24.8	20.0	17.9	(36)	
	5% WB	MCWBR	13.0	15.6	17.7	16.5	14.5	12.7	12.0	12.9	13.9	15.3	13.8	13.1	(37)	
		MCWBR	16.2	22.5	27.6	26.6	26.8	26.5	25.3	26.2	23.0	22.8	18.4	15.7	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.282	0.311	0.353	0.398	0.405	0.412	0.413	0.409	0.378	0.349	0.317	0.283	(40)	
		taud	2.418	2.358	2.312	2.249	2.276	2.295	2.292	2.321	2.382	2.441	2.479	2.474	(41)	
	Ebn at Noon	Ebn at Noon	258	271	274	271	273	271	269	265	263	254	242	245	(42)	
		Edh at Noon	21	28	35	41	41	40	40	37	32	26	21	18	(43)	
(44) All-Sky Solar Radiation	RadAvg		387	659	998	1317	1549	1705	1703	1515	1092	742	414	321	(44)	
	RadStd		45	86	116	141	167	126	143	171	140	74	61	46	(45)	

Historical Trends