

LUNZ, Austria

WMO: 111700

Lat: 47.854N

Lon: 15.068E

Elev: 611

StdP: 94.20

Time Zone: 1.00 (EUC)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-16.6	-13.6	-18.2	0.8	-16.3	-15.3	1.1	-13.1	6.5	2.6	5.8	2.8	0.4	90	0.514

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.1	28.9	19.2	27.0	18.5	25.2	17.6	20.3	26.6	19.3	25.2	18.4	23.8	1.4	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.3	14.2	22.6	17.3	13.3	21.7	16.4	12.6	20.7	61.0	26.7	57.7	25.3	54.6	23.8	24.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 4.9	3.9	3.1	DB	-19.6	32.5	4.5	1.7	-22.8	33.7	-25.4	34.7	-27.9	35.6	-31.2	36.8	(4)
(5)			WB	-19.8	22.4	4.4	1.1	-23.0	23.2	-25.6	23.8	-28.1	24.5	-31.3	25.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.8	-3.0	-0.9	3.0	7.8	12.2	15.8	17.2	16.9	12.9	8.7	3.3	-1.3	(6)	
	DBStd	8.09	5.18	4.80	3.92	3.90	3.47	3.50	3.07	2.91	3.34	3.59	4.28	4.52	(7)	
	HDD10.0	1665	402	306	217	86	17	3	0	0	11	67	205	351	(8)	
	HDD18.3	3913	661	539	475	316	190	90	59	62	163	299	451	609	(9)	
	CDD10.0	852	0	0	1	19	87	177	222	216	99	27	4	0	(10)	
	CDD18.3	57	0	0	0	0	1	13	23	18	1	0	0	0	(11)	
	CDH23.3	837	0	0	0	7	51	208	284	254	32	0	0	0	(12)	
	CDH26.7	200	0	0	0	0	6	50	74	67	3	0	0	0	(13)	
(14) Wind	WSAvg	0.9	1.1	1.1	1.1	1.1	0.9	0.9	0.9	0.7	0.7	0.9	1.0	1.0	(14)	
(15) Precipitation	PrecAvg	1307	95	80	112	80	126	137	151	136	128	82	87	91	(15)	
	PrecMax	1661	200	176	196	140	314	350	349	294	322	194	156	170	(16)	
	PrecMin	955	17	22	55	13	31	43	39	36	48	8	10	34	(17)	
	PrecStd	178	48	43	47	35	61	65	75	65	63	44	36	33	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.7	12.7	17.6	24.3	27.4	30.6	31.5	31.3	26.5	21.4	18.5	12.7	(19)	
		MCWB	7.1	6.8	9.1	13.5	17.3	19.6	20.0	19.8	17.7	14.6	11.3	6.8	(20)	
	2%	DB	7.9	10.1	14.3	21.1	24.8	28.0	28.7	28.5	23.7	18.6	15.7	8.1	(21)	
		MCWB	4.8	6.0	7.9	12.1	16.1	18.8	19.6	19.1	16.9	13.6	9.9	5.9	(22)	
	5%	DB	5.0	7.4	11.8	18.5	22.6	25.8	26.5	26.3	21.5	16.5	12.2	5.6	(23)	
		MCWB	3.3	4.5	6.9	10.9	14.8	17.8	18.7	18.6	15.9	12.3	8.6	4.0	(24)	
	10%	DB	3.1	5.2	9.3	16.0	20.0	23.5	24.3	23.8	19.2	14.3	9.2	3.8	(25)	
		MCWB	1.9	3.1	5.9	9.7	13.6	16.9	17.7	17.6	14.8	11.5	7.4	2.5	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.5	7.6	10.0	14.2	18.9	21.1	21.7	21.5	18.8	15.9	11.7	7.9	(27)	
		MCDB	10.8	11.4	16.0	22.8	24.1	27.6	28.4	27.8	24.0	19.8	16.6	11.2	(28)	
	2%	WB	5.2	6.1	8.5	12.7	16.9	19.6	20.2	20.1	17.7	14.1	10.2	6.1	(29)	
		MCDB	7.1	9.5	13.2	19.8	23.3	25.8	26.8	26.3	22.5	17.5	14.4	8.1	(30)	
	5%	WB	3.4	4.7	7.3	11.3	15.5	18.5	19.3	19.1	16.5	12.9	8.9	4.1	(31)	
		MCDB	4.8	7.1	11.1	17.3	21.0	24.4	25.0	24.7	20.7	15.8	12.0	5.6	(32)	
	10%	WB	1.9	3.2	6.1	10.1	14.2	17.4	18.3	18.1	15.3	11.7	7.4	2.7	(33)	
		MCDB	3.0	5.1	9.2	15.2	19.1	22.6	23.3	23.0	18.6	13.9	9.4	3.6	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	6.4	7.8	9.4	11.2	11.1	11.2	11.1	11.5	9.9	9.3	6.6	5.4	(35)	
		MCDBR	7.9	11.4	14.7	17.2	16.9	16.4	16.3	16.6	14.6	13.3	11.2	8.3	(36)	
	5% WB	MCWBR	5.5	7.4	8.6	8.9	8.5	8.0	7.9	8.1	8.4	8.4	6.9	6.1	(37)	
		MCWBR	7.3	9.9	13.3	15.5	15.3	14.9	14.6	15.1	13.4	12.1	10.1	8.0	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.294	0.324	0.367	0.408	0.414	0.419	0.424	0.418	0.389	0.355	0.325	0.294	(40)	
		taud	2.381	2.317	2.259	2.203	2.234	2.260	2.248	2.278	2.331	2.404	2.435	2.426	(41)	
	Ebn at Noon		782	830	844	841	850	846	835	823	812	785	739	738	(42)	
		Edh at Noon	69	91	114	133	134	131	131	122	106	84	66	59	(43)	
(44) All-Sky Solar Radiation	RadAvg		1.12	2.00	3.04	4.18	4.84	5.29	5.22	4.66	3.36	2.24	1.22	0.92	(44)	
	RadStd		0.14	0.25	0.35	0.47	0.55	0.43	0.49	0.51	0.43	0.23	0.16	0.12	(45)	

Historical Trends

		DBAvg		Heating		Cooling			Degree-Days			
				99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (102 neighbors)	+0.52	N/A	N/A	N/A	+0.43	+0.40	-110	-143	+79	+38	(47)

Nomenclature: See separate page