

MOENICKKIRCHEN, Austria

WMO: 111850

Lat: 47.511N

Lon: 16.033E

Elev: 3248

StdP: 13.05

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.7	14.0	2.7	7.1	17.0	6.5	8.7	19.0	20.9	34.8	18.4	33.0	5.3	200	0.547

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.3	77.7	65.5	74.8	64.2	72.3	62.8	67.1	75.3	65.4	73.2	63.7	71.0	6.2	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.1	101.1	72.4	62.2	94.6	70.4	60.6	89.1	68.9	33.6	75.4	32.1	73.6	30.8	71.1	73.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.3	15.4	13.1	DB	7.7	81.4	4.5	3.6	4.4	84.0	1.8	86.1	-0.7	88.1	-4.0	90.8	(4)
(5)			WB	7.1	69.7	4.3	2.0	3.9	71.1	1.4	72.3	-1.0	73.4	-4.2	74.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	45.5	28.8	30.6	35.9	44.8	52.4	58.6	62.0	61.8	53.4	46.5	38.6	32.1	
	DBStd	14.00	8.72	8.94	8.60	8.08	6.89	6.83	6.22	6.26	6.49	7.82	8.14	8.56	
	HDD50	3005	658	543	440	192	55	9	1	2	38	161	349	557	
	HDD65	7207	1123	962	903	607	392	211	133	138	352	573	792	1021	
	CDD50	1378	0	1	2	35	130	267	374	369	139	54	7	0	
	CDD65	104	0	0	0	0	2	19	41	40	2	0	0	0	
	CDH74	318	0	0	0	0	3	50	117	145	3	0	0	0	
	CDH80	22	0	0	0	0	0	2	6	14	0	0	0	0	
Wind	WSAvg	5.7	5.4	5.8	5.8	6.5	6.3	5.5	5.5	5.5	5.5	5.7	6.0	5.3	
Precipitation	PrecAvg	34.8	1.3	1.3	2.1	2.0	4.1	4.9	4.6	4.3	3.4	2.6	2.3	1.7	
	PrecMax	44.5	3.2	3.1	4.4	4.0	8.3	8.9	9.5	6.6	8.2	5.2	5.3	3.2	
	PrecMin	24.5	0.2	0.0	0.6	0.2	1.3	1.3	0.3	1.2	1.2	0.5	0.0	0.1	
	PrecStd	4.9	0.7	0.9	1.1	0.9	1.7	2.0	2.2	1.5	1.5	1.3	1.1	0.8	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.3	53.9	58.1	67.4	73.0	78.6	80.7	81.8	72.2	66.2	59.9	53.2	
		MCWB	42.7	41.9	47.3	54.8	60.5	65.9	67.8	67.1	62.1	55.9	49.8	42.2	
	2%	DB	48.1	49.6	54.3	62.5	68.9	75.1	77.3	78.1	68.4	62.7	55.5	49.2	
		MCWB	40.2	40.6	44.9	51.6	58.6	64.7	65.7	65.3	60.3	54.4	47.7	40.7	
	5%	DB	44.8	46.4	50.9	59.1	65.9	72.0	74.5	74.7	65.7	59.7	52.4	46.4	
		MCWB	38.7	39.1	43.0	49.9	56.9	62.9	64.4	63.7	58.7	52.8	46.8	39.5	
	10%	DB	41.7	42.9	47.6	56.0	63.0	69.2	71.9	71.9	62.9	57.0	49.5	43.7	
		MCWB	37.0	37.6	41.4	48.0	55.1	60.7	62.9	62.6	57.0	51.6	45.0	38.2	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.1	44.1	48.2	55.8	62.4	68.3	69.4	69.2	63.7	58.2	52.0	44.9
			MCDB	51.5	51.2	56.2	65.3	70.4	75.8	77.8	77.2	70.4	64.0	56.3	49.7
2%		WB	41.5	41.7	45.9	53.0	59.8	65.6	67.3	66.8	61.4	55.9	49.5	42.5	
		MCDB	46.6	48.0	52.7	61.0	67.1	73.3	75.0	75.8	67.2	60.8	53.4	47.5	
5%		WB	39.6	39.8	43.9	50.7	57.8	63.7	65.4	64.9	59.5	54.1	47.4	40.5	
		MCDB	44.0	45.2	49.4	58.0	64.8	70.8	72.9	73.2	64.6	58.4	51.3	45.0	
10%		WB	37.1	37.7	42.1	48.7	55.8	61.7	63.6	63.2	57.5	52.1	45.4	38.5	
		MCDB	41.1	42.6	47.1	55.1	62.1	68.4	70.9	70.6	62.1	56.1	49.0	43.2	
Mean Daily Temperature Range		5% DB	MDBR	9.1	9.4	10.2	11.3	11.2	11.4	11.3	11.1	9.5	9.4	8.7	9.3
			MCDBR	12.3	12.8	13.9	14.4	14.0	14.3	13.7	13.8	12.4	11.9	11.9	12.2
	MCWBR		8.1	8.2	9.1	8.8	8.8	9.2	8.3	8.5	8.7	8.9	7.8	8.4	
	5% WB	MCDBR	11.4	11.9	12.7	13.6	13.2	13.7	13.0	13.2	11.9	11.0	10.6	11.1	
		MCWBR	8.2	8.4	8.8	8.5	8.9	9.4	8.7	9.0	8.8	8.8	7.6	8.5	
Clear-Sky Solar Irradiance	taub	0.276	0.298	0.331	0.368	0.369	0.375	0.379	0.379	0.355	0.330	0.305	0.276		
	taud	2.453	2.424	2.385	2.318	2.349	2.357	2.343	2.356	2.407	2.463	2.495	2.489		
	Ebn at Noon	261	277	282	280	284	282	279	274	271	260	246	247		
	Edh at Noon	20	26	32	38	38	38	38	36	31	25	20	18		
All-Sky Solar Radiation	RadAvg	359	625	982	1378	1619	1763	1740	1550	1115	733	398	287		
	RadStd	36	81	114	137	172	128	147	163	134	70	47	37		

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only		(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A
Regional (100 neighbors)		+0.99	N/A	N/A	+1.58	+0.81	+0.72	-200	-266	+162

Nomenclature: See separate page