

MOENICKIRCHEN, Austria

WMO: 111850

Lat: 47.511N

Lon: 16.033E

Elev: 990

StdP: 89.98

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.8	-10.0	-16.3	1.0	-8.3	-14.2	1.2	-7.2	9.3	1.5	8.2	0.5	2.4	200	0.547

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.3	25.4	18.6	23.8	17.9	22.4	17.1	19.5	24.0	18.5	22.9	17.6	21.7	2.8	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.8	14.4	22.4	16.8	13.5	21.3	15.9	12.7	20.5	60.3	24.1	56.8	23.1	53.7	21.7	23.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.2	6.9	5.9	-13.5	27.4	2.5	2.0	-15.3	28.9	-16.8	30.0	-18.2	31.2	-20.0	32.6		
(5)			-13.9	21.0	2.4	1.1	-15.6	21.7	-17.0	22.4	-18.4	23.0	-20.1	23.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.5	-1.8	-0.8	2.2	7.1	11.3	14.8	16.7	16.6	11.9	8.1	3.7	0.0		
	DBStd	7.78	4.84	4.97	4.78	4.49	3.83	3.79	3.45	3.48	3.61	4.34	4.52	4.75		
	HDD10.0	1669	366	302	244	107	31	5	1	1	21	89	194	309		
	HDD18.3	4004	624	534	502	337	218	117	74	77	196	318	440	567		
	CDD10.0	766	0	1	1	39	72	148	208	205	77	30	4	0		
	CDD18.3	58	0	0	0	0	1	11	23	22	1	0	0	0		
	CDH23.3	177	0	0	0	0	2	28	65	81	2	0	0	0		
	CDH26.7	12	0	0	0	0	0	1	3	8	0	0	0	0		
(14) Wind	WSAvg	2.6	2.4	2.6	2.6	2.9	2.8	2.5	2.5	2.4	2.5	2.5	2.7	2.4		
(15) Precipitation	PrecAvg	883	34	32	54	52	103	125	117	109	86	67	59	44		
	PrecMax	1130	82	78	113	101	211	226	241	168	209	132	134	81		
	PrecMin	623	6	0	15	6	34	33	7	31	31	12	0	2		
	PrecStd	124	19	22	27	23	42	50	55	37	39	32	28	20		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.8	12.2	14.5	19.7	22.8	25.9	27.0	27.7	22.3	19.0	15.5	11.8		
		MCWB	5.9	5.5	8.5	12.7	15.8	18.8	19.9	19.5	16.7	13.3	9.9	5.7		
	2%	DB	9.0	9.8	12.4	16.9	20.5	23.9	25.2	25.6	20.2	17.1	13.1	9.6		
		MCWB	4.5	4.8	7.2	10.9	14.8	18.2	18.7	18.5	15.7	12.5	8.7	4.8		
	5%	DB	7.1	8.0	10.5	15.1	18.8	22.2	23.6	23.7	18.7	15.4	11.3	8.0		
		MCWB	3.7	3.9	6.1	10.0	13.8	17.2	18.0	17.6	14.8	11.5	8.2	4.2		
	10%	DB	5.4	6.1	8.7	13.3	17.2	20.7	22.2	22.2	17.2	13.9	9.7	6.5		
		MCWB	2.8	3.1	5.2	8.9	12.8	16.0	17.2	17.0	13.9	10.9	7.2	3.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.7	6.7	9.0	13.2	16.9	20.2	20.8	20.7	17.6	14.6	11.1	7.2		
		MCDB	10.8	10.7	13.4	18.5	21.3	24.4	25.4	25.1	21.3	17.8	13.5	9.8		
	2%	WB	5.3	5.4	7.7	11.6	15.4	18.7	19.6	19.3	16.3	13.3	9.7	5.8		
		MCDB	8.1	8.9	11.5	16.1	19.5	22.9	23.9	24.3	19.5	16.0	11.9	8.6		
	5%	WB	4.2	4.3	6.6	10.4	14.3	17.6	18.6	18.3	15.3	12.3	8.6	4.7		
		MCDB	6.6	7.3	9.7	14.4	18.2	21.5	22.7	22.9	18.1	14.7	10.7	7.2		
	10%	WB	2.9	3.2	5.6	9.3	13.2	16.5	17.6	17.3	14.2	11.2	7.4	3.6		
		MCDB	5.1	5.9	8.4	12.8	16.7	20.2	21.6	21.4	16.7	13.4	9.4	6.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	5.1	5.2	5.7	6.3	6.2	6.3	6.3	6.1	5.3	5.2	4.8	5.1		
		MCDBR	6.8	7.1	7.7	8.0	7.8	7.9	7.6	7.7	6.9	6.6	6.6	6.8		
	5% WB	MCWBR	4.5	4.6	5.0	4.9	4.9	5.1	4.6	4.7	4.8	4.9	4.4	4.7		
		MCWBR	6.3	6.6	7.1	7.6	7.3	7.6	7.2	7.3	6.6	6.1	5.9	6.2		
(40) Clear-Sky Solar Irradiance	taub	taub	0.276	0.298	0.331	0.368	0.369	0.375	0.379	0.379	0.355	0.330	0.305	0.276		
		taud	2.453	2.424	2.385	2.318	2.349	2.357	2.343	2.356	2.407	2.463	2.495	2.489		
	Ebn at Noon	Ebn at Noon	822	873	890	884	894	888	878	863	853	821	776	779		
		Edh at Noon	64	82	101	119	119	119	119	113	98	79	63	56		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.13	1.97	3.10	4.34	5.10	5.56	5.48	4.88	3.52	2.31	1.25	0.90		
	RadStd	RadStd	0.11	0.26	0.36	0.43	0.54	0.40	0.46	0.52	0.42	0.22	0.15	0.12		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (100 neighbors)	+0.55	N/A	N/A	+0.88	+0.45	+0.40	-111	-148	+90	+52

Nomenclature: See separate page