

EISENSTADT, Austria

WMO: 111900

Lat: 47.854N

Lon: 16.538E

Elev: 182

StdP: 99.16

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-9.2	-7.1	-13.6	1.2	-8.1	-10.9	1.5	-5.2	10.4	5.5	9.6	4.4	2.7	340	0.513

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.8	31.9	21.6	30.0	20.7	28.2	19.9	22.3	29.9	21.4	28.5	20.5	26.9	3.8	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.7	14.8	25.8	18.9	14.0	24.9	18.1	13.3	23.9	66.3	30.1	62.8	28.5	59.9	27.0	25.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.4	8.3	7.4	-11.6	34.5	2.9	2.3	-13.7	36.2	-15.4	37.5	-17.0	38.8	-19.1	40.5		
(5)			-12.2	23.7	2.7	0.8	-14.1	24.3	-15.8	24.8	-17.3	25.3	-19.3	25.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.3	0.4	2.3	6.5	11.8	15.9	19.6	21.6	21.2	16.4	11.1	6.1	1.4		
	DBStd	8.41	4.45	4.53	4.31	4.04	3.50	3.48	3.26	3.24	3.38	3.89	3.95	4.06		
	HDD10.0	1094	297	217	124	28	2	0	0	0	1	34	126	267		
	HDD18.3	2897	555	449	367	199	92	27	8	10	77	223	366	524		
	CDD10.0	1551	1	1	14	81	184	289	361	348	192	69	10	1		
	CDD18.3	312	0	0	0	2	16	65	111	100	18	1	0	0		
	CDH23.3	2404	0	0	0	18	124	509	893	752	104	3	0	0		
	CDH26.7	752	0	0	0	2	18	148	308	259	17	0	0	0		
(14) Wind	WSAvg	3.4	3.3	3.5	3.5	3.7	3.7	3.4	3.5	3.3	3.4	3.1	3.2	3.2		
(15) Precipitation	PrecAvg	623	29	26	41	41	67	77	76	71	67	47	45	35		
	PrecMax	822	63	65	89	88	176	186	176	164	169	97	93	75		
	PrecMin	430	5	0	9	0	13	21	5	7	18	3	0	5		
	PrecStd	100	16	19	24	24	35	40	43	39	40	26	22	17		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.7	15.5	20.3	25.7	28.8	32.7	34.1	34.6	28.9	23.3	18.5	13.2		
		MCWB	8.3	9.5	12.2	16.1	19.3	22.0	22.3	21.1	19.3	16.6	13.4	8.9		
	2%	DB	10.8	12.7	17.7	22.7	26.4	30.4	31.9	31.8	26.2	20.6	15.9	10.4		
		MCWB	6.9	8.0	10.9	14.5	18.2	21.2	21.5	21.4	18.3	15.3	11.8	7.1		
	5%	DB	8.6	10.5	15.1	20.5	24.6	28.2	30.0	29.5	24.1	18.7	13.4	8.2		
		MCWB	5.5	6.8	9.5	13.4	17.3	20.1	20.7	20.5	17.2	14.4	10.4	5.5		
	10%	DB	6.7	8.5	12.9	18.5	22.6	26.4	28.1	27.5	22.1	16.7	11.6	6.6		
		MCWB	4.2	5.5	8.5	12.3	16.0	19.1	20.0	19.6	16.4	13.3	9.2	4.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.1	10.0	12.7	16.8	20.2	23.3	23.4	23.2	20.1	17.2	13.9	9.3		
		MCDB	12.7	15.1	19.3	24.2	26.9	30.5	31.5	31.1	26.7	21.8	17.5	12.3		
	2%	WB	7.5	8.4	11.3	15.1	18.9	21.9	22.3	21.9	19.0	15.9	12.2	7.4		
		MCDB	10.5	12.1	16.5	21.6	25.3	28.8	30.1	29.8	24.6	19.8	15.1	10.2		
	5%	WB	5.7	7.0	10.1	13.9	17.7	20.8	21.4	21.0	18.1	14.8	10.7	5.9		
		MCDB	8.0	10.1	14.3	19.5	23.6	27.1	28.5	28.3	22.7	17.8	13.2	7.9		
	10%	WB	4.4	5.7	8.9	12.8	16.7	19.8	20.5	20.1	17.2	13.8	9.4	4.7		
		MCDB	6.6	8.3	12.5	17.7	21.6	25.3	26.8	26.2	21.1	16.3	11.3	6.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	4.9	6.2	7.8	9.2	9.3	9.5	9.8	9.6	8.2	7.2	5.2	4.4		
		MCDBR	7.8	9.6	11.6	12.3	12.5	12.5	12.8	12.9	11.3	9.7	8.2	7.4		
	5% WB	MCWBR	5.1	5.9	6.5	6.1	5.7	5.2	4.8	4.9	4.9	5.2	5.1	5.1		
		MCWBR	7.4	9.0	10.8	11.7	11.8	12.1	12.0	12.1	10.5	9.0	7.6	7.1		
(40) Clear-Sky Solar Irradiance	taub		0.317	0.342	0.380	0.424	0.422	0.427	0.433	0.433	0.406	0.376	0.348	0.316		
		taud	2.391	2.352	2.273	2.177	2.229	2.254	2.238	2.250	2.297	2.354	2.389	2.417		
	Ebn at Noon		752	811	830	826	843	839	827	808	793	757	704	706		
		Edh at Noon	69	89	113	137	135	132	133	126	109	88	70	61		
(44) All-Sky Solar Radiation	RadAvg		1.02	1.84	3.03	4.52	5.35	5.82	5.65	5.03	3.60	2.22	1.16	0.79		
	RadStd		0.11	0.25	0.38	0.44	0.55	0.42	0.48	0.49	0.43	0.24	0.11	0.09		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.71	N/A	N/A	+1.07	N/A	N/A	-272	-301	N/A	N/A
(47) Regional (84 neighbors)		+0.57	N/A	N/A	+0.88	+0.48	+0.41	-119	-159	+91	+49

Nomenclature: See separate page