

LIENZ, Austria

WMO: 112040

Lat: 46.826N

Lon: 12.806E

Elev: 2192

StdP: 13.57

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	7.1	11.0	3.5	7.1	11.0	6.5	8.3	15.6	18.2	38.2	15.7	37.3	1.6	280	0.510

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.4	85.9	68.1	82.8	66.5	79.7	64.9	69.4	83.3	67.6	80.2	66.0	77.4	9.1	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
64.4	98.1	76.6	62.8	92.8	73.8	61.6	88.7	71.4	34.8	83.7	33.2	80.3	31.9	77.5	74.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.7	14.1	11.8	2.8	90.9	4.6	3.6	-0.5	93.4	-3.2	95.5	-5.8	97.5	-9.2	100.1		
(5)			2.4	72.0	4.6	2.3	-0.9	73.6	-3.5	75.0	-6.1	76.3	-9.4	77.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	48.0	26.5	32.2	41.1	49.1	57.2	63.8	66.8	65.9	57.6	48.8	37.6	28.2		
	DBStd	15.36	7.38	6.74	6.62	6.15	5.56	6.23	5.23	5.26	5.45	6.20	6.79	6.69		
	HDD50	2757	727	499	281	89	7	1	0	0	6	97	374	676		
	HDD65	6465	1192	919	740	478	250	95	43	54	228	502	823	1141		
	CDD50	2021	0	0	6	61	230	416	521	492	233	61	1	0		
	CDD65	252	0	0	0	0	7	60	98	81	6	0	0	0		
	CDH74	2370	0	0	0	7	125	628	868	679	63	0	0	0		
	CDH80	613	0	0	0	0	18	175	236	180	4	0	0	0		
(14) Wind	WSAvg	3.8	3.0	3.3	4.4	5.0	4.9	5.0	4.6	4.1	3.4	2.9	2.6	2.7		
(15) Precipitation	PrecAvg	49.2	2.5	2.4	2.9	3.4	4.3	5.3	5.5	5.4	4.3	5.0	5.1	3.1		
	PrecMax	63.1	8.6	8.0	6.2	6.0	8.6	8.3	10.4	8.4	7.5	13.3	15.3	7.4		
	PrecMin	39.7	0.6	0.8	0.6	1.0	1.6	2.8	1.7	2.7	1.7	0.3	0.3	0.5		
	PrecStd	6.4	1.6	1.5	1.4	1.2	1.6	1.5	1.9	1.4	1.5	3.0	3.7	1.5		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.3	56.3	67.6	74.0	82.8	89.3	90.0	89.9	80.1	70.4	56.5	46.9		
		MCWB	42.1	45.2	51.0	56.9	64.1	68.0	69.8	69.1	65.9	58.8	48.5	39.5		
	2%	DB	43.1	50.2	62.6	69.8	77.6	85.0	85.6	84.6	75.4	66.1	52.7	42.1		
		MCWB	36.4	40.9	49.0	55.0	61.1	66.8	68.5	68.0	62.8	56.1	47.6	37.7		
	5%	DB	38.9	45.9	58.3	66.2	73.6	81.3	82.4	81.0	71.8	63.0	50.2	39.1		
		MCWB	34.6	38.3	46.7	52.8	59.1	64.8	66.5	66.6	60.6	54.3	46.7	35.9		
	10%	DB	36.0	42.2	53.9	62.3	69.9	77.4	79.0	77.4	68.6	59.5	47.7	36.6		
		MCWB	33.0	36.2	44.3	50.5	57.0	62.8	65.0	64.9	59.1	52.8	44.7	34.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	43.1	45.7	52.5	58.3	65.2	70.7	72.0	71.7	66.4	59.9	51.1	41.8		
		MCDB	49.8	55.3	65.3	72.7	79.9	85.3	87.3	86.7	78.5	68.1	53.5	44.5		
	2%	WB	37.7	41.7	49.6	55.7	62.1	68.1	69.6	69.0	63.6	57.4	49.2	38.5		
		MCDB	41.1	49.0	61.2	68.0	75.3	81.7	83.4	82.6	73.5	63.6	51.5	40.9		
	5%	WB	35.3	39.0	47.3	53.4	60.1	65.9	67.6	67.2	61.8	55.5	47.3	36.3		
		MCDB	37.9	44.7	57.2	64.1	71.6	78.8	79.9	79.1	69.8	61.0	49.7	38.4		
	10%	WB	33.4	36.8	44.8	51.3	58.0	64.0	65.8	65.5	60.1	53.7	44.8	34.5		
		MCDB	35.6	41.4	52.7	60.6	67.6	75.1	76.7	75.8	67.0	58.8	47.2	36.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	14.5	17.3	20.9	20.4	20.6	21.0	21.4	20.3	19.7	17.9	13.3	12.2		
		MCDBR	16.8	23.2	29.1	28.1	28.1	28.2	26.9	26.7	24.8	22.7	16.7	14.3		
		MCWBR	11.7	14.6	16.4	14.5	13.4	12.3	11.7	11.8	13.1	13.2	11.2	10.5		
	5% WB	MCDBR	14.7	21.6	27.6	25.9	26.0	25.8	25.1	24.5	22.0	19.9	13.5	12.4		
		MCWBR	10.8	13.9	16.0	13.8	12.8	11.8	11.7	11.4	11.7	12.0	9.3	9.6		
(40) Clear-Sky Solar Irradiance	taub		0.292	0.328	0.389	0.450	0.467	0.478	0.469	0.461	0.416	0.383	0.336	0.295		
	taud		2.297	2.183	2.081	2.017	2.043	2.072	2.112	2.148	2.239	2.282	2.348	2.367		
	Ebn at Noon		251	261	259	254	255	252	253	249	250	239	231	236		
	Edh at Noon		24	34	43	51	52	50	48	44	37	30	23	21		
(44) All-Sky Solar Radiation	RadAvg		452	729	1072	1332	1546	1730	1766	1551	1155	778	450	379		
	RadStd		51	96	131	175	189	151	142	162	140	90	82	54		

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+1.51	+2.84	N/A	+2.39	N/A	N/A	-392	-484	+265
(47) Regional (81 neighbors)		+0.77	N/A	N/A	+1.13	+0.72	+0.63	N/A	N/A	+133

Nomenclature: See separate page