

WEITENSFELD, Austria

WMO: 112250

Lat: 46.8492N

Lon: 14.1908E

Elev: 712

StdP: 93.05

Time Zone: 1.00 (EUC)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.9	-12.4	-16.7	0.9	-13.1	-14.5	1.2	-11.1	6.5	2.9	5.1	3.1	1.4	280	0.508

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.3	29.8	19.8	28.1	18.9	26.4	18.3	20.6	27.9	19.7	26.5	18.8	25.0	1.9	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.1	14.2	23.8	17.3	13.5	22.7	16.5	12.8	21.4	62.6	27.9	59.4	26.5	56.3	25.1	24.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5.1	3.9	3.2	-18.1	32.5	2.7	1.6	-20.1	33.7	-21.7	34.6	-23.2	35.5	-25.2	36.7
			-18.3	22.2	2.7	0.9	-20.3	22.8	-21.8	23.4	-23.4	23.9	-25.3	24.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	8.4	-2.6	-0.4	3.9	8.7	12.6	16.6	18.5	18.1	13.7	8.9	3.9	-2.1
	DBStd	8.16	3.82	3.90	3.36	3.20	3.15	3.07	2.87	2.94	3.32	3.54	3.69	3.79
	HDD10.0	1573	392	291	188	61	12	1	0	0	7	64	182	376
	HDD18.3	3734	650	524	446	291	179	68	34	41	142	294	432	634
	CDD10.0	972	0	0	0	20	92	199	263	252	117	29	1	0
	CDD18.3	92	0	0	0	0	1	17	38	34	2	0	0	0
	CDH23.3	1250	0	0	0	6	51	293	476	388	36	0	0	0
	CDH26.7	319	0	0	0	0	6	73	129	109	2	0	0	0
Wind	WSAvg	1.4	1.3	1.3	1.5	1.6	1.6	1.5	1.4	1.3	1.3	1.4	1.2	1.2
Precipitation	PrecAvg	995	29	33	50	65	91	121	142	139	100	93	87	45
	PrecMax	1276	95	141	100	108	147	184	292	225	165	228	228	123
	PrecMin	795	4	3	8	16	40	62	37	79	45	0	5	5
	PrecStd	118	19	29	25	23	26	30	50	44	33	51	51	27
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.7	14.0	19.1	24.1	27.2	31.3	31.8	32.4	26.1	21.7	14.6	7.9
		MCWB	4.9	7.6	10.0	14.6	17.1	19.3	20.9	21.1	17.9	15.5	10.8	4.0
	2%	DB	5.8	9.8	16.6	21.0	24.6	28.7	29.8	29.5	24.3	19.1	12.0	5.8
		MCWB	3.3	5.2	9.0	12.5	15.8	18.8	20.0	19.8	17.4	13.8	9.7	3.3
	5%	DB	3.9	7.3	13.7	18.9	22.6	26.8	28.0	27.5	22.3	17.1	10.3	4.1
		MCWB	1.9	3.4	7.7	11.2	14.8	17.9	19.1	19.2	16.5	12.9	8.9	2.2
	10%	DB	2.3	5.0	11.1	16.5	20.3	24.6	26.1	25.4	20.0	14.7	8.9	2.5
		MCWB	0.8	2.2	6.3	10.3	13.6	16.9	18.4	18.3	15.1	11.4	7.9	1.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.5	7.6	10.7	14.9	17.9	20.6	21.8	21.6	18.7	15.7	11.2	5.5
		MCDB	7.8	13.8	18.1	23.8	24.5	28.6	29.5	29.7	24.3	20.6	12.9	6.6
	2%	WB	4.0	5.4	9.2	13.2	16.4	19.5	20.7	20.6	17.8	14.4	10.1	4.0
		MCDB	5.9	9.2	15.8	19.5	23.6	26.9	28.0	27.9	23.2	18.3	11.4	5.3
	5%	WB	2.2	3.8	8.0	11.7	15.2	18.4	19.8	19.7	16.9	13.1	9.1	2.6
		MCDB	3.4	6.7	13.1	17.2	21.4	25.4	26.6	26.1	21.6	16.4	10.2	3.7
	10%	WB	1.1	2.5	6.6	10.6	14.1	17.4	18.8	18.8	15.8	11.9	7.9	1.6
		MCDB	2.0	4.7	10.5	15.4	19.4	23.7	24.9	24.6	19.2	14.4	8.8	2.4
Mean Daily Temperature Range	5% DB	MDBR	8.8	10.5	12.9	13.3	12.9	13.0	13.3	13.1	11.2	10.7	7.3	8.5
		MCDBR	10.1	14.7	18.1	18.6	17.3	17.3	16.7	16.7	14.3	13.9	9.7	10.1
		MCWBR	7.4	9.9	10.9	10.2	8.9	8.2	7.6	7.8	7.8	8.9	6.9	7.7
	5% WB	MCDBR	8.4	13.2	16.9	16.3	15.7	15.6	15.7	15.2	13.1	12.9	8.6	8.6
		MCWBR	6.4	9.2	10.5	9.1	8.2	7.6	7.5	7.5	7.3	8.3	6.4	6.8
Clear-Sky Solar Irradiance	taub	0.278	0.306	0.349	0.394	0.404	0.411	0.411	0.405	0.374	0.349	0.315	0.280	
	taud	2.424	2.367	2.320	2.256	2.278	2.298	2.300	2.332	2.395	2.444	2.486	2.480	
	Ebn at Noon	824	864	871	859	862	856	850	840	835	804	770	782	
	Edh at Noon	68	88	108	127	129	127	125	117	100	82	65	58	
All-Sky Solar Radiation	RadAvg	1.30	2.15	3.26	4.20	4.97	5.54	5.57	4.92	3.56	2.39	1.34	1.08	
	RadStd	0.16	0.30	0.40	0.49	0.54	0.42	0.43	0.53	0.45	0.26	0.22	0.16	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (94 neighbors)	+0.49	N/A	N/A	+0.81	+0.47	+0.37	N/A	-133	+89	+55

Nomenclature: See separate page