

KLAGENFURT, Austria

WMO: 112310

Lat: 46.643N

Lon: 14.337E

Elev: 1562

StdP: 13.89

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.1	13.4	5.1	7.6	13.7	8.7	9.1	16.7	13.3	37.3	10.4	35.7	3.3	310	0.466

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.7	88.0	68.3	84.9	67.4	82.0	66.3	70.2	84.1	68.6	81.5	67.2	79.1	5.7	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.7	100.5	75.4	64.3	95.4	73.5	62.8	90.7	71.9	35.0	84.4	33.7	82.0	32.5	79.1	76.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.7	9.9	7.8	DB	4.0	92.7	5.3	3.1	0.2	94.9	-2.9	96.7	-5.9	98.4	-9.7	100.6	(4)
(5)			WB	3.6	73.1	5.2	1.7	-0.1	74.3	-3.2	75.3	-6.1	76.3	-9.9	77.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	49.5	28.0	32.7	41.7	50.4	59.0	65.9	68.8	67.8	59.0	50.3	39.8	29.5		
	DBStd	15.68	7.00	6.97	7.03	6.48	5.88	6.17	5.41	5.35	5.75	6.60	7.01	6.54		
	HDD50	2537	682	485	266	74	5	0	0	0	3	78	310	634		
	HDD65	6035	1147	905	723	438	199	63	26	32	193	455	755	1099		
	CDD50	2355	0	0	7	86	284	477	584	550	274	88	5	0		
	CDD65	382	0	0	0	0	14	91	145	118	14	0	0	0		
	CDH74	3536	0	0	0	15	217	867	1319	1012	104	2	0	0		
	CDH80	1061	0	0	0	0	34	259	442	318	8	0	0	0		
	WSAvg	3.4	2.8	3.2	4.0	4.1	4.0	3.8	3.8	3.4	3.2	3.0	2.8	2.7		
	PrecAvg	37.4	1.3	1.5	2.1	2.6	3.5	4.3	4.8	4.8	4.0	3.3	3.3	1.9		
(15) Precipitation	PrecMax	56.0	5.1	7.1	6.7	5.8	11.0	8.9	11.5	11.6	12.4	8.9	8.6	4.9		
	PrecMin	26.8	0.0	0.0	0.1	0.4	0.9	1.5	1.1	0.9	0.7	0.0	0.0	0.0		
	PrecStd	6.5	1.0	1.4	1.3	1.3	1.8	1.8	1.9	2.2	2.2	2.2	1.9	1.2		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.6	58.2	67.7	75.8	84.3	90.1	92.9	91.7	80.7	73.2	62.0	47.2		
		MCWB	42.3	46.9	51.4	57.9	64.3	68.6	71.0	69.2	66.4	61.5	52.6	43.6		
	2%	DB	42.8	51.9	63.0	71.5	79.2	86.3	88.1	87.4	77.2	68.1	55.7	42.3		
		MCWB	38.0	43.0	49.9	55.6	62.2	67.9	68.6	68.3	64.4	58.7	50.5	39.7		
	5%	DB	39.3	46.8	59.1	67.9	75.7	82.7	84.8	83.5	73.5	64.2	52.1	39.4		
		MCWB	36.1	39.9	48.1	53.9	60.3	66.2	67.5	67.4	62.4	56.5	48.9	37.9		
	10%	DB	36.2	42.7	55.2	64.1	71.9	79.1	81.6	79.7	69.9	60.5	49.7	37.4		
		MCWB	34.5	37.9	45.8	52.3	58.6	64.5	66.2	66.1	60.4	54.8	47.0	36.1		
	0.4%	WB	43.4	46.9	52.8	59.3	65.9	71.0	72.4	72.0	67.5	61.9	54.1	44.8		
		MCDB	48.0	56.2	64.8	73.6	79.8	86.1	88.3	84.9	78.3	71.2	59.2	46.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	39.1	43.7	50.5	56.6	63.5	69.0	70.2	69.9	65.3	59.4	51.6	40.2		
		MCDB	41.4	50.5	61.6	68.7	77.0	83.2	84.6	83.2	74.9	66.3	54.9	41.3		
	5%	WB	36.6	40.9	48.6	54.7	61.5	67.3	68.5	68.3	63.4	57.5	49.4	38.1		
		MCDB	38.3	46.1	57.8	65.1	73.2	80.2	81.4	80.7	71.6	62.8	52.3	39.0		
	10%	WB	34.6	38.2	46.5	53.0	59.6	65.5	67.1	66.9	61.6	55.4	47.4	36.1		
		MCDB	35.8	41.7	53.9	62.2	69.9	76.9	78.9	77.9	68.2	59.9	49.3	36.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	12.2	16.5	20.6	20.4	20.9	21.1	21.7	20.6	18.5	16.4	11.2	9.5		
		MCDBR	16.1	23.4	28.2	28.3	27.6	27.0	26.9	26.8	22.6	21.4	15.7	11.6		
		MCWBR	11.6	15.0	15.8	14.1	12.2	10.7	10.1	10.3	11.3	12.4	10.5	8.8		
		MCDBR	13.6	22.0	26.4	25.1	25.1	25.2	24.7	24.1	21.0	19.6	14.0	9.8		
	5% WB	MCWBR	10.3	14.7	15.1	12.8	11.4	10.5	10.2	10.3	10.8	11.7	9.7	7.9		
(40) Clear-Sky Solar Irradiance	taub		0.293	0.321	0.365	0.411	0.418	0.426	0.425	0.420	0.391	0.366	0.331	0.294		
	taud		2.430	2.373	2.307	2.221	2.249	2.269	2.275	2.305	2.361	2.408	2.462	2.486		
	Ebn at Noon		256	269	271	267	269	267	266	262	259	248	238	243		
	Edh at Noon		22	28	35	42	42	42	41	38	33	27	21	19		
(44) All-Sky Solar Radiation	RadAvg		412	678	1039	1340	1611	1799	1806	1590	1144	758	421	341		
	RadStd		55	98	132	155	164	127	129	170	147	85	68	50		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.86	N/A	N/A	N/A	+0.79	+0.95	N/A	N/A	+148	+95
(47)	Regional (91 neighbors)	+0.86	N/A	N/A	+1.35	+0.77	+0.59	N/A	-225	+162	+101

Nomenclature: See separate page