

KLAGENFURT, Austria

WMO: 112310

Lat: 46.643N

Lon: 14.337E

Elev: 476

StdP: 95.74

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.7	-10.3	-15.0	1.1	-10.1	-13.0	1.3	-8.5	6.0	2.9	4.6	2.1	1.5	310	0.466

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.1	31.1	20.2	29.4	19.7	27.8	19.1	21.2	29.0	20.3	27.5	19.6	26.2	2.6	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.7	14.4	24.1	17.9	13.6	23.0	17.1	13.0	22.2	63.4	29.1	60.5	27.8	57.8	26.2	24.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.7	4.4	3.5	-15.5	33.7	2.9	1.7	-17.7	34.9	-19.4	35.9	-21.0	36.9	-23.2	38.1		
(5)			-15.8	22.8	2.9	0.9	-17.9	23.5	-19.5	24.1	-21.2	24.6	-23.3	25.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.7	-2.2	0.4	5.4	10.2	15.0	18.8	20.5	19.9	15.0	10.2	4.4	-1.4		
	DBStd	8.71	3.89	3.87	3.90	3.60	3.27	3.43	3.01	2.97	3.20	3.67	3.89	3.64		
	HDD10.0	1409	379	269	148	41	3	0	0	0	2	43	172	352		
	HDD18.3	3353	637	503	402	243	111	35	14	18	107	253	419	611		
	CDD10.0	1308	0	0	4	48	158	265	324	306	152	49	3	0		
	CDD18.3	212	0	0	0	0	8	51	81	66	8	0	0	0		
	CDH23.3	1964	0	0	0	8	121	482	733	562	58	1	0	0		
	CDH26.7	589	0	0	0	0	19	144	246	177	4	0	0	0		
(14) Wind	WSAvg	1.5	1.2	1.4	1.8	1.8	1.8	1.7	1.7	1.5	1.4	1.3	1.2	1.2		
(15) Precipitation	PrecAvg	951	33	39	53	65	90	110	122	121	101	84	85	49		
	PrecMax	1423	130	181	170	148	279	226	293	295	315	226	219	124		
	PrecMin	681	0	0	3	9	24	37	28	23	18	0	0	1		
	PrecStd	164	26	35	33	32	46	45	49	55	57	55	48	30		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.2	14.6	19.8	24.3	29.0	32.3	33.8	33.1	27.1	22.9	16.7	8.5		
		MCWB	5.7	8.3	10.8	14.4	18.0	20.4	21.7	20.7	19.1	16.4	11.5	6.5		
	2%	DB	6.0	11.1	17.2	21.9	26.2	30.2	31.2	30.8	25.1	20.0	13.2	5.7		
		MCWB	3.3	6.1	10.0	13.1	16.8	19.9	20.3	20.2	18.0	14.8	10.3	4.3		
	5%	DB	4.0	8.2	15.1	20.0	24.3	28.2	29.4	28.6	23.0	17.9	11.1	4.1		
		MCWB	2.3	4.4	9.0	12.2	15.7	19.0	19.7	19.7	16.9	13.6	9.4	3.3		
	10%	DB	2.3	6.0	12.9	17.8	22.2	26.2	27.5	26.5	21.1	15.8	9.8	3.0		
		MCWB	1.4	3.3	7.7	11.3	14.8	18.0	19.0	19.0	15.8	12.7	8.3	2.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.3	8.3	11.6	15.2	18.8	21.7	22.4	22.2	19.7	16.6	12.3	7.1		
		MCDB	8.9	13.4	18.2	23.1	26.5	30.0	31.3	29.4	25.7	21.8	15.1	7.9		
	2%	WB	3.9	6.5	10.3	13.7	17.5	20.6	21.2	21.1	18.5	15.2	10.9	4.6		
		MCDB	5.2	10.3	16.5	20.4	25.0	28.5	29.2	28.4	23.8	19.1	12.7	5.2		
	5%	WB	2.6	4.9	9.2	12.6	16.4	19.6	20.3	20.2	17.5	14.2	9.7	3.4		
		MCDB	3.5	7.8	14.4	18.4	22.9	26.8	27.4	27.0	22.0	17.1	11.3	3.9		
	10%	WB	1.4	3.4	8.0	11.7	15.3	18.6	19.5	19.4	16.5	13.0	8.5	2.3		
		MCDB	2.1	5.4	12.2	16.8	21.1	24.9	26.1	25.5	20.1	15.5	9.6	2.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	6.8	9.1	11.4	11.4	11.6	11.7	12.1	11.4	10.3	9.1	6.2	5.3		
		MCDBR	9.0	13.0	15.6	15.7	15.3	15.0	14.9	14.9	12.5	11.9	8.7	6.5		
		MCWBR	6.4	8.4	8.8	7.9	6.8	5.9	5.6	5.7	6.3	6.9	5.8	4.9		
		MCDBR	7.5	12.2	14.7	13.9	14.0	14.0	13.7	13.4	11.7	10.9	7.8	5.4		
	5% WB	MCWBR	5.7	8.1	8.4	7.1	6.4	5.8	5.6	5.7	6.0	6.5	5.4	4.4		
(40) Clear-Sky Solar Irradiance	taub		0.293	0.321	0.365	0.411	0.418	0.426	0.425	0.420	0.391	0.366	0.331	0.294		
	taud		2.430	2.373	2.307	2.221	2.249	2.269	2.275	2.305	2.361	2.408	2.462	2.486		
	Ebn at Noon		806	848	855	843	849	842	837	826	818	783	750	765		
	Edh at Noon		68	89	110	132	133	131	129	120	104	86	67	59		
(44) All-Sky Solar Radiation	RadAvg		1.30	2.14	3.27	4.22	5.08	5.67	5.69	5.01	3.61	2.39	1.33	1.07		
	RadStd		0.17	0.31	0.41	0.49	0.52	0.40	0.41	0.54	0.46	0.27	0.21	0.16		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.48	N/A	N/A	N/A	+0.44	+0.53	N/A	N/A	+82	+53
(47) Regional (91 neighbors)		+0.48	N/A	N/A	+0.75	+0.43	+0.33	N/A	-125	+90	+56

Nomenclature: See separate page