

SCHOECKL, Austria

WMO: 112410

Lat: 47.1986N

Lon: 15.4664E

Elev: 4720

StdP: 12.36

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	6.0	10.1	-4.2	5.2	16.0	1.4	7.0	17.5	39.5	17.8	35.1	19.3	9.7	340	0.680

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.4	71.5	61.3	69.0	60.2	66.7	59.2	63.3	68.8	61.5	67.3	59.9	65.5	7.0	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
61.3	96.7	66.7	59.2	89.7	64.9	57.4	84.0	63.6	31.4	68.8	29.9	67.6	28.6	65.8	72.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
33.3	27.3	22.3	DB	4.1	75.9	4.9	2.8	0.6	77.9	-2.3	79.5	-5.0	81.1	-8.6	83.1
			WB	3.2	66.4	4.7	2.0	-0.1	67.8	-2.9	68.9	-5.5	70.0	-8.9	71.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	41.0	25.7	26.7	31.4	39.4	46.7	53.4	57.1	56.3	48.2	42.2	35.1	29.1	(6)
(7)		DBStd	13.50	8.90	9.13	8.52	7.93	7.02	7.17	6.22	6.44	6.64	8.31	8.64	9.01	(7)
(8)		HDD50	4002	754	651	577	325	149	47	12	16	112	262	448	649	(8)
(9)		HDD65	8772	1219	1071	1041	767	567	352	254	279	505	707	896	1114	(9)
(10)		CDD50	725	0	0	0	8	47	148	232	210	57	21	2	0	(10)
(11)		CDD65	21	0	0	0	0	0	3	9	9	0	0	0	0	(11)
(12)		CDH74	21	0	0	0	0	0	2	8	11	0	0	0	0	(12)
(13)		CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	9.4	10.5	9.8	9.3	9.7	9.8	8.7	8.7	8.2	8.4	9.0	9.6	10.6	(14)
(15)	Precipitation	PrecAvg	36.3	1.0	1.3	1.7	2.3	3.8	5.1	5.1	5.2	3.8	3.1	2.3	1.7	(15)
(16)		PrecMax	48.6	2.3	3.8	3.7	4.6	7.5	7.8	11.3	9.5	5.8	7.1	5.2	4.3	(16)
(17)		PrecMin	23.8	0.2	0.2	0.2	0.7	1.6	2.5	1.1	1.6	1.3	0.2	0.1	0.1	(17)
(18)		PrecStd	4.6	0.6	1.0	0.9	1.0	1.4	1.5	2.2	1.9	1.1	1.7	1.2	1.0	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.2	49.7	52.1	61.0	67.5	72.5	74.8	75.2	65.5	63.5	55.4	50.4	(19)
(20)			MCWB	37.7	37.7	41.6	50.0	56.0	61.4	63.2	62.5	57.7	49.5	43.7	37.0	(20)
(21)		2%	DB	45.3	45.4	48.6	56.3	62.8	69.5	71.2	71.5	62.2	59.0	52.1	46.5	(21)
(22)			MCWB	36.3	35.7	40.2	47.3	54.5	60.2	62.1	60.5	55.9	49.4	42.3	35.9	(22)
(23)		5%	DB	41.3	42.0	45.7	53.2	59.9	66.8	68.7	68.7	60.0	55.9	49.0	43.4	(23)
(24)			MCWB	35.3	34.5	39.0	45.5	53.1	59.3	60.8	59.8	54.6	48.4	41.7	35.5	(24)
(25)		10%	DB	38.1	38.8	42.9	50.2	57.1	64.0	66.3	66.0	57.6	53.0	46.4	40.8	(25)
(26)			MCWB	33.3	33.2	37.6	43.6	51.2	57.4	59.4	59.0	53.1	47.5	41.3	34.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	40.7	39.3	43.5	51.1	58.3	63.9	66.8	64.8	59.4	53.8	47.1	40.7	(27)
(28)			MCD B	45.3	46.3	48.7	59.0	64.4	69.2	70.9	69.9	63.8	58.9	50.4	43.9	(28)
(29)		2%	WB	37.8	37.1	41.4	48.5	55.8	62.0	63.8	62.6	57.0	51.5	44.9	38.9	(29)
(30)			MCD B	42.4	42.7	46.4	54.5	61.4	67.4	69.0	69.0	60.9	55.8	48.2	43.2	(30)
(31)		5%	WB	36.2	35.5	39.6	46.4	53.8	59.9	61.8	60.9	55.3	49.7	43.3	37.2	(31)
(32)			MCD B	40.3	40.9	44.3	52.2	58.9	65.5	67.3	67.1	58.9	53.6	47.0	41.3	(32)
(33)		10%	WB	33.9	33.7	38.0	44.4	51.6	58.0	60.0	59.3	53.5	48.1	41.8	35.4	(33)
(34)			MCD B	37.7	37.8	42.1	49.1	56.5	63.3	65.5	64.9	56.7	51.7	45.5	40.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.5	8.1	8.9	9.8	10.3	10.2	10.4	9.4	8.3	8.2	7.3	7.7	(35)
(36)			MCD BR	10.7	10.8	11.4	12.4	12.4	12.7	11.5	11.5	10.1	10.2	9.3	10.1	(36)
(37)			MCWBR	6.3	6.6	7.6	8.0	8.6	8.6	8.3	8.2	8.2	7.2	5.7	6.0	(37)
(38)		5% WB	MCD BR	9.2	10.2	10.4	11.6	11.7	11.6	10.7	10.9	9.3	9.2	8.0	9.1	(38)
(39)			MCWBR	6.6	7.2	7.4	7.8	8.8	8.8	8.6	8.6	7.8	7.1	6.0	6.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.255	0.276	0.307	0.341	0.344	0.350	0.352	0.351	0.328	0.308	0.284	0.256	(40)	
(41)		taud	2.494	2.471	2.446	2.390	2.408	2.412	2.398	2.414	2.465	2.517	2.548	2.534	(41)	
(42)		Ebn at Noon	273	288	292	290	292	290	287	283	281	271	259	260	(42)	
(43)		Edh at Noon	20	25	30	35	36	36	36	34	29	24	19	17	(43)	
(44)	All-Sky Solar Radiation	RadAvg	387	659	998	1317	1549	1706	1704	1516	1093	742	414	321	(44)	
(45)		RadStd	45	86	116	141	167	126	143	171	140	74	61	46	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(46)	
(47)	Regional (101 neighbors)	+0.97	N/A	N/A	+1.57	+0.86	+0.72	-191	-252	+162	+97	(47)

Nomenclature: See separate page