

SCHOECKL, Austria

WMO: 112410

Lat: 47.1986N

Lon: 15.4664E

Elev: 1439

StdP: 85.19

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.4	-12.1	-20.1	0.7	-8.9	-17.0	1.0	-8.1	17.7	-7.9	15.7	-7.1	4.4	340	0.680

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.8	21.9	16.3	20.6	15.7	19.3	15.1	17.4	20.4	16.4	19.6	15.5	18.6	3.1	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
16.3	13.8	19.3	15.1	12.8	18.3	14.1	12.0	17.5	55.1	20.4	51.7	19.8	48.7	18.8	22.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.9	12.2	10.0	-15.5	24.4	2.7	1.5	-17.5	25.5	-19.0	26.4	-20.6	27.3	-22.5	28.4		
(5)			-16.0	19.1	2.6	1.1	-17.9	19.9	-19.4	20.5	-20.8	21.1	-22.7	21.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	5.0	-3.5	-2.9	-0.3	4.1	8.2	11.9	13.9	13.5	9.0	5.7	1.7	-1.6		
	DBStd	7.50	4.94	5.07	4.74	4.41	3.90	3.98	3.46	3.58	3.69	4.61	4.80	5.01		
	HDD10.0	2223	419	362	321	181	83	26	7	9	62	146	249	361		
	HDD18.3	4873	677	595	578	426	315	196	141	155	281	393	498	619		
	CDD10.0	403	0	0	0	4	26	82	129	117	32	12	1	0		
	CDD18.3	12	0	0	0	0	0	2	5	5	0	0	0	0		
	CDH23.3	12	0	0	0	0	0	1	4	6	0	0	0	0		
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0		
(14) Wind	WSAvg	4.2	4.7	4.4	4.2	4.3	4.4	3.9	3.9	3.7	3.7	4.0	4.3	4.7		
(15) Precipitation	PrecAvg	922	25	32	44	59	96	130	129	132	96	79	58	44		
	PrecMax	1235	59	97	95	116	191	199	286	242	148	181	131	109		
	PrecMin	604	4	4	5	18	41	63	27	40	32	6	2	3		
	PrecStd	117	14	26	24	25	35	38	55	49	29	44	30	26		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.6	9.8	11.2	16.1	19.7	22.5	23.8	24.0	18.6	17.5	13.0	10.2		
		MCWB	3.1	3.2	5.3	10.0	13.3	16.3	17.3	16.9	14.3	9.7	6.5	2.8		
	2%	DB	7.4	7.5	9.2	13.5	17.1	20.9	21.8	21.9	16.8	15.0	11.2	8.1		
		MCWB	2.4	2.0	4.5	8.5	12.5	15.7	16.7	15.8	13.3	9.7	5.7	2.1		
	5%	DB	5.2	5.6	7.6	11.8	15.5	19.3	20.4	20.4	15.5	13.3	9.4	6.4		
		MCWB	1.8	1.4	3.9	7.5	11.7	15.2	16.0	15.4	12.5	9.1	5.4	1.9		
	10%	DB	3.4	3.8	6.0	10.1	14.0	17.8	19.1	18.9	14.2	11.7	8.0	4.9		
		MCWB	0.7	0.7	3.1	6.4	10.7	14.1	15.2	15.0	11.7	8.6	5.2	1.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.8	4.1	6.4	10.6	14.6	17.7	19.3	18.2	15.2	12.1	8.4	4.8		
		MCDB	7.4	7.9	9.3	15.0	18.0	20.7	21.6	21.1	17.7	15.0	10.2	6.6		
	2%	WB	3.2	2.8	5.2	9.2	13.2	16.7	17.6	17.0	13.9	10.8	7.1	3.8		
		MCDB	5.8	5.9	8.0	12.5	16.3	19.7	20.5	20.6	16.1	13.2	9.0	6.2		
	5%	WB	2.3	2.0	4.2	8.0	12.1	15.5	16.5	16.1	12.9	9.8	6.3	2.9		
		MCDB	4.6	4.9	6.8	11.2	14.9	18.6	19.6	19.5	14.9	12.0	8.3	5.2		
	10%	WB	1.1	0.9	3.3	6.9	10.9	14.4	15.6	15.1	12.0	8.9	5.5	1.9		
		MCDB	3.2	3.2	5.6	9.5	13.6	17.4	18.6	18.3	13.7	10.9	7.5	4.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	4.2	4.5	4.9	5.4	5.7	5.7	5.8	5.2	4.6	4.6	4.1	4.3		
		MCDBR	6.0	6.0	6.4	6.9	6.9	7.1	6.4	6.4	5.6	5.7	5.2	5.6		
		MCWBR	3.5	3.6	4.2	4.5	4.8	4.8	4.6	4.5	4.6	4.0	3.2	3.4		
		MCWBR	5.1	5.7	5.8	6.4	6.5	6.4	5.9	6.1	5.2	5.1	4.5	5.1		
(40) Clear-Sky Solar Irradiance	taub	taub	0.255	0.276	0.307	0.341	0.344	0.350	0.352	0.351	0.328	0.308	0.284	0.256		
		taud	2.494	2.471	2.446	2.390	2.408	2.412	2.398	2.414	2.465	2.517	2.548	2.534		
		Ebn at Noon	861	907	922	914	919	913	905	892	885	855	815	821		
		Edh at Noon	62	79	95	110	113	113	113	107	92	75	59	53		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.22	2.08	3.15	4.15	4.88	5.38	5.37	4.78	3.44	2.34	1.30	1.01		
		RadStd	0.14	0.27	0.37	0.45	0.53	0.40	0.45	0.54	0.44	0.23	0.19	0.15		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (101 neighbors)	+0.54	N/A	N/A	+0.87	+0.48	+0.40	-106	-140	+90	+54

Nomenclature: See separate page