

BAD GLEICHENBERG, Austria

WMO: 112440

Lat: 46.8722N

Lon: 15.9036E

Elev: 890

StdP: 14.23

Time Zone: 1.00 (EUC)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.2	17.8	8.1	8.6	16.8	12.7	10.9	21.0	12.2	34.5	11.3	34.0	2.1	80	0.432

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.8	89.0	71.2	86.1	70.3	83.2	68.9	72.9	85.9	71.3	83.4	69.9	80.9	5.4	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.7	109.0	79.1	67.2	103.5	77.2	65.9	98.7	75.3	37.0	86.1	35.7	83.5	34.4	81.3	77.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.5	9.7	8.5	7.6	93.1	6.5	3.4	2.9	95.5	-0.9	97.5	-4.6	99.4	-9.3	101.9		
			7.1	75.3	6.4	1.3	2.5	76.2	-1.3	77.0	-4.8	77.8	-9.5	78.7		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	51.6	31.7	35.1	43.2	53.2	59.7	67.0	70.3	69.3	60.8	51.4	43.2	33.5	
	DBStd	14.97	7.15	7.57	7.11	6.48	5.82	5.61	5.38	5.39	6.04	6.59	6.95	6.70	
	HDD50	2058	568	418	226	42	4	0	0	0	2	65	221	512	
	HDD65	5370	1033	838	676	355	181	44	17	20	153	423	654	976	
	CDD50	2645	0	0	15	138	303	510	630	599	325	107	17	1	
	CDD65	483	0	0	0	1	16	103	182	154	27	0	0	0	
	CDH74	4642	0	0	0	52	205	1040	1727	1403	204	11	0	0	
	CDH80	1425	0	0	0	4	23	302	590	479	27	0	0	0	
Wind	WSAvg	3.5	3.3	3.4	4.0	4.1	3.9	3.7	3.4	3.3	3.2	3.2	2.9	3.7	
Precipitation	PrecAvg	35.0	1.5	1.3	2.2	2.5	3.4	4.2	5.2	4.6	3.1	2.4	2.9	1.8	
	PrecMax	44.5	3.1	3.5	4.3	6.4	5.6	7.5	12.8	8.2	7.2	7.0	6.7	3.1	
	PrecMin	27.2	0.0	0.2	0.8	0.5	1.3	2.6	2.3	2.1	0.6	0.0	0.7	0.5	
	PrecStd	5.2	0.9	0.9	1.1	1.5	1.5	1.3	2.7	1.9	2.1	1.8	1.5	0.9	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.0	62.2	69.7	79.8	82.8	90.9	92.6	93.2	83.3	75.6	64.7	56.4	
		MCWB	46.3	49.6	54.0	61.3	66.4	72.1	73.2	71.7	68.6	62.1	56.4	50.4	
	2%	DB	49.3	55.2	65.4	74.5	79.1	86.7	89.1	88.8	79.6	70.5	60.3	50.8	
		MCWB	44.5	46.2	52.0	57.8	64.3	70.4	71.5	71.0	66.4	60.3	54.5	46.7	
	5%	DB	44.7	50.7	61.1	70.9	76.0	83.5	86.2	85.2	76.0	66.9	56.6	46.6	
		MCWB	41.4	43.7	49.8	56.2	62.3	68.6	70.4	70.2	64.8	58.6	52.2	42.8	
	10%	DB	41.6	46.4	56.6	67.0	72.6	80.3	83.1	81.9	72.4	62.8	53.0	42.7	
		MCWB	39.0	41.1	47.5	54.6	60.4	66.6	69.0	69.0	62.8	56.4	49.9	39.9	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.9	50.3	54.5	62.0	68.5	74.0	75.0	74.3	69.9	63.8	57.7	50.6
			MCDB	51.9	61.0	67.1	78.1	80.5	87.0	89.9	88.7	81.5	73.7	62.8	54.6
2%		WB	44.8	46.6	52.7	59.5	65.6	71.7	73.0	72.5	67.3	60.9	55.2	47.0	
		MCDB	48.5	53.5	63.7	72.2	76.4	84.0	85.6	85.9	76.7	68.8	59.5	50.7	
5%		WB	41.8	44.3	50.4	57.2	63.5	69.6	71.4	71.1	65.8	59.1	52.7	43.4	
		MCDB	44.3	49.9	59.6	67.8	73.2	81.0	83.5	82.8	74.5	66.1	56.3	46.1	
10%		WB	39.3	41.8	48.1	55.4	61.7	67.7	69.9	69.5	63.8	57.3	50.1	40.4	
		MCDB	41.4	45.8	55.4	65.3	70.5	78.3	80.9	79.9	70.7	61.8	52.6	42.1	
Mean Daily Temperature Range	5% DB	MDBR	11.8	15.1	19.9	21.4	19.6	20.2	20.8	20.6	17.8	17.8	12.4	11.9	
		MCDBR	18.1	24.0	28.6	29.3	26.0	25.9	25.7	25.6	22.9	24.0	19.1	18.0	
		MCWBR	12.7	15.3	16.0	14.0	12.0	10.8	9.9	10.0	10.7	14.0	12.8	13.0	
	5% WB	MCDBR	16.1	22.6	26.6	25.8	23.1	24.5	24.0	24.3	21.8	22.6	17.8	16.8	
		MCWBR	11.9	14.8	15.4	12.5	11.1	10.5	9.7	10.2	10.4	13.7	12.1	12.7	
Clear-Sky Solar Irradiance	taub		0.315	0.339	0.378	0.424	0.421	0.427	0.430	0.432	0.405	0.378	0.346	0.314	
	taud		2.412	2.357	2.284	2.174	2.230	2.255	2.247	2.252	2.299	2.349	2.397	2.447	
	Ebn at Noon		245	261	266	263	268	267	264	258	254	242	228	231	
	Edh at Noon		22	29	36	44	43	42	42	40	35	29	23	19	
All-Sky Solar Radiation	RadAvg		384	646	1010	1373	1650	1818	1808	1600	1140	755	411	307	
	RadStd		48	92	123	144	161	129	134	170	143	80	56	44	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (82 neighbors)	+0.97	N/A	N/A	+1.62	+0.86	+0.74	-191	-256	+162	+103

Nomenclature: See separate page