

BAD RADKERSBURG, Austria

WMO: 112480

Lat: **46.686N**Lon: **15.979E**Elev: **702**StdP: **14.33**Time Zone: **1.00 (EUC)**Period: **94-16**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.4	17.1	8.2	8.6	13.8	13.2	11.0	20.9	12.0	44.7	10.7	45.3	2.5	240	0.420

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.3	87.5	70.9	84.2	69.5	81.1	68.1	72.7	83.2	71.0	81.2	69.4	78.6	3.5	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.5	111.4	76.8	67.7	104.4	75.0	66.2	99.0	73.9	36.8	83.6	35.2	81.0	33.9	78.8	79.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation	n=5 years		n=10 years		n=20 years		n=50 years			
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(4) 10.9	8.9	7.2		7.7	92.4	7.6	3.6	2.2	95.0	-2.2	97.1	-6.4	99.2	-11.9	101.8	
(5)				7.2	74.6	7.0	1.8	2.2	75.9	-1.9	76.9	-5.8	78.0	-10.9	79.3	(p)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	51.4	31.3	35.4	43.0	52.9	60.4	66.2	69.5	68.9	60.1	52.1	42.9	33.3
	DBStd	14.97	7.56	8.03	7.50	6.65	5.67	6.07	5.44	5.49	5.80	6.89	7.87	7.30
	HDD50	2087	580	410	234	47	1	0	0	0	1	60	236	518
	HDD65	5400	1044	829	681	365	163	58	21	23	169	403	662	982
	CDD50	2606	0	1	19	134	325	486	604	585	303	124	24	1
	CDD65	442	0	0	0	1	21	94	160	143	21	2	0	0
	CDH74	3239	0	0	0	18	207	706	1221	979	105	3	0	0
	CDH80	882	0	0	0	1	27	173	362	310	9	0	0	0
Wind	WSAvg	2.9	2.7	3.1	3.4	3.5	3.0	2.8	2.7	2.6	2.4	2.5	2.8	2.6
Precipitation	PrecAvg	35.7	1.4	1.7	2.0	2.4	3.4	4.2	3.9	4.3	4.1	3.1	3.0	2.3
	PrecMax	45.0	4.1	5.2	4.4	5.9	5.8	6.9	6.7	7.9	7.9	8.5	7.5	4.6
	PrecMin	24.7	0.3	0.1	0.3	0.3	1.5	1.4	1.1	0.7	1.9	0.0	0.3	0.3
	PrecStd	4.9	0.9	1.3	1.1	1.3	1.4	1.4	1.5	1.9	1.8	2.0	1.7	1.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.1	60.0	68.5	76.7	83.4	89.0	91.3	91.8	80.8	73.8	66.2	57.2
		MCWB	46.9	49.3	53.2	59.8	66.4	71.3	72.1	71.6	66.6	62.9	56.7	52.1
	2%	DB	50.7	54.5	63.9	72.2	79.3	84.8	87.3	87.7	76.9	69.7	61.8	51.5
		MCWB	45.5	46.5	51.5	57.3	64.1	69.7	71.3	71.0	65.7	61.0	54.8	47.1
	5%	DB	46.5	51.0	59.9	68.7	75.9	81.2	83.9	83.5	73.7	66.5	58.5	46.3
		MCWB	42.4	44.1	50.0	56.0	62.7	68.2	69.5	69.7	64.4	59.2	53.0	43.1
	10%	DB	41.9	47.5	55.8	65.4	72.6	78.0	80.8	79.7	70.3	62.9	55.0	42.6
		MCWB	38.8	42.1	47.6	54.3	60.8	66.2	68.2	68.1	62.4	57.2	51.3	40.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.3	50.1	54.4	61.1	68.0	72.8	75.1	75.8	69.4	64.3	58.0	52.1
		MCDB	52.7	58.4	65.3	72.5	79.3	84.9	85.6	84.5	77.6	72.2	63.8	57.1
	2%	WB	45.8	47.1	52.5	58.9	65.6	70.9	72.8	72.8	67.1	61.8	55.5	47.1
		MCDB	50.3	53.3	62.2	69.6	76.4	81.8	83.2	82.9	74.4	68.3	60.9	51.2
	5%	WB	42.6	44.6	50.5	57.0	63.6	69.2	71.0	70.8	65.3	59.8	53.5	43.6
		MCDB	46.6	49.8	58.5	65.9	73.5	79.0	81.2	80.7	72.1	65.2	57.9	45.7
	10%	WB	39.2	42.4	48.4	55.3	61.8	67.4	69.4	69.1	63.4	57.9	51.2	40.9
		MCDB	41.2	46.4	55.1	62.9	70.5	76.0	78.4	77.8	69.0	62.3	54.9	42.5
Mean Daily Temperature Range	5% DB	MDBR	10.7	14.4	17.1	18.2	18.1	17.4	18.3	17.5	15.0	14.5	11.1	9.0
		MCDBR	17.3	20.4	24.4	24.3	24.4	22.3	23.1	23.4	19.2	18.8	17.5	15.9
		MCWBR	11.8	12.4	13.3	10.7	10.2	8.9	8.6	8.7	9.4	11.1	11.2	11.8
	5% WB	MCDBR	16.5	18.7	22.8	21.1	22.1	21.4	21.2	21.9	17.7	17.0	15.4	14.7
		MCWBR	11.6	12.1	12.8	9.6	9.9	9.0	8.8	9.0	9.2	10.5	10.0	11.4
Clear-Sky Solar Irradiance	taub	0.321	0.346	0.385	0.432	0.427	0.433	0.435	0.438	0.413	0.386	0.353	0.321	
	taud	2.392	2.334	2.261	2.150	2.214	2.242	2.235	2.238	2.279	2.329	2.375	2.427	
	Ebn at Noon	242	258	264	261	267	265	263	256	252	239	226	228	
	Edh at Noon	23	30	37	45	43	43	43	41	36	30	23	20	
All-Sky Solar Radiation	RadAvg	388	646	1017	1384	1678	1850	1841	1627	1154	763	414	307	
	RadStd	51	94	126	146	157	130	131	172	146	83	57	46	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
Regional (77 neighbors)	+0.97	N/A	N/A	+1.64	+0.90	+0.79	-194	-272	+171	+108