

KOETSCHACH-MAUTHEN, Austria

WMO: 112550

Lat: 46.677N

Lon: 12.997E

Elev: 2336

StdP: 13.50

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.3	15.5	5.3	7.9	19.0	8.5	9.3	21.6	9.6	41.6	6.8	37.3	1.0	310	0.478

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.6	84.2	67.0	81.0	65.6	78.2	64.1	68.4	81.0	66.7	78.2	65.2	75.6	4.9	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
64.2	98.0	72.8	62.6	92.7	70.9	61.3	88.5	69.4	34.0	80.8	32.6	78.4	31.4	75.7	74.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.7	7.4	5.6	8.2	89.8	4.9	3.5	4.7	92.3	1.9	94.4	-0.8	96.3	-4.3	98.9		
(5)			7.6	71.0	4.6	1.4	4.2	72.0	1.5	72.8	-1.1	73.6	-4.5	74.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	48.0	29.3	32.8	40.2	47.9	55.8	62.6	66.2	64.9	57.0	48.9	38.9	30.8		
	DBStd	14.36	6.65	6.67	6.96	6.46	5.85	6.20	5.28	5.57	5.81	6.47	7.01	6.54		
	HDD50	2600	641	483	307	113	15	1	0	0	10	98	336	596		
	HDD65	6405	1106	903	767	513	289	118	50	71	245	498	784	1061		
	CDD50	1877	0	0	4	50	195	378	502	461	220	65	2	0		
	CDD65	209	0	0	0	0	4	45	87	67	6	0	0	0		
	CDH74	1762	0	0	0	5	74	436	702	508	37	0	0	0		
	CDH80	384	0	0	0	0	8	91	158	126	1	0	0	0		
(14) Wind	WSAvg	2.0	1.5	1.9	2.2	2.5	2.6	2.5	2.4	2.2	1.8	1.7	1.5	1.3		
(15) Precipitation	PrecAvg	53.0	2.6	2.4	3.1	3.9	4.8	5.4	5.4	5.2	4.6	6.2	6.3	3.0		
	PrecMax	77.9	13.3	11.9	6.7	9.8	11.0	9.2	11.2	8.5	10.2	19.7	21.2	8.8		
	PrecMin	40.1	0.1	0.2	0.5	1.4	1.5	2.6	1.4	2.6	0.7	0.0	0.0	0.3		
	PrecStd	9.7	2.6	2.4	1.7	1.9	2.0	1.9	2.0	1.6	2.2	4.6	5.6	2.2		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.2	55.2	65.5	72.7	81.0	86.6	88.2	88.8	78.1	69.9	58.1	48.4		
		MCWB	42.7	44.5	50.2	56.3	63.3	67.2	69.1	69.0	64.2	58.7	49.7	41.3		
	2%	DB	44.1	49.5	60.7	67.9	75.6	82.6	84.2	83.2	74.3	65.6	53.6	44.6		
		MCWB	37.9	40.7	48.5	54.1	60.3	65.7	67.2	66.9	62.2	56.0	48.0	40.3		
	5%	DB	40.6	45.4	56.3	64.1	71.8	79.2	80.9	79.6	70.7	62.3	50.7	41.3		
		MCWB	36.0	38.3	46.0	51.7	58.2	64.2	65.9	65.5	60.0	54.1	47.3	37.7		
	10%	DB	37.8	41.8	51.9	60.7	68.4	75.6	77.9	75.9	67.5	58.9	48.3	38.5		
		MCWB	34.5	36.5	43.4	49.8	56.5	62.4	64.1	63.6	58.4	52.8	45.8	35.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	42.9	44.9	51.5	57.4	64.1	69.2	70.7	70.9	65.4	59.7	51.7	44.2		
		MCDB	50.1	53.9	63.5	70.0	78.2	83.2	84.3	86.1	75.1	67.9	54.7	46.0		
	2%	WB	39.3	41.4	48.9	54.8	61.4	67.0	68.5	68.2	63.1	57.4	49.8	40.9		
		MCDB	42.9	47.6	59.6	66.3	73.4	79.6	80.9	80.6	71.9	63.6	52.1	43.3		
	5%	WB	37.0	39.0	46.6	52.6	59.2	65.2	66.8	66.3	61.5	55.5	47.9	38.3		
		MCDB	39.7	44.3	55.0	62.2	69.6	76.8	78.1	77.1	68.7	60.3	50.3	40.6		
	10%	WB	35.0	37.0	44.2	50.6	57.3	63.3	65.3	64.6	59.7	53.6	46.1	36.2		
		MCDB	37.1	41.0	50.8	58.8	66.3	73.5	75.5	74.0	65.4	58.1	48.2	38.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	11.4	14.3	18.1	18.5	19.4	19.6	20.6	18.9	17.4	15.2	11.1	10.7		
		MCDBR	15.1	20.0	25.7	25.6	25.9	25.8	24.6	24.5	21.3	19.9	15.0	14.2		
	5% WB	MCWBR	10.2	12.5	14.5	12.7	11.9	10.8	9.8	10.1	10.0	10.7	9.5	9.8		
		MCWBR	13.1	18.0	24.6	23.5	23.6	24.0	22.7	22.4	19.1	17.5	12.2	12.7		
(40) Clear-Sky Solar Irradiance	taub		0.283	0.314	0.368	0.421	0.435	0.447	0.439	0.432	0.395	0.368	0.325	0.287		
		taud	2.354	2.277	2.197	2.136	2.158	2.178	2.210	2.244	2.321	2.361	2.422	2.428		
	Ebn at Noon		257	269	269	264	264	261	261	258	258	247	239	244		
		Edh at Noon	23	31	39	45	46	45	43	40	34	28	22	19		
(44) All-Sky Solar Radiation	RadAvg		462	735	1085	1340	1562	1753	1790	1568	1172	783	455	391		
	RadStd		51	98	133	178	192	146	137	158	138	93	84	54		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (76 neighbors)		+0.77	N/A	N/A	+1.21	+0.77	+0.61	N/A	-214	+140	+81

Nomenclature: See separate page