

DELLACH IM DRAUTAL, Austria

WMO: 112700

Lat: 46.742N

Lon: 13.083E

Elev: 627

StdP: 94.01

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-13.3	-11.3	-14.9	1.1	-11.2	-13.2	1.3	-8.9	7.0	3.4	5.6	3.5	0.6	20	0.474

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.3	30.2	20.5	28.4	19.7	26.7	18.8	21.2	28.7	20.3	27.0	19.4	25.3	1.6	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.8	14.7	24.2	18.0	13.9	23.2	17.2	13.3	21.9	64.6	28.8	61.2	27.1	58.1	25.5	24.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 4.8	3.5	2.7	DB	-15.2	33.5	2.8	2.2	-17.2	35.0	-18.8	36.3	-20.3	37.5	-22.4	39.1	(4)
(5)			WB	-15.4	23.0	2.6	0.9	-17.3	23.6	-18.9	24.1	-20.3	24.6	-22.3	25.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.9	-3.2	0.3	5.0	9.7	14.1	17.8	19.5	19.0	14.3	9.5	3.2	-2.6	(6)	
	DBStd	8.64	3.89	3.46	3.61	3.49	3.16	3.42	2.97	3.04	3.12	3.41	3.81	3.80	(7)	
	HDD10.0	1538	408	272	158	47	4	0	0	0	4	51	204	391	(8)	
	HDD18.3	3581	667	506	413	258	135	51	22	29	126	272	454	649	(9)	
	CDD10.0	1152	0	0	3	38	132	234	296	279	132	36	1	0	(10)	
	CDD18.3	152	0	0	0	0	4	35	59	50	4	0	0	0	(11)	
	CDH23.3	1379	0	0	0	7	81	349	513	394	34	0	0	0	(12)	
	CDH26.7	381	0	0	0	1	14	99	151	113	3	0	0	0	(13)	
(14) Wind	WSAvg	0.9	0.9	0.9	1.0	1.1	1.1	1.1	1.1	1.0	0.9	0.8	0.7	0.7	(14)	
(15) Precipitation	PrecAvg	1073	40	44	50	78	99	123	104	126	111	96	133	69	(15)	
	PrecMax	1466	72	96	122	175	229	229	148	404	315	372	261	210	(16)	
	PrecMin	731	0	1	3	11	37	57	24	22	18	0	9	6	(17)	
	PrecStd	194	25	33	37	44	52	44	35	89	90	100	90	58	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.8	12.9	19.8	24.1	28.7	31.5	32.8	32.9	26.8	21.6	13.3	7.6	(19)	
		MCWB	4.7	7.5	11.0	14.6	18.7	21.0	21.9	21.7	19.0	15.5	9.8	4.5	(20)	
	2%	DB	4.8	9.5	16.8	21.5	25.5	29.4	30.2	29.6	24.0	18.7	11.2	5.1	(21)	
		MCWB	2.2	4.8	9.7	13.3	16.5	19.8	20.6	20.5	17.5	13.9	9.4	3.6	(22)	
	5%	DB	3.1	7.3	14.4	19.4	23.4	27.5	28.2	27.4	22.0	17.0	10.0	3.3	(23)	
		MCWB	1.4	3.5	8.5	12.0	15.4	18.9	19.8	19.6	16.2	13.0	8.8	2.3	(24)	
	10%	DB	1.7	5.2	11.8	17.1	21.2	25.1	26.3	25.4	20.1	15.0	8.7	2.0	(25)	
		MCWB	0.7	2.4	7.0	10.9	14.3	17.8	18.9	18.7	15.3	12.0	7.6	1.2	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.2	7.8	11.7	15.2	19.0	22.1	22.6	22.5	19.3	16.1	11.0	5.9	(27)	
		MCDB	7.9	12.4	18.6	23.4	27.0	29.9	30.7	30.9	25.3	20.4	11.9	6.6	(28)	
	2%	WB	3.1	5.3	10.1	13.8	17.2	20.6	21.4	21.0	18.1	14.7	9.9	3.9	(29)	
		MCDB	4.6	8.7	16.2	20.5	24.0	27.9	28.7	28.4	22.7	17.9	10.8	4.6	(30)	
	5%	WB	1.8	3.9	8.7	12.5	16.0	19.5	20.4	20.1	17.1	13.6	8.9	2.5	(31)	
		MCDB	2.6	6.6	13.6	18.1	22.0	26.0	26.9	26.4	20.5	16.0	9.8	3.2	(32)	
	10%	WB	0.8	2.8	7.5	11.4	14.9	18.4	19.4	19.1	16.1	12.6	7.7	1.4	(33)	
		MCDB	1.5	4.7	11.2	16.1	19.9	24.0	25.1	24.4	19.1	14.7	8.6	1.9	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	6.8	9.3	11.8	11.8	11.9	12.0	12.3	11.5	10.6	9.4	6.2	5.3	(35)	
		MCDBR	8.0	12.8	16.6	16.5	16.1	16.0	15.3	15.1	13.3	12.4	8.1	6.2	(36)	
	5% WB	MCWBR	5.9	8.2	9.6	8.4	7.3	6.8	6.4	6.4	6.9	7.6	5.7	4.7	(37)	
		MCWBR	6.7	11.6	15.7	15.1	14.8	14.8	14.5	14.1	11.6	10.8	6.3	5.3	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.281	0.312	0.364	0.416	0.431	0.443	0.436	0.430	0.392	0.364	0.323	0.286	(40)	
		taud	2.362	2.286	2.214	2.158	2.180	2.201	2.227	2.262	2.340	2.383	2.438	2.437	(41)	
	Ebn at Noon	Ebn at Noon	814	852	851	837	836	827	827	816	816	782	756	770	(42)	
		Edh at Noon	72	96	120	140	142	140	135	125	106	88	68	61	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.44	2.31	3.40	4.21	4.90	5.50	5.61	4.92	3.67	2.46	1.43	1.22	(44)	
	RadStd	RadStd	0.16	0.31	0.42	0.56	0.60	0.47	0.44	0.50	0.44	0.29	0.26	0.17	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (80 neighbors)	+0.43	N/A	N/A	+0.67	+0.42	+0.34	N/A	-119	+78	+45

Nomenclature: See separate page