

ARRIACH, Austria

WMO: 112750

Lat: 46.728N

Lon: 13.852E

Elev: 2927

StdP: 13.21

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.9	15.5	4.3	7.6	18.3	7.2	8.9	19.8	16.6	39.3	14.1	36.8	4.4	70	0.547

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.2	80.4	65.2	77.3	64.1	74.4	62.8	67.0	77.4	65.3	74.9	63.8	72.4	7.8	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.2	96.8	71.9	61.7	91.7	70.0	60.3	87.2	68.3	33.2	77.8	31.8	75.1	30.6	72.7	73.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.2	11.9	10.1	DB	8.9	85.7	5.0	3.6	5.3	88.3	2.3	90.3	-0.5	92.3	-4.2	94.9	(4)
(5)			WB	7.4	70.1	5.0	1.8	3.8	71.4	0.8	72.5	-2.0	73.5	-5.7	74.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	46.2	28.8	31.6	38.6	45.6	53.8	59.9	63.3	62.5	54.4	47.0	38.0	30.5	(6)
(7)		DBStd	13.81	6.99	7.53	7.33	6.81	6.08	6.56	5.68	5.74	5.84	6.83	7.11	6.87	(7)
(8)		HDD50	2855	657	516	356	164	30	4	0	2	23	137	362	604	(8)
(9)		HDD65	6958	1122	936	819	583	348	178	101	117	318	557	810	1069	(9)
(10)		CDD50	1484	0	0	2	30	149	301	411	388	156	45	2	0	(10)
(11)		CDD65	113	0	0	0	0	2	25	47	38	1	0	0	0	(11)
(12)		CDH74	716	0	0	0	0	18	181	297	217	3	0	0	0	(12)
(13)		CDH80	107	0	0	0	0	0	23	46	38	0	0	0	0	(13)
(14)	Wind	WSAvg	4.8	4.0	4.6	5.5	5.5	5.3	5.2	5.1	4.9	4.7	3.8	3.7	(14)	
(15)	Precipitation	PrecAvg	50.6	2.0	2.0	2.8	3.5	4.1	5.2	5.9	5.8	5.4	5.5	5.5	3.0	(15)
(16)		PrecMax	66.6	8.7	9.1	6.7	5.9	7.8	8.9	11.6	8.7	9.3	13.5	18.0	9.2	(16)
(17)		PrecMin	39.1	0.1	0.0	0.1	0.8	1.5	1.9	1.8	2.2	2.2	0.0	0.6	0.4	(17)
(18)		PrecStd	7.3	1.7	2.0	1.7	1.5	1.4	1.7	2.0	1.9	2.0	3.0	3.8	2.0	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.8	53.4	61.7	69.0	76.8	82.9	84.9	84.6	73.5	66.8	56.9	48.0	(19)
(20)			MCWB	41.1	43.0	48.3	54.8	60.9	65.3	67.2	67.0	62.3	58.2	49.1	42.3	(20)
(21)		2%	DB	44.4	47.7	57.2	64.2	71.9	79.0	80.4	79.5	70.1	62.6	52.7	44.3	(21)
(22)			MCWB	39.2	40.2	46.7	51.6	58.2	64.0	65.8	65.6	61.0	54.7	47.5	39.7	(22)
(23)		5%	DB	40.4	44.2	52.9	60.6	68.7	75.6	77.1	75.8	66.7	59.3	49.7	41.5	(23)
(24)			MCWB	36.4	37.7	44.3	49.5	56.4	62.4	64.4	64.5	59.2	53.7	46.3	37.9	(24)
(25)		10%	DB	37.8	41.3	49.2	56.8	65.3	71.9	74.0	72.3	63.5	56.3	47.2	38.7	(25)
(26)			MCWB	34.7	36.0	42.2	48.2	55.1	60.8	63.2	63.0	57.4	52.0	44.8	35.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	43.0	44.0	49.6	55.8	62.3	67.3	69.7	69.2	64.3	58.8	50.7	44.0	(27)
(28)			MCD B	47.5	51.8	59.4	67.0	72.7	78.5	78.9	80.5	71.3	64.6	54.0	46.3	(28)
(29)		2%	WB	39.6	40.8	46.9	53.0	59.7	65.2	67.2	66.9	61.9	56.3	48.7	40.8	(29)
(30)			MCD B	43.4	46.5	56.0	61.5	69.3	76.3	77.8	76.7	68.2	61.2	51.5	43.1	(30)
(31)		5%	WB	37.4	38.3	44.8	50.8	57.7	63.4	65.4	65.2	59.9	54.3	46.9	38.4	(31)
(32)			MCD B	39.8	43.1	51.8	58.3	66.4	73.3	75.0	74.1	65.3	58.3	49.3	40.9	(32)
(33)		10%	WB	35.2	36.5	42.7	48.9	55.9	61.6	63.8	63.5	58.1	52.5	45.0	36.0	(33)
(34)			MCD B	37.4	40.4	48.2	55.6	63.5	70.3	72.3	71.3	62.7	55.9	47.0	38.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.8	11.5	14.8	15.2	16.3	16.8	17.2	16.1	14.0	12.1	8.6	8.3	(35)
(36)			MCDBR	12.0	16.2	20.7	21.1	21.6	22.3	21.3	20.8	17.4	16.0	11.6	11.0	(36)
(37)			MCWBR	8.4	10.5	12.1	10.7	10.3	10.1	9.8	9.9	9.6	10.0	8.1	8.0	(37)
(38)		5% WB	MCD BR	10.5	14.8	19.4	18.7	19.9	20.8	19.6	19.6	15.9	14.6	10.0	10.1	(38)
(39)			MCWBR	7.9	10.0	11.7	10.0	10.2	10.1	9.9	10.2	9.4	9.6	7.5	7.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.273	0.301	0.346	0.391	0.401	0.410	0.407	0.401	0.371	0.347	0.312	0.276	(40)	
(41)		taud	2.415	2.356	2.310	2.247	2.270	2.288	2.297	2.330	2.393	2.440	2.484	2.477	(41)	
(42)		Ebn at Noon	264	276	278	273	274	272	271	268	266	256	246	251	(42)	
(43)		Edh at Noon	22	28	35	41	41	41	40	37	32	26	21	18	(43)	
(44)	All-Sky Solar Radiation	RadAvg	438	709	1061	1336	1575	1761	1785	1569	1154	771	440	366	(44)	
(45)		RadStd	52	97	131	167	180	139	136	164	142	89	76	52	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (91 neighbors)		+0.86	N/A	N/A	+1.30	+0.81	+0.63	N/A	-221	+151	+94

Nomenclature: See separate page