

ARRIACH, Austria

WMO: 112750

Lat: 46.728N

Lon: 13.852E

Elev: 892

StdP: 91.05

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.2	-9.2	-15.4	1.1	-7.6	-13.8	1.3	-6.8	7.4	4.0	6.3	2.7	2.0	70	0.547

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.5	26.9	18.4	25.2	17.9	23.5	17.1	19.4	25.2	18.5	23.8	17.7	22.4	3.5	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.3	13.8	22.2	16.5	13.1	21.1	15.7	12.5	20.2	59.3	25.4	56.2	23.9	53.3	22.6	23.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
6.3	5.3	4.5	-12.8	29.8	2.8	2.0	-14.9	31.3	-16.5	32.4	-18.1	33.5	-20.1	35.0		
			-13.7	21.2	2.8	1.0	-15.7	21.9	-17.3	22.5	-18.9	23.1	-20.9	23.8		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.9	-1.8	-0.2	3.7	7.5	12.1	15.5	17.4	16.9	12.5	8.4	3.3	-0.8
	DBStd	7.67	3.88	4.18	4.07	3.78	3.38	3.65	3.16	3.19	3.24	3.79	3.95	3.82
	HDD10.0	1586	365	287	198	91	17	2	0	1	13	76	201	336
	HDD18.3	3866	623	520	455	324	193	99	56	65	177	309	450	594
	CDD10.0	824	0	0	1	17	83	167	228	216	87	25	1	0
	CDD18.3	63	0	0	0	0	1	14	26	21	1	0	0	0
	CDH23.3	398	0	0	0	0	10	101	165	121	2	0	0	0
	CDH26.7	59	0	0	0	0	0	13	26	21	0	0	0	0
(14) Wind	WSAvg	2.1	1.8	2.0	2.5	2.5	2.4	2.3	2.3	2.3	2.2	2.1	1.7	1.7
(15) Precipitation	PrecAvg	1285	51	52	70	89	104	132	150	147	136	140	139	76
	PrecMax	1691	221	232	169	149	199	227	295	221	236	342	458	234
	PrecMin	994	2	0	3	20	37	49	45	56	56	0	15	10
	PrecStd	185	44	52	43	38	36	44	52	48	50	77	96	52
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.9	11.9	16.5	20.6	24.9	28.3	29.4	29.2	23.0	19.3	13.8	8.9
		MCWB	5.0	6.1	9.0	12.6	16.0	18.5	19.5	19.5	16.8	14.5	9.5	5.7
	2%	DB	6.9	8.7	14.0	17.9	22.2	26.1	26.9	26.4	21.2	17.0	11.5	6.8
		MCWB	4.0	4.5	8.2	10.9	14.6	17.8	18.8	18.7	16.1	12.6	8.6	4.3
	5%	DB	4.7	6.8	11.6	15.9	20.4	24.2	25.1	24.3	19.3	15.2	9.8	5.3
		MCWB	2.5	3.1	6.8	9.7	13.5	16.9	18.0	18.1	15.1	12.1	8.0	3.3
	10%	DB	3.2	5.1	9.5	13.8	18.5	22.2	23.3	22.4	17.5	13.5	8.4	3.7
		MCWB	1.5	2.2	5.7	9.0	12.8	16.0	17.3	17.2	14.1	11.1	7.1	1.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.1	6.7	9.8	13.2	16.9	19.6	20.9	20.7	17.9	14.9	10.4	6.7
		MCDB	8.6	11.0	15.2	19.4	22.6	25.9	26.1	26.9	21.8	18.1	12.2	7.9
	2%	WB	4.2	4.9	8.3	11.7	15.4	18.5	19.5	19.4	16.6	13.5	9.3	4.9
		MCDB	6.3	8.1	13.3	16.4	20.7	24.6	25.5	24.8	20.1	16.2	10.8	6.2
	5%	WB	3.0	3.5	7.1	10.4	14.3	17.4	18.6	18.4	15.5	12.4	8.3	3.6
		MCDB	4.3	6.2	11.0	14.6	19.1	22.9	23.9	23.4	18.5	14.6	9.6	4.9
	10%	WB	1.8	2.5	6.0	9.4	13.3	16.5	17.7	17.5	14.5	11.4	7.2	2.2
		MCDB	3.0	4.7	9.0	13.1	17.5	21.3	22.4	21.8	17.0	13.3	8.3	3.3
(35) Mean Daily Temperature Range	5% DB	MDBR	4.9	6.4	8.2	8.4	9.0	9.4	9.5	8.9	7.8	6.7	4.8	4.6
		MCDBR	6.6	9.0	11.5	11.7	12.0	12.4	11.8	11.6	9.7	8.9	6.5	6.1
	5% WB	MCWBR	4.6	5.8	6.7	5.9	5.7	5.6	5.5	5.5	5.3	5.6	4.5	4.5
		MCWBR	5.9	8.2	10.8	10.4	11.0	11.6	10.9	10.9	8.8	8.1	5.6	5.6
(40) Clear-Sky Solar Irradiance	taub		0.273	0.301	0.346	0.391	0.401	0.410	0.407	0.401	0.371	0.347	0.312	0.276
		taud	2.415	2.356	2.310	2.247	2.270	2.288	2.297	2.330	2.393	2.440	2.484	2.477
	Ebn at Noon		832	871	875	862	865	857	854	844	839	807	776	790
		Edh at Noon	68	89	109	128	130	128	126	117	100	83	65	58
(44) All-Sky Solar Radiation	RadAvg		1.38	2.23	3.34	4.21	4.97	5.55	5.63	4.95	3.64	2.43	1.39	1.16
	RadStd		0.16	0.31	0.41	0.53	0.57	0.44	0.43	0.52	0.45	0.28	0.24	0.16

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (91 neighbors)	+0.48	N/A	N/A	+0.72	+0.45	+0.35	N/A	-123	+84	+52

Nomenclature: See separate page