

MURAU, Austria

WMO: 112800

Lat: 47.111N

Lon: 14.177E

Elev: 814

StdP: 91.92

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-13.6	-11.5	-16.1	1.0	-12.2	-14.2	1.2	-9.7	5.1	-0.3	4.4	-0.2	1.0	290	0.526

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.1	29.2	19.0	27.4	18.2	25.6	17.5	19.8	27.4	18.9	25.8	18.0	24.3	2.9	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.3	13.6	22.7	16.4	12.9	21.6	15.6	12.2	20.7	60.3	27.6	57.0	25.9	54.0	24.5	25.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.0	4.3	3.8	DB	-15.8	31.9	3.4	1.7	-18.3	33.1	-20.3	34.1	-22.2	35.1	-24.6	36.4	(4)
(5)			WB	-16.1	21.7	3.2	1.2	-18.4	22.6	-20.3	23.3	-22.1	23.9	-24.4	24.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.0	-2.8	-0.2	3.8	8.0	12.5	16.2	17.9	17.5	12.9	8.7	3.2	-1.8	(6)	
	DBStd	8.00	3.76	3.72	3.73	3.49	3.21	3.50	3.10	3.02	3.22	3.42	3.72	3.65	(7)	
	HDD10.0	1614	398	286	192	77	12	1	0	1	11	66	206	364	(8)	
	HDD18.3	3837	657	519	450	310	182	82	46	51	164	299	455	623	(9)	
	CDD10.0	897	0	0	1	18	90	187	245	234	98	24	1	0	(10)	
	CDD18.3	78	0	0	0	0	1	17	32	26	1	0	0	0	(11)	
	CDH23.3	947	0	0	0	3	43	239	356	285	21	0	0	0	(12)	
	CDH26.7	224	0	0	0	0	5	54	92	72	1	0	0	0	(13)	
(14) Wind	WSAvg	1.5	1.3	1.5	1.6	1.7	1.7	1.7	1.6	1.5	1.4	1.4	1.2	1.1	(14)	
(15) Precipitation	PrecAvg	982	34	35	48	59	91	130	146	137	93	88	75	45	(15)	
	PrecMax	1181	66	112	114	92	128	172	292	230	135	223	184	113	(16)	
	PrecMin	827	9	4	10	14	42	76	38	77	47	4	3	9	(17)	
	PrecStd	107	17	25	22	18	23	28	53	43	24	46	43	23	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.5	13.6	18.5	23.2	27.2	30.4	31.7	31.2	25.9	21.3	15.0	7.7	(19)	
		MCWB	4.5	7.0	9.9	13.6	17.2	18.9	19.9	19.7	17.8	14.8	10.3	4.1	(20)	
	2%	DB	5.2	9.4	15.8	20.2	24.3	28.3	29.1	28.8	23.2	18.7	12.0	5.4	(21)	
		MCWB	2.8	4.7	8.6	11.9	15.6	18.0	19.3	19.1	16.3	13.0	8.6	3.2	(22)	
	5%	DB	3.4	7.1	13.3	18.0	22.2	26.3	27.1	26.6	21.3	16.6	10.0	3.9	(23)	
		MCWB	1.4	3.1	7.4	10.9	14.3	17.3	18.2	18.3	15.2	11.9	7.8	2.3	(24)	
	10%	DB	2.0	5.1	10.6	15.7	20.0	24.1	25.1	24.4	19.2	14.4	8.3	2.6	(25)	
		MCWB	0.5	2.1	5.9	9.6	13.2	16.6	17.6	17.4	14.3	10.8	6.6	1.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.9	7.3	10.5	14.0	18.3	20.6	21.2	21.0	18.2	15.2	10.9	5.2	(27)	
		MCDB	7.3	12.7	17.2	21.9	24.5	26.8	29.2	29.4	24.5	20.1	13.6	6.6	(28)	
	2%	WB	3.1	5.0	8.9	12.4	16.1	19.0	20.0	19.6	17.0	13.7	9.2	3.6	(29)	
		MCDB	4.8	8.8	14.9	18.8	23.2	26.3	27.7	27.0	22.3	17.5	11.3	4.8	(30)	
	5%	WB	1.8	3.5	7.7	11.2	14.9	17.9	18.9	18.7	15.8	12.4	8.1	2.5	(31)	
		MCDB	3.0	6.4	12.8	16.9	21.2	24.9	25.8	25.3	20.0	15.6	9.8	3.6	(32)	
	10%	WB	0.7	2.3	6.3	10.0	13.7	16.9	17.9	17.7	14.7	11.3	6.8	1.5	(33)	
		MCDB	1.7	4.7	10.1	15.0	18.9	22.9	24.0	23.4	18.2	14.0	8.0	2.4	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	7.8	9.8	11.3	11.6	11.9	12.0	12.1	11.9	11.0	10.5	7.3	7.1	(35)	
		MCDBR	8.6	12.9	16.4	16.6	16.3	16.4	15.9	15.7	14.5	13.7	9.8	8.0	(36)	
	5% WB	MCWBR	6.2	8.3	9.6	8.9	8.1	7.3	6.9	7.1	7.8	8.3	6.5	5.9	(37)	
		MCWBR	7.8	11.8	15.3	15.0	15.3	14.9	14.6	14.4	12.7	12.5	8.7	7.1	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.278	0.309	0.355	0.401	0.412	0.418	0.418	0.411	0.377	0.348	0.315	0.280	(40)	
		taud	2.394	2.321	2.269	2.213	2.237	2.265	2.266	2.303	2.372	2.427	2.461	2.452	(41)	
	Edn at Noon	Edn at Noon	816	855	861	851	854	849	842	832	830	801	764	775	(42)	
		Edh at Noon	69	92	113	132	134	131	129	120	102	83	66	59	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.27	2.14	3.21	4.16	4.87	5.39	5.42	4.81	3.49	2.37	1.33	1.05	(44)	
	RadStd	RadStd	0.15	0.28	0.38	0.48	0.54	0.43	0.46	0.54	0.45	0.25	0.21	0.15	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (98 neighbors)	N/A	N/A	N/A	+0.83	+0.49	+0.39	-92	-137	+92	+55

Nomenclature: See separate page