

LASSNITZHOEHE, Austria

WMO: 112920

Lat: 47.074N

Lon: 15.592E

Elev: 1737

StdP: 13.80

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.2	17.6	7.5	8.6	18.4	11.3	10.4	22.6	11.2	37.8	9.6	35.7	2.9	240	0.426

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.5	84.5	70.1	81.6	68.8	78.9	67.3	71.6	81.8	69.9	79.8	68.3	77.3	3.4	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.1	110.2	77.0	66.4	103.7	75.8	64.8	98.0	73.8	36.4	82.1	35.0	80.1	33.6	77.6	76.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.5	7.8	7.1	10.5	89.2	4.4	3.5	7.4	91.7	4.8	93.8	2.3	95.7	-1.0	98.3
			9.8	74.1	4.3	1.5	6.7	75.2	4.2	76.1	1.7	76.9	-1.4	78.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	50.3	31.0	35.1	42.3	51.1	58.6	64.9	67.9	67.2	58.9	50.9	41.5	33.0
	DBStd	14.70	7.87	8.27	8.27	7.47	6.38	6.44	5.75	5.82	6.05	7.01	7.45	7.29
	HDD50	2228	588	421	261	76	6	0	0	0	4	76	268	528
	HDD65	5724	1053	839	705	418	216	81	37	43	199	436	705	992
	CDD50	2326	0	2	22	109	272	446	555	532	270	105	13	0
	CDD65	348	0	0	0	1	17	77	128	110	15	0	0	0
	CDH74	2084	0	0	0	9	90	475	807	656	47	0	0	0
	CDH80	431	0	0	0	0	9	95	172	153	2	0	0	0
Wind	WSAvg	3.3	3.3	3.5	3.7	3.8	3.5	3.3	3.4	3.1	3.0	3.0	3.1	3.3
Precipitation	PrecAvg	34.6	0.9	1.2	1.6	2.2	3.7	5.0	4.6	5.0	3.6	3.0	2.2	1.7
	PrecMax	47.8	2.4	3.9	3.4	3.9	7.3	8.6	9.2	9.1	6.0	6.5	5.1	3.7
	PrecMin	22.7	0.2	0.1	0.2	0.5	1.5	2.2	1.0	1.5	1.0	0.2	0.1	0.2
	PrecStd	4.7	0.6	1.1	0.9	0.9	1.3	1.7	1.9	1.8	1.2	1.6	1.2	0.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.7	59.7	66.4	75.2	80.9	86.7	88.0	88.1	78.3	71.1	63.4	53.4
		MCWB	45.2	48.0	52.5	59.7	65.8	70.0	71.9	71.1	66.8	60.4	53.9	46.5
	2%	DB	48.6	53.9	62.0	70.1	76.4	82.7	84.3	84.2	74.8	67.0	58.3	49.0
		MCWB	42.4	45.3	50.2	56.3	63.4	69.2	70.3	70.1	64.7	58.6	52.0	43.3
	5%	DB	45.2	49.9	58.0	66.4	73.2	79.5	81.4	80.8	71.8	63.9	54.2	45.4
		MCWB	40.9	42.7	48.3	54.6	61.6	67.5	69.0	68.5	63.3	57.2	49.8	41.3
	10%	DB	42.0	46.5	54.2	63.0	70.0	76.1	78.6	77.5	68.6	60.9	51.0	42.6
		MCWB	38.3	40.5	46.2	52.7	59.5	65.3	67.4	66.9	61.4	55.6	47.8	39.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.5	48.9	53.7	60.3	67.1	72.4	73.9	73.3	68.6	62.0	55.4	47.6
		MCDB	51.6	58.3	63.7	73.6	77.8	82.9	84.1	83.7	76.3	68.1	60.7	51.8
	2%	WB	43.5	45.8	51.0	57.7	64.6	70.2	71.9	71.2	66.0	59.8	52.9	44.6
		MCDB	47.4	52.7	60.3	68.1	74.0	80.8	81.8	81.5	73.0	65.2	57.3	47.8
	5%	WB	41.2	43.4	49.0	55.5	62.6	68.3	70.1	69.4	64.2	58.1	50.4	42.0
		MCDB	44.9	48.9	56.8	65.1	71.7	77.9	79.5	79.3	70.1	62.6	53.8	44.7
	10%	WB	38.7	41.2	46.9	53.5	60.5	66.5	68.4	67.7	62.2	56.4	48.2	39.6
		MCDB	41.6	45.6	53.1	61.1	68.6	74.8	77.1	76.3	67.4	60.3	50.7	42.4
Mean Daily Temperature Range	5% DB	MDBR	9.0	11.7	13.9	15.2	15.3	15.6	15.5	14.8	12.9	11.9	8.9	8.5
		MCDBR	13.6	16.8	19.3	20.2	19.3	19.7	18.9	18.7	16.3	15.8	14.1	13.5
		MCWBR	8.9	10.5	11.0	10.4	9.7	9.4	8.8	8.9	8.2	8.4	8.8	9.4
	5% WB	MCDBR	12.9	15.6	18.2	18.4	18.5	18.9	18.0	17.7	15.7	14.4	12.5	12.4
		MCWBR	8.8	10.1	10.8	9.7	9.6	9.4	8.8	9.0	8.2	8.0	8.2	9.2
Clear-Sky Solar Irradiance	taub	0.297	0.322	0.360	0.403	0.404	0.410	0.413	0.413	0.385	0.359	0.329	0.297	
	taud	2.444	2.394	2.329	2.232	2.272	2.291	2.282	2.293	2.346	2.400	2.446	2.481	
	Ebn at Noon	252	268	272	269	273	272	269	263	260	249	236	239	
	Edh at Noon	21	27	34	41	41	41	40	38	33	27	21	18	
All-Sky Solar Radiation	RadAvg	388	656	1004	1333	1580	1743	1739	1543	1109	746	413	318	
	RadStd	47	89	120	143	165	126	139	171	142	76	60	46	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (95 neighbors)		+0.99	N/A	N/A	+1.60	+0.86	+0.72	-193	-261	+164	+103

Nomenclature: See separate page