

DORNBIRN, AustriaWMO: **113020**Lat: **47.4327N**Lon: **9.7257E**Elev: **407**StdP: **96.53**Time Zone: **1.00 (EUC)**Period: **95-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-9.2	-7.2	-11.1	1.5	-8.6	-9.0	1.8	-6.2	5.9	8.2	4.8	6.7	0.8	50	0.439

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.9	30.0	21.2	28.1	20.3	26.5	19.5	22.0	28.3	21.0	26.9	20.1	25.3	2.0	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.8	15.2	25.4	18.9	14.4	24.1	18.1	13.7	22.9	66.2	28.4	62.6	27.1	59.5	25.5	26.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 4.7	3.8	3.1	-12.1	33.0	3.3	2.2	-14.5	34.5	-16.4	35.8	-18.2	37.0	-20.6	38.6		
(5)			-12.3	23.8	3.2	1.1	-14.7	24.6	-16.6	25.2	-18.4	25.8	-20.7	26.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.3	0.5	2.1	6.1	10.1	14.5	18.2	19.5	19.2	15.1	11.0	5.3	1.8
	DBStd	7.70	4.18	4.29	3.97	3.93	3.60	3.72	3.20	3.01	3.18	3.36	3.86	3.96
	HDD10.0	1130	296	222	128	46	5	1	0	0	2	29	146	256
	HDD18.3	3092	553	454	378	247	126	48	25	26	104	228	390	513
	CDD10.0	1256	1	1	8	50	146	246	294	286	156	59	6	1
	CDD18.3	176	0	0	0	1	8	44	61	53	8	0	0	0
	CDH23.3	1350	0	0	0	8	89	373	468	363	47	3	0	0
	CDH26.7	339	0	0	0	1	12	104	127	92	3	1	0	0
Wind	WSAvg	1.1	1.0	1.1	1.3	1.3	1.3	1.2	1.1	1.0	0.9	1.0	1.0	1.0
Precipitation	PrecAvg	1400	69	77	88	101	138	171	168	170	124	96	104	91
	PrecMax	1799	150	210	177	188	321	314	311	291	200	208	238	192
	PrecMin	1067	7	21	30	32	19	65	65	49	57	9	7	10
	PrecStd	155	40	41	37	42	67	61	65	60	39	43	50	43
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.2	15.8	19.5	24.2	28.1	32.0	32.1	32.0	26.9	22.2	18.2	15.8
		MCWB	8.9	9.1	12.0	14.9	18.6	21.8	21.9	22.5	19.6	15.9	12.1	8.9
	2%	DB	9.7	12.2	17.0	22.0	25.9	29.6	29.9	29.1	24.7	19.8	14.9	10.2
		MCWB	6.8	7.6	10.6	14.0	17.5	20.7	21.1	21.5	18.7	15.0	10.6	7.7
	5%	DB	7.8	10.0	14.9	19.8	23.8	27.5	27.9	27.1	22.7	17.8	12.1	8.3
		MCWB	5.9	6.5	9.8	13.0	16.7	19.8	20.3	20.5	17.9	14.1	9.7	6.6
	10%	DB	5.9	8.0	12.8	17.5	21.6	25.4	26.0	25.2	20.8	16.0	10.3	7.0
		MCWB	4.6	5.4	8.7	11.8	15.3	18.9	19.4	19.6	16.8	13.5	8.6	5.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.7	9.7	12.5	16.1	19.8	22.8	23.1	23.2	20.6	17.2	12.9	9.6
		MCDB	12.6	14.1	18.3	23.1	26.6	29.8	30.8	30.2	25.1	20.9	16.7	13.3
	2%	WB	7.2	8.1	11.2	14.4	18.2	21.4	21.6	22.1	19.3	15.7	11.2	8.1
		MCDB	9.1	11.8	15.8	20.4	24.4	28.0	28.1	28.1	23.6	18.5	14.0	10.2
	5%	WB	5.9	6.8	10.1	13.2	17.1	20.3	20.7	20.9	18.3	14.6	9.9	6.9
		MCDB	7.4	9.6	14.0	18.6	22.5	26.2	26.7	26.2	21.8	17.0	11.9	8.2
	10%	WB	4.6	5.6	9.1	12.1	15.9	19.2	19.8	20.0	17.2	13.6	8.8	5.6
		MCDB	5.9	7.7	12.1	16.9	20.6	24.5	25.1	24.5	20.3	15.6	10.2	6.7
Mean Daily Temperature Range	5% DB	MDBR	5.7	7.5	9.3	10.2	10.1	10.0	9.9	9.9	9.2	8.0	6.5	5.5
		MCDBR	7.7	10.9	13.3	14.5	14.3	14.0	13.4	13.4	11.9	10.8	9.5	7.6
		MCWBR	5.4	6.9	7.8	7.4	6.9	6.3	6.0	6.4	6.6	6.6	6.2	5.2
	5% WB	MCDBR	7.4	10.1	12.0	13.2	12.8	12.9	12.2	12.4	10.9	9.6	8.7	7.3
		MCWBR	5.5	6.6	7.4	7.2	6.6	6.2	5.8	6.3	6.4	6.3	5.9	5.1
Clear-Sky Solar Irradiance	taub	0.288	0.315	0.357	0.401	0.416	0.423	0.424	0.415	0.383	0.350	0.316	0.285	
	taud	2.393	2.317	2.281	2.224	2.241	2.267	2.262	2.303	2.370	2.447	2.471	2.420	
	Ebn at Noon	798	844	858	850	849	844	836	828	822	798	759	757	
	Edh at Noon	69	92	112	130	133	131	130	120	102	81	65	60	
All-Sky Solar Radiation	RadAvg	1.21	2.07	3.24	4.32	4.94	5.64	5.49	4.81	3.60	2.31	1.30	0.99	
	RadStd	0.14	0.27	0.42	0.61	0.51	0.54	0.51	0.50	0.39	0.25	0.17	0.15	