

ISCHGL IDALPE, Austria

WMO: 113100

Lat: 46.983N

Lon: 10.317E

Elev: 7585

StdP: 11.09

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-0.2	3.3	-14.9	3.2	13.9	-10.5	4.1	14.8	19.8	19.9	16.9	23.1	2.8	90	0.733

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.9	64.7	50.6	61.8	49.4	59.3	48.2	52.3	61.2	50.8	59.3	49.4	57.5	5.6	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
48.5	67.1	55.2	46.7	62.7	54.1	45.2	59.2	53.0	24.6	61.5	23.5	59.7	22.6	57.6	58.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.2	13.3	11.2	DB	-4.9	69.4	5.1	3.4	-8.6	71.8	-11.6	73.8	-14.4	75.7	-18.1	78.1	(4)
(5)			WB	-5.2	54.8	5.2	1.8	-9.0	56.1	-12.1	57.1	-15.0	58.1	-18.8	59.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	34.7	21.3	20.9	25.0	30.7	38.1	45.3	48.9	49.3	42.5	38.5	29.8	24.6
	DBStd	12.85	8.23	9.21	8.65	7.85	6.99	7.68	6.92	6.86	7.41	7.97	8.98	8.77
	HDD50	5795	889	814	775	578	370	179	103	97	237	359	606	788
	HDD65	11069	1354	1234	1240	1028	832	592	498	488	674	820	1056	1253
	CDD50	200	0	0	0	0	3	37	70	74	13	3	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	4.5	5.0	4.5	4.6	4.5	4.3	4.4	4.4	4.0	3.9	4.5	5.1	4.8
Precipitation	PrecAvg	30.2	1.6	1.5	1.6	1.6	2.5	3.6	4.2	4.4	2.7	2.5	2.3	1.6
	PrecMax	38.8	4.1	6.9	4.1	3.3	5.0	5.9	7.0	7.9	5.5	6.0	7.6	5.6
	PrecMin	23.1	0.2	0.4	0.3	0.3	0.9	1.8	2.8	1.7	1.0	0.2	0.2	0.2
	PrecStd	3.9	1.1	1.4	0.9	0.7	0.9	1.1	1.0	1.4	1.2	1.4	1.6	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	40.9	42.3	45.0	49.7	58.4	66.6	67.5	68.2	61.2	57.5	49.1	42.3
		MCWB	31.0	29.9	33.5	38.5	45.8	51.4	52.2	51.8	46.7	43.4	37.2	31.1
	2%	DB	37.7	38.4	41.3	46.5	54.1	62.2	64.4	64.7	57.9	53.7	45.8	39.4
		MCWB	29.2	28.8	31.4	36.6	42.8	49.3	50.8	50.7	45.8	42.0	35.3	29.1
	5%	DB	34.8	35.2	38.6	43.7	50.9	59.2	61.3	61.7	55.0	50.6	43.1	37.3
		MCWB	27.5	27.4	30.1	35.2	41.1	48.0	49.7	49.5	44.5	40.1	33.9	28.5
	10%	DB	32.2	32.5	35.7	41.2	47.8	56.2	58.7	58.9	52.6	48.2	40.6	35.3
		MCWB	26.4	26.1	28.8	33.7	39.5	46.4	48.3	48.2	43.5	39.2	32.7	28.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	33.1	32.6	34.9	40.2	47.4	53.0	54.2	54.8	49.5	45.6	39.6	33.6
		MCDB	37.0	37.4	41.9	47.2	57.3	64.2	63.3	63.2	56.3	53.8	46.1	37.5
	2%	WB	30.7	30.1	32.9	37.9	44.1	50.6	52.4	52.4	47.6	43.5	37.3	32.1
		MCDB	35.2	35.2	39.1	44.7	52.1	59.8	61.3	60.8	55.1	50.6	43.1	36.1
	5%	WB	28.8	28.5	31.2	36.0	42.1	48.9	50.9	50.6	46.0	41.9	35.3	30.6
		MCDB	33.3	34.5	36.7	42.5	49.3	57.3	59.3	59.2	53.3	48.6	41.0	35.3
	10%	WB	27.0	26.7	29.7	34.2	40.2	47.3	49.4	49.2	44.6	40.4	33.8	28.8
		MCDB	31.9	32.1	34.7	40.4	46.6	55.1	57.2	57.3	51.0	47.0	39.1	34.0
Mean Daily Temperature Range	5% DB	MDBR	8.7	9.5	10.2	10.2	10.2	11.0	11.2	10.9	10.1	9.7	8.3	8.8
		MCDBR	10.0	10.3	12.0	11.6	13.2	14.6	13.9	14.0	12.5	11.8	9.3	9.4
		MCWBR	7.3	7.2	8.1	7.0	7.0	7.2	6.9	6.8	7.2	7.3	6.0	6.4
	5% WB	MCDBR	9.3	10.1	10.5	10.7	12.2	13.5	13.1	13.0	11.3	10.8	8.6	9.0
		MCWBR	7.8	8.3	7.8	6.9	7.0	7.2	7.1	6.9	6.7	7.4	6.4	7.6
Clear-Sky Solar Irradiance	taub	0.207	0.225	0.256	0.291	0.304	0.311	0.310	0.305	0.281	0.260	0.233	0.207	
	taud	2.405	2.360	2.341	2.395	2.458	2.473	2.471	2.505	2.566	2.599	2.561	2.452	
	Ebn at Noon	296	309	311	307	305	302	301	299	299	293	284	284	
	Edh at Noon	21	27	33	35	34	34	33	31	26	22	18	17	
All-Sky Solar Radiation	RadAvg	466	763	1132	1397	1541	1754	1751	1537	1170	788	469	385	
	RadStd	53	91	137	193	168	155	149	151	126	95	72	51	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (105 neighbors)	+0.61	N/A	N/A	+1.15	+0.76	+0.65	N/A	N/A	+104	+29

Nomenclature: See separate page