

SONNBLICK, Austria

WMO: 113430

Lat: 47.054N

Lon: 12.957E

Elev: 10216

StdP: 10.02

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-9.9	-6.5	-21.9	2.4	6.2	-17.0	3.2	10.1	51.8	14.5	48.3	13.7	21.8	30	1.155

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.8	50.4	44.1	48.3	43.3	46.4	42.2	46.2	48.8	44.6	47.2	43.2	45.7	9.8	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
44.9	64.8	47.4	43.2	60.6	45.8	41.8	57.4	44.5	21.6	49.0	20.6	47.4	19.7	45.8	70.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 46.8	41.2	36.6	DB	-14.5	56.0	5.2	5.9	-18.3	60.2	-21.3	63.7	-24.3	67.0	-28.0	71.3	(4)
(5)			WB	-14.8	51.9	5.3	6.2	-18.7	56.4	-21.8	60.0	-24.8	63.5	-28.7	68.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	23.8	11.1	10.1	13.8	20.1	27.0	34.4	38.1	38.0	31.1	27.1	19.6	13.9
	DBStd	12.28	8.05	8.65	8.29	7.01	6.07	6.82	5.94	5.72	6.30	6.98	8.39	8.59
	HDD50	9569	1206	1117	1122	898	712	467	369	372	566	711	911	1118
	HDD65	15043	1671	1537	1587	1348	1177	917	833	837	1016	1176	1361	1583
	CDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	17.6	20.7	21.2	19.1	17.6	16.4	13.7	13.6	13.1	14.8	19.3	21.5	20.0
Precipitation	PrecAvg	67.4	5.4	4.6	6.0	6.3	6.1	5.9	6.5	6.5	4.8	4.8	5.6	5.5
	PrecMax	82.7	12.6	10.4	13.5	12.3	19.4	8.9	10.1	14.1	10.3	10.0	12.6	11.1
	PrecMin	49.2	1.1	1.1	1.6	0.9	1.3	2.8	2.2	2.8	2.1	0.0	0.4	0.5
	PrecStd	9.0	2.6	2.3	2.6	2.5	3.1	1.5	1.8	2.0	1.7	2.4	2.6	2.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	29.7	30.5	31.3	35.8	44.2	52.6	53.4	52.7	46.0	42.3	36.8	32.6
		MCWB	22.8	20.9	23.7	31.1	38.1	44.4	46.4	45.3	40.4	33.0	28.2	23.9
	2%	DB	27.0	27.5	28.3	32.6	40.7	48.9	50.8	49.6	43.5	39.9	34.2	29.2
		MCWB	20.9	20.0	23.0	28.6	36.2	42.7	45.3	43.1	38.5	31.7	27.6	21.1
	5%	DB	24.8	24.0	26.3	30.6	37.9	46.4	48.5	47.6	41.5	37.9	32.2	26.8
		MCWB	20.1	19.4	21.4	27.7	34.3	41.6	43.9	42.9	37.3	30.6	25.2	20.2
	10%	DB	21.9	21.1	24.2	28.6	35.2	43.9	46.4	45.8	39.6	36.0	29.5	24.5
		MCWB	18.1	17.9	20.7	26.4	33.2	40.1	42.7	42.2	35.9	29.9	24.7	20.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.5	24.3	27.0	32.2	40.0	46.9	49.1	47.7	43.0	37.1	32.9	26.5
		MCDB	27.1	25.8	28.6	34.0	42.9	50.5	51.9	49.7	44.8	38.9	34.2	29.4
	2%	WB	22.8	22.0	24.8	30.3	37.3	44.4	46.7	45.7	40.7	35.1	29.7	24.1
		MCDB	25.3	24.7	26.6	31.9	39.8	47.3	49.5	47.9	42.3	36.9	31.7	25.9
	5%	WB	20.6	20.0	22.9	28.6	35.2	42.6	45.0	44.2	38.9	33.6	27.9	22.6
		MCDB	23.5	23.1	25.0	30.0	37.2	45.6	47.6	46.6	40.4	35.5	29.7	24.8
	10%	WB	18.9	18.2	21.4	26.9	33.4	40.9	43.4	42.9	37.2	32.0	26.4	20.9
		MCDB	21.5	21.1	23.6	28.3	35.0	43.7	45.9	45.2	38.8	33.9	28.3	23.6
Mean Daily Temperature Range	5% DB	MDBR	7.3	7.3	7.5	7.3	6.9	7.3	7.8	7.0	6.1	6.3	6.6	7.3
		MCDBR	8.9	8.5	7.4	7.0	8.5	9.9	9.8	8.3	7.1	6.2	6.9	8.2
		MCWBR	6.5	6.6	6.4	6.9	7.8	9.2	8.8	7.9	8.2	6.9	4.6	6.1
	5% WB	MCDBR	8.1	9.1	7.1	6.9	8.0	9.4	9.4	8.0	6.8	5.5	5.3	7.2
		MCWBR	7.5	8.4	6.9	6.8	7.5	8.8	8.8	7.8	7.8	7.2	5.6	7.5
Clear-Sky Solar Irradiance	taub	0.193	0.208	0.236	0.263	0.274	0.282	0.281	0.277	0.257	0.240	0.218	0.195	
	taud	2.480	2.443	2.468	2.517	2.543	2.546	2.542	2.570	2.624	2.648	2.628	2.546	
	Ebn at Noon	305	318	320	318	315	311	310	309	309	302	293	294	
	Edh at Noon	19	25	29	31	31	31	31	29	25	20	17	16	
All-Sky Solar Radiation	RadAvg	437	721	1052	1319	1522	1696	1729	1526	1129	772	442	362	
	RadStd	51	93	127	171	185	159	150	168	142	86	77	53	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (88 neighbors)	+0.77	N/A	N/A	+1.13	+0.70	+0.59	N/A	N/A	+130	+72

Nomenclature: See separate page