

RAURIS, Austria

WMO: 113460

Lat: 47.224N

Lon: 12.992E

Elev: 3091

StdP: 13.13

Time Zone: 1.00 (EUC)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	2.6	6.8	0.6	6.3	3.0	4.6	7.8	7.4	14.4	34.3	12.9	33.3	1.7	180	0.553

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.3	82.7	64.0	79.1	63.0	75.7	61.8	65.8	78.3	64.3	76.0	62.8	73.3	5.6	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
61.7	92.2	69.7	60.1	87.0	68.3	58.7	82.8	66.9	32.4	78.4	31.1	76.1	30.0	73.7	72.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.0	10.0	8.6	DB	-0.8	88.9	5.6	2.0	-4.8	90.3	-8.1	91.5	-11.2	92.6	-15.3	94.1	(4)
(5)			WB	-1.7	68.7	5.5	1.5	-5.7	69.8	-8.9	70.7	-11.9	71.5	-15.9	72.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	44.7	24.9	29.5	37.3	45.3	52.3	58.9	61.7	61.4	53.5	46.0	35.9	28.4	(6)	
	DBStd	14.37	8.07	7.79	6.79	6.48	5.99	6.75	5.80	5.56	5.69	6.36	7.60	7.75	(7)	
	HDD50	3250	779	574	395	166	46	11	1	2	29	153	425	669	(8)	
	HDD65	7495	1244	994	860	592	394	200	134	137	344	590	872	1134	(9)	
	CDD50	1305	0	0	0	24	118	278	363	354	136	28	4	0	(10)	
	CDD65	75	0	0	0	0	0	18	31	25	1	0	0	0	(11)	
	CDH74	1068	0	0	0	2	46	300	373	322	25	0	0	0	(12)	
	CDH80	224	0	0	0	0	3	66	85	69	1	0	0	0	(13)	
	WSAvg	3.2	3.0	3.3	3.6	3.8	3.5	3.4	3.3	3.0	2.7	2.9	2.9	2.8	(14)	
	PrecAvg	49.2	2.6	2.5	3.1	3.3	4.6	5.9	6.4	6.0	4.3	4.0	3.5	2.9	(15)	
(16) Precipitation	PrecMax	60.7	5.4	5.7	7.4	5.9	7.4	8.2	9.8	8.7	6.3	7.1	7.6	7.7	(16)	
	PrecMin	40.3	0.7	0.7	0.9	0.6	1.4	3.6	2.6	3.1	1.9	0.6	0.0	0.7	(17)	
	PrecStd	4.0	1.3	1.4	1.5	1.3	1.5	1.1	1.8	1.5	1.1	1.7	1.7	1.4	(18)	
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	47.0	51.6	62.1	71.1	79.3	86.2	87.0	85.7	77.4	68.5	61.0	52.1	(19)	
		MCWB	40.1	41.6	46.9	54.1	60.3	63.7	66.0	65.6	62.2	55.8	49.5	42.0	(20)	
	2%	DB	41.3	46.9	57.4	66.6	74.2	81.4	82.1	81.7	72.7	63.8	56.1	45.4	(21)	
		MCWB	37.0	39.1	45.6	51.7	58.5	62.7	64.3	64.8	60.0	53.6	47.1	39.9	(22)	
	5%	DB	38.1	43.2	53.2	63.1	70.1	77.4	78.2	77.6	68.7	60.1	50.7	40.9	(23)	
		MCWB	35.2	37.2	43.4	49.7	56.1	61.7	63.2	63.3	58.1	51.8	45.1	37.1	(24)	
	10%	DB	35.3	39.8	48.6	59.2	66.0	72.8	74.1	73.4	64.9	56.4	46.2	37.5	(25)	
		MCWB	33.3	35.4	41.0	47.7	54.0	60.0	62.0	61.9	56.5	50.4	43.0	35.1	(26)	
	0.4%	WB	41.4	42.3	48.4	55.9	62.0	66.4	68.0	67.7	63.7	57.2	51.0	43.8	(27)	
		MCDB	46.1	49.6	59.7	69.9	76.0	80.2	82.1	81.2	73.7	65.3	58.4	49.9	(28)	
(30) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	37.4	39.8	45.8	52.5	59.2	64.4	65.9	65.8	61.2	54.8	47.9	40.5	(29)	
		MCDB	40.6	46.0	55.4	64.8	72.2	77.5	78.4	78.2	70.3	61.4	54.4	44.7	(30)	
	5%	WB	35.4	37.6	43.9	50.4	57.1	62.6	64.3	64.1	59.1	52.8	45.5	37.5	(31)	
		MCDB	37.7	42.2	52.0	61.4	68.2	74.1	75.7	75.3	66.6	58.4	50.1	40.1	(32)	
	10%	WB	33.6	35.7	41.6	48.3	55.0	60.7	62.7	62.6	57.2	51.0	43.1	35.3	(33)	
		MCDB	35.3	39.2	48.0	57.8	64.3	70.9	72.5	72.2	63.6	55.9	46.3	37.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	13.9	16.5	18.6	20.7	21.1	20.6	20.3	21.1	19.7	18.9	14.3	13.2	(35)	
		MCDBR	14.3	21.2	27.4	29.7	30.6	30.6	28.9	29.3	27.5	24.5	20.6	17.0	(36)	
	5% WB	MCWBR	10.4	14.3	15.6	15.6	15.4	13.3	12.9	13.6	15.3	14.7	13.1	11.9	(37)	
		MCWBR	13.3	18.9	25.1	27.5	28.2	27.0	26.1	26.7	24.9	22.0	18.3	15.5	(38)	
		MCWBR	9.8	13.1	14.7	14.5	14.6	12.4	12.3	13.1	14.4	13.7	12.2	11.2	(39)	
(40) Clear-Sky Solar Irradiance	taub	0.270	0.299	0.345	0.389	0.403	0.411	0.410	0.402	0.365	0.336	0.303	0.271	(40)		
	taud	2.369	2.282	2.235	2.216	2.241	2.266	2.273	2.315	2.394	2.447	2.467	2.433	(41)		
	Ebn at Noon	262	274	276	273	273	271	270	267	267	259	247	248	(42)		
	Edh at Noon	22	30	37	42	42	42	41	37	32	26	21	19	(43)		
(44) All-Sky Solar Radiation	RadAvg	425	716	1036	1310	1505	1670	1701	1508	1109	767	435	350	(44)		
	RadStd	51	91	124	167	182	165	156	173	143	84	74	53	(45)		

Historical Trends

		Heating		Cooling		Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (88 neighbors)	+0.77	N/A	N/A	N/A	+0.68	+0.61	N/A	N/A	+126	+65 (47)

Nomenclature: See separate page