

RAURIS, Austria

WMO: 113460

Lat: 47.224N

Lon: 12.992E

Elev: 942

StdP: 90.51

Time Zone: 1.00 (EUC)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-16.3	-14.0	-17.5	0.9	-16.1	-15.2	1.1	-13.7	6.4	1.3	5.8	0.7	0.8	180	0.553

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.3	28.1	17.8	26.2	17.2	24.3	16.6	18.8	25.7	17.9	24.4	17.1	22.9	2.5	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
16.5	13.2	20.9	15.6	12.4	20.1	14.9	11.8	19.4	57.4	25.8	54.5	24.5	51.9	23.2	22.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.4	4.5	3.9	-18.2	31.6	3.1	1.1	-20.5	32.4	-22.3	33.1	-24.0	33.7	-26.3	34.5		
(5)			-18.7	20.4	3.0	0.8	-20.9	21.0	-22.7	21.5	-24.4	22.0	-26.6	22.6	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	7.0	-4.0	-1.4	2.9	7.4	11.3	14.9	16.5	16.3	12.0	7.8	2.2	-2.0	(6)
(7)		DBStd	7.99	4.48	4.33	3.77	3.60	3.33	3.75	3.22	3.09	3.16	3.53	4.22	4.31	(7)
(8)		HDD10.0	1806	433	319	219	92	26	6	1	1	16	85	236	372	(8)
(9)		HDD18.3	4164	691	552	478	329	219	111	74	76	191	328	484	630	(9)
(10)		CDD10.0	725	0	0	0	13	66	154	202	197	76	16	2	0	(10)
(11)		CDD18.3	42	0	0	0	0	0	10	17	14	1	0	0	0	(11)
(12)		CDH23.3	593	0	0	0	1	26	167	207	179	14	0	0	0	(12)
(13)		CDH26.7	124	0	0	0	0	2	37	47	38	1	0	0	0	(13)
(14)	Wind	WSAvg	1.4	1.4	1.5	1.6	1.7	1.6	1.5	1.5	1.4	1.2	1.3	1.3	1.3	(14)
(15)	Precipitation	PrecAvg	1249	66	64	78	85	116	151	162	153	109	101	90	74	(15)
(16)		PrecMax	1542	136	145	188	150	187	208	250	220	161	181	193	196	(16)
(17)		PrecMin	1024	17	19	24	16	36	91	67	80	47	16	0	18	(17)
(18)		PrecStd	102	32	35	38	32	38	29	45	37	29	42	44	35	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.3	10.9	16.7	21.7	26.3	30.1	30.6	29.8	25.2	20.3	16.1	11.2	(19)
MCWB			4.5	5.3	8.3	12.3	15.7	17.6	18.9	18.7	16.8	13.2	9.7	5.6	(20)	
2%		DB	5.2	8.3	14.1	19.2	23.5	27.4	27.8	27.6	22.6	17.7	13.4	7.4	(21)	
		MCWB	2.8	3.9	7.5	11.0	14.7	17.0	17.9	18.2	15.5	12.0	8.4	4.4	(22)	
5%		DB	3.4	6.2	11.8	17.3	21.1	25.2	25.7	25.3	20.4	15.6	10.4	4.9	(23)	
		MCWB	1.8	2.9	6.3	9.9	13.4	16.5	17.3	17.4	14.5	11.0	7.3	2.8	(24)	
10%		DB	1.8	4.4	9.2	15.1	18.9	22.7	23.4	23.0	18.3	13.5	7.9	3.0	(25)	
		MCWB	0.7	1.9	5.0	8.7	12.2	15.6	16.7	16.6	13.6	10.2	6.1	1.7	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.2	5.7	9.1	13.3	16.7	19.1	20.0	19.9	17.6	14.0	10.6	6.6	(27)
MCDWB			7.8	9.8	15.4	21.0	24.4	26.8	27.8	27.4	23.2	18.5	14.7	10.0	(28)	
2%		WB	3.0	4.3	7.7	11.4	15.1	18.0	18.9	18.8	16.2	12.7	8.8	4.7	(29)	
		MCDWB	4.8	7.8	13.0	18.2	22.3	25.3	25.8	25.7	21.3	16.3	12.4	7.1	(30)	
5%		WB	1.9	3.1	6.6	10.2	13.9	17.0	17.9	17.8	15.1	11.6	7.5	3.1	(31)	
		MCDWB	3.1	5.7	11.1	16.3	20.1	23.4	24.3	24.0	19.2	14.7	10.0	4.5	(32)	
10%		WB	0.9	2.1	5.3	9.0	12.8	16.0	17.0	17.0	14.0	10.6	6.1	1.8	(33)	
		MCDWB	1.8	4.0	8.9	14.4	17.9	21.6	22.5	22.3	17.6	13.3	7.9	2.8	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.7	9.2	10.3	11.5	11.7	11.4	11.3	11.7	10.9	10.5	7.9	7.3	(35)
MCDBR			7.9	11.8	15.2	16.5	17.0	17.0	16.1	16.3	15.3	13.6	11.4	9.4	(36)	
MCWBR			5.8	7.9	8.7	8.7	8.6	7.4	7.2	7.5	8.5	8.2	7.3	6.6	(37)	
5% WB		MCDWR	7.4	10.5	13.9	15.3	15.7	15.0	14.5	14.8	13.8	12.2	10.2	8.6	(38)	
		MCWBR	5.4	7.3	8.2	8.1	8.1	6.9	6.9	7.3	8.0	7.6	6.8	6.2	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.270	0.299	0.345	0.389	0.403	0.411	0.410	0.402	0.365	0.336	0.303	0.271	(40)	
(41)		taud	2.369	2.282	2.235	2.216	2.241	2.266	2.273	2.315	2.394	2.447	2.467	2.433	(41)	
(42)		Ebn at Noon	825	864	870	862	861	854	850	841	843	816	780	783	(42)	
(43)		Edh at Noon	70	95	117	132	133	131	128	118	100	81	65	59	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.34	2.26	3.27	4.13	4.74	5.27	5.36	4.75	3.50	2.42	1.37	1.10	(44)	
(45)		RadStd	0.16	0.29	0.39	0.53	0.57	0.52	0.49	0.55	0.45	0.26	0.23	0.17	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (88 neighbors)		+0.43	N/A	N/A	N/A	+0.38	+0.34	N/A	N/A	+70	+36

Nomenclature: See separate page