

SALZBURG FREISAAL, Austria

WMO: 113500

Lat: 47.791N

Lon: 13.054E

Elev: 1373

StdP: 13.98

Time Zone: 1.00 (EUC)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.3	16.4	8.6	9.0	12.4	13.2	11.3	18.2	11.8	45.4	9.7	41.1	1.6	350	0.443

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.9	87.7	70.0	84.3	68.5	81.2	66.9	71.3	85.0	69.5	82.1	68.0	79.0	3.7	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.6	103.0	77.6	65.1	97.5	75.3	63.8	93.1	73.4	35.9	85.5	34.4	82.4	33.1	79.3	79.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.5	7.7	6.7	7.9	94.2	6.2	2.7	3.5	96.1	-0.1	97.7	-3.6	99.2	-8.1	101.2
			7.3	74.6	5.9	1.9	3.1	75.9	-0.3	77.1	-3.6	78.1	-7.9	79.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	50.5	31.7	35.4	42.8	51.2	58.5	64.5	67.2	67.0	59.2	51.5	41.1	34.9
	DBStd	14.36	7.99	8.11	7.69	7.54	7.15	7.15	6.36	6.12	6.31	6.83	7.21	6.90
	HDD50	2132	568	410	244	75	12	2	0	0	5	67	278	471
	HDD65	5654	1032	829	689	418	225	96	51	50	193	420	717	934
	CDD50	2310	1	1	20	110	274	436	533	528	282	113	11	1
	CDD65	358	0	0	0	3	22	81	119	113	19	1	0	0
	CDH74	3090	0	0	1	37	253	748	1002	906	135	8	0	0
	CDH80	909	0	0	0	5	50	222	327	286	19	0	0	0
Wind	WSAvg	2.6	2.6	2.8	3.2	3.0	2.8	2.6	2.6	2.4	2.2	2.2	2.4	2.7
Precipitation	PrecAvg	49.1	2.6	2.1	3.1	3.3	5.4	6.7	6.5	6.5	4.4	3.1	2.9	2.8
	PrecMax	91.5	7.4	5.7	6.9	8.5	13.9	15.2	12.8	14.2	10.9	7.9	8.1	6.5
	PrecMin	31.1	0.1	0.3	0.6	0.5	0.6	2.0	1.8	2.2	0.7	0.2	0.0	0.5
	PrecStd	10.7	1.7	1.2	1.5	1.7	2.5	2.7	2.3	2.5	2.0	1.7	1.7	1.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.9	59.3	68.8	78.1	85.4	90.7	92.0	92.2	82.4	74.8	66.5	58.2
		MCWB	48.2	47.2	52.4	58.8	65.5	71.2	71.5	70.8	67.0	61.2	53.5	46.8
	2%	DB	48.6	54.3	64.2	73.4	80.6	86.0	87.1	87.0	77.6	70.1	60.5	50.7
		MCWB	42.9	45.1	51.1	57.3	64.4	69.3	70.0	70.2	64.9	58.8	51.3	44.0
	5%	DB	44.8	49.9	59.8	69.5	76.4	82.4	83.6	82.8	74.1	66.1	55.3	47.0
		MCWB	40.8	42.5	48.9	55.2	61.9	67.3	68.6	68.6	63.6	57.2	48.6	42.6
	10%	DB	41.8	46.1	55.3	65.4	72.2	78.5	79.9	79.1	70.4	62.2	51.1	44.1
		MCWB	38.7	40.9	46.6	53.0	59.5	65.4	67.0	66.9	61.8	55.3	47.2	40.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.7	48.6	54.5	61.3	67.8	72.7	73.8	73.1	68.5	62.7	54.2	47.9
		MCDB	55.1	58.1	66.0	73.9	82.1	87.2	88.4	87.1	78.7	71.7	62.7	56.3
	2%	WB	43.7	45.7	51.8	57.9	65.1	70.3	71.0	71.1	66.2	60.0	51.7	45.4
		MCDB	47.6	52.5	62.1	71.7	78.4	84.1	84.3	84.6	75.4	67.2	59.4	49.5
	5%	WB	41.1	43.5	49.5	55.7	63.0	68.3	69.3	69.2	64.4	58.0	49.6	42.9
		MCDB	44.5	49.0	58.1	68.1	74.5	79.7	81.6	81.2	72.3	64.4	54.2	46.5
	10%	WB	38.8	41.2	47.4	53.6	60.7	66.2	67.6	67.5	62.6	56.1	47.4	40.8
		MCDB	41.4	45.5	54.2	63.7	69.8	76.2	78.2	77.7	69.2	61.3	51.3	43.9
Mean Daily Temperature Range	5% DB	MDBR	10.7	13.1	16.1	18.1	18.0	17.7	17.9	18.3	16.5	16.1	11.8	10.2
		MCDBR	14.3	20.8	25.2	26.7	26.8	26.5	25.6	25.4	23.0	22.7	19.8	15.2
		MCWBR	9.4	12.6	13.8	13.0	12.4	11.3	10.7	10.8	11.8	12.7	11.4	9.8
	5% WB	MCDBR	13.0	18.5	23.1	25.3	24.8	23.7	23.6	24.0	21.3	20.8	17.9	13.8
MCWBR		8.8	11.5	13.0	12.7	11.9	10.7	10.4	10.7	11.3	12.1	10.8	9.3	
Clear-Sky Solar Irradiance	taub	0.297	0.325	0.367	0.402	0.415	0.420	0.422	0.416	0.386	0.353	0.323	0.295	
	taud	2.398	2.317	2.269	2.235	2.249	2.278	2.270	2.306	2.361	2.431	2.457	2.439	
	Ebn at Noon	248	263	268	269	270	268	266	262	259	251	236	234	
	Edh at Noon	22	29	36	41	42	41	41	38	33	26	21	19	
All-Sky Solar Radiation	RadAvg	381	679	994	1318	1511	1668	1669	1481	1073	732	400	303	
	RadStd	51	86	118	166	181	168	163	172	144	77	61	46	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (87 neighbors)	+0.81	N/A	N/A	N/A	+0.67	+0.68	N/A	N/A	+117	+49

Nomenclature: See separate page