

SALZBURG FREISAAL, AustriaWMO: **113500**Lat: **47.791N**Lon: **13.054E**Elev: **418**StdP: **96.40**Time Zone: **1.00 (EUC)**Period: **97-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.5	-8.6	-13.0	1.3	-10.9	-10.4	1.6	-7.7	5.3	7.5	4.4	5.1	0.7	350	0.443

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.9	30.9	21.1	29.1	20.3	27.3	19.4	21.8	29.4	20.8	27.8	20.0	26.1	1.6	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.2	14.7	25.3	18.4	13.9	24.0	17.6	13.3	23.0	65.6	29.7	62.1	28.0	59.0	26.3	26.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 4.2	3.4	3.0	-13.4	34.5	3.4	1.5	-15.8	35.6	-17.8	36.5	-19.8	37.3	-22.3	38.4		
(5)			-13.7	23.7	3.3	1.1	-16.0	24.4	-18.0	25.0	-19.8	25.6	-22.2	26.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.3	-0.2	1.9	6.0	10.6	14.7	18.0	19.5	19.5	15.1	10.8	5.1	1.6
	DBStd	7.98	4.44	4.50	4.27	4.19	3.97	3.97	3.53	3.40	3.51	3.80	4.01	3.83
	HDD10.0	1184	316	228	136	42	7	1	0	0	3	37	154	262
	HDD18.3	3141	573	461	383	232	125	53	28	28	107	233	398	519
	CDD10.0	1283	1	1	11	61	152	242	296	293	157	63	6	1
	CDD18.3	199	0	0	0	2	12	45	66	63	11	1	0	0
	CDH23.3	1717	0	0	1	21	141	416	557	503	75	4	0	0
	CDH26.7	505	0	0	0	3	28	123	182	159	11	0	0	0
Wind	WSAvg	1.2	1.2	1.3	1.4	1.4	1.2	1.2	1.2	1.1	1.0	1.0	1.1	1.2
Precipitation	PrecAvg	1246	66	54	79	84	138	170	164	165	111	78	74	72
	PrecMax	2323	187	146	176	215	352	386	324	360	277	200	207	164
	PrecMin	790	2	7	15	12	14	50	46	57	17	6	0	13
	PrecStd	271	42	31	37	44	63	69	59	63	51	43	42	38
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.3	15.1	20.5	25.6	29.7	32.6	33.3	33.4	28.0	23.8	19.2	14.6
		MCWB	9.0	8.5	11.3	14.9	18.6	21.8	21.9	21.5	19.4	16.2	11.9	8.2
	2%	DB	9.2	12.4	17.9	23.0	27.0	30.0	30.6	30.5	25.3	21.1	15.8	10.4
		MCWB	6.0	7.3	10.6	14.0	18.0	20.7	21.1	21.2	18.3	14.9	10.7	6.7
	5%	DB	7.1	9.9	15.4	20.8	24.7	28.0	28.7	28.2	23.4	18.9	13.0	8.3
		MCWB	4.9	5.9	9.4	12.9	16.6	19.6	20.3	20.3	17.6	14.0	9.2	5.9
	10%	DB	5.5	7.8	13.0	18.5	22.3	25.8	26.6	26.2	21.4	16.8	10.6	6.7
		MCWB	3.7	4.9	8.1	11.7	15.3	18.5	19.4	19.4	16.6	13.0	8.4	4.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.8	9.2	12.5	16.3	19.9	22.6	23.2	22.8	20.3	17.0	12.3	8.8
		MCDB	12.8	14.5	18.9	23.3	27.8	30.7	31.3	30.6	26.0	22.1	17.0	13.5
	2%	WB	6.5	7.6	11.0	14.4	18.4	21.3	21.6	21.7	19.0	15.6	11.0	7.4
		MCDB	8.6	11.4	16.7	22.0	25.8	28.9	29.1	29.2	24.1	19.6	15.2	9.7
	5%	WB	5.1	6.4	9.7	13.2	17.2	20.1	20.7	20.7	18.0	14.4	9.8	6.1
		MCDB	7.0	9.5	14.5	20.1	23.6	26.5	27.6	27.3	22.4	18.0	12.3	8.0
	10%	WB	3.8	5.1	8.6	12.0	15.9	19.0	19.8	19.7	17.0	13.4	8.6	4.9
		MCDB	5.2	7.5	12.3	17.6	21.0	24.6	25.7	25.4	20.7	16.3	10.7	6.6
Mean Daily Temperature Range	5% DB	MDBR	6.0	7.3	9.0	10.1	10.0	9.9	9.9	10.1	9.2	9.0	6.5	5.7
		MCDBR	7.9	11.6	14.0	14.8	14.9	14.7	14.2	14.1	12.8	12.6	11.0	8.5
		MCWBR	5.2	7.0	7.7	7.2	6.9	6.3	5.9	6.0	6.5	7.0	6.4	5.5
	5% WB	MCDBR	7.2	10.3	12.8	14.1	13.8	13.2	13.1	13.3	11.8	11.5	9.9	7.7
		MCWBR	4.9	6.4	7.2	7.0	6.6	5.9	5.8	6.0	6.3	6.7	6.0	5.2
Clear-Sky Solar Irradiance	taub	0.297	0.325	0.367	0.402	0.415	0.420	0.422	0.416	0.386	0.353	0.323	0.295	
	taud	2.398	2.317	2.269	2.235	2.249	2.278	2.270	2.306	2.361	2.431	2.457	2.439	
	Ebn at Noon	781	828	844	848	850	846	837	826	817	790	744	739	
	Edh at Noon	68	92	113	129	132	129	129	119	103	82	65	59	
All-Sky Solar Radiation	RadAvg	1.20	2.14	3.13	4.16	4.76	5.26	5.26	4.67	3.38	2.31	1.26	0.96	
	RadStd	0.16	0.27	0.37	0.52	0.57	0.53	0.52	0.54	0.45	0.24	0.19	0.14	