

BAD GOISERN, Austria

WMO: 113540

Lat: 47.6425N

Lon: 13.6181E

Elev: 1650

StdP: 13.84

Time Zone: 1.00 (EUC)

Period: 01-16

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.3	14.6	7.2	8.5	11.2	11.6	10.5	16.7	11.6	38.0	8.7	37.3	1.3	160	0.480

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.8	87.6	68.3	83.9	67.0	80.4	65.2	69.4	83.4	68.0	81.1	66.6	77.6	5.8	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.2	98.9	73.2	63.7	94.0	71.8	62.5	90.0	70.4	34.4	84.0	33.2	81.4	32.1	77.6	77.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.2	8.6	7.1	DB	5.8	94.0	5.7	2.5	1.7	95.8	-1.6	97.2	-4.8	98.6	-8.9	100.4	(4)
(5)			WB	6.1	72.3	5.9	2.1	1.8	73.9	-1.6	75.1	-5.0	76.3	-9.3	77.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	48.7	29.6	32.4	40.2	49.9	56.9	63.1	66.6	65.6	57.8	49.5	39.8	32.1	(6)	
	DBStd	14.62	6.76	7.37	7.10	6.99	6.91	7.01	6.30	5.98	6.33	6.50	7.09	6.23	(7)	
	HDD50	2509	633	493	308	86	19	2	0	0	10	89	314	555	(8)	
	HDD65	6221	1098	913	769	454	263	116	59	66	227	480	756	1020	(9)	
	CDD50	2038	0	0	4	83	232	397	513	483	243	75	8	0	(10)	
	CDD65	271	0	0	0	0	10	60	107	84	10	0	0	0	(11)	
	CDH74	2656	0	0	0	32	196	612	989	741	85	1	0	0	(12)	
	CDH80	816	0	0	0	4	43	189	333	235	12	0	0	0	(13)	
(14) Wind	WSAvg	2.3	1.8	2.1	2.5	2.8	2.8	2.7	2.7	2.4	2.1	2.1	1.9	1.7	(14)	
(15) Precipitation	PrecAvg	63.1	3.9	3.8	4.2	4.9	6.5	7.8	8.4	7.0	4.0	3.7	4.1	4.9	(15)	
	PrecMax	86.3	7.2	9.8	6.5	8.6	10.7	12.9	14.6	10.7	6.1	8.3	10.0	13.7	(16)	
	PrecMin	44.6	0.6	0.9	0.9	1.3	2.7	5.3	3.2	3.1	1.5	0.2	1.1	0.5	(17)	
	PrecStd	12.1	2.4	2.3	1.7	2.2	2.7	2.2	3.5	2.4	1.4	2.6	2.3	3.6	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.7	54.5	66.4	77.6	85.7	90.5	92.2	91.6	80.8	72.0	65.2	50.9	(19)	
		MCWB	42.8	43.4	50.3	57.7	65.0	69.3	69.6	68.7	65.2	59.8	51.7	42.9	(20)	
	2%	DB	42.5	49.2	61.6	72.6	79.4	85.7	87.4	86.5	76.1	66.6	59.3	44.9	(21)	
		MCWB	39.5	41.3	48.2	55.7	61.4	68.0	68.5	68.0	62.6	56.1	49.9	41.9	(22)	
	5%	DB	39.5	44.9	57.2	68.4	75.1	81.1	83.7	81.9	72.6	63.4	53.3	42.2	(23)	
		MCWB	37.3	39.3	46.1	53.4	59.9	65.2	67.3	66.5	61.1	54.4	47.8	39.7	(24)	
	10%	DB	37.3	41.7	52.7	64.5	71.0	76.9	79.8	78.0	69.1	60.0	49.3	39.4	(25)	
		MCWB	35.5	37.8	44.0	51.5	57.6	63.4	65.7	65.2	59.8	53.6	46.0	37.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	43.6	44.9	51.0	59.0	66.3	70.9	72.0	70.8	66.3	60.4	53.4	44.5	(27)	
		MCDB	49.2	50.9	64.1	75.3	79.3	86.1	86.9	86.2	77.1	68.9	61.9	48.6	(28)	
	2%	WB	39.6	42.1	48.9	56.4	63.6	68.7	69.5	68.8	64.2	58.1	50.5	42.3	(29)	
		MCDB	42.1	47.7	60.1	71.3	76.1	82.5	83.3	82.5	73.0	64.1	57.3	44.9	(30)	
	5%	WB	37.6	39.9	46.7	54.0	61.2	66.9	68.1	67.4	62.5	55.9	48.4	39.7	(31)	
		MCDB	39.3	44.0	55.7	66.4	72.5	78.5	81.2	79.6	70.2	61.0	52.6	41.8	(32)	
	10%	WB	35.8	38.0	44.5	52.0	58.8	64.6	66.6	65.8	60.7	54.1	46.2	37.7	(33)	
		MCDB	37.0	41.3	51.5	62.3	68.4	74.3	77.3	76.1	67.1	58.8	49.3	39.3	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	10.3	13.4	17.6	20.7	19.3	18.0	18.8	18.4	16.3	16.6	12.3	10.3	(35)	
		MCDBR	11.8	19.3	27.9	30.4	29.7	27.9	27.2	26.8	23.4	21.6	19.5	13.4	(36)	
	5% WB	MCWBR	8.4	12.0	15.1	14.1	12.9	10.8	10.1	10.2	11.0	11.8	11.4	9.6	(37)	
		MCWBR	11.0	16.8	26.2	27.8	27.1	25.6	24.6	25.2	20.8	18.7	17.3	12.2	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.291	0.322	0.367	0.406	0.419	0.424	0.427	0.419	0.387	0.353	0.322	0.292	(40)	
		taud	2.375	2.290	2.239	2.216	2.232	2.264	2.258	2.300	2.362	2.428	2.450	2.429	(41)	
	Ebn at Noon		250	264	268	268	268	267	264	261	259	251	237	236	(42)	
		Edh at Noon	22	30	37	42	43	42	41	38	33	26	21	19	(43)	
(44) All-Sky Solar Radiation	RadAvg		391	687	1000	1308	1496	1650	1661	1479	1074	744	411	315	(44)	
	RadStd		50	86	118	161	178	167	163	175	144	77	64	49	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (95 neighbors)	+0.86	N/A	N/A	+1.37	+0.76	+0.63	N/A	N/A	+131	+68

Nomenclature: See separate page