

WINDISCHGARSTEN, Austria

WMO: 113550

Lat: 47.720N

Lon: 14.326E

Elev: 1960

StdP: 13.68

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	6.5	11.4	3.4	7.0	10.3	7.8	8.8	13.1	18.4	39.4	15.9	38.9	1.5	80	0.501

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.6	86.8	68.3	83.2	66.7	79.9	65.0	69.7	83.3	68.1	80.2	66.4	77.2	5.6	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.5	101.2	74.1	63.9	95.5	72.6	62.4	90.8	70.9	34.8	83.5	33.5	80.7	32.1	77.3	76.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
15.9	12.7	10.3	2.0	92.6	7.3	3.0	-3.3	94.8	-7.6	96.6	-11.7	98.3	-17.0	100.5		
			1.6	72.4	7.2	1.7	-3.6	73.7	-7.8	74.7	-11.9	75.7	-17.1	76.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	47.8	28.2	32.4	39.2	48.0	56.1	62.4	65.0	64.6	56.8	49.6	39.5	31.2	(6)
	DBStd	14.75	7.99	7.99	7.26	7.79	6.95	6.99	6.19	6.08	6.32	6.89	8.31	7.70	(7)
	HDD50	2680	677	492	338	126	23	4	0	1	14	93	330	582	(8)
	HDD65	6481	1142	912	799	511	286	129	77	82	253	478	766	1046	(9)
	CDD50	1888	0	0	4	66	212	374	466	452	219	81	14	0	(10)
	CDD65	215	0	0	0	1	9	50	78	69	8	0	0	0	(11)
	CDH74	2481	0	0	0	25	175	601	827	738	107	8	0	0	(12)
	CDH80	706	0	0	0	1	29	180	260	222	14	0	0	0	(13)
(14) Wind	WSAvg	3.2	3.0	3.5	3.5	3.9	3.6	3.2	3.1	2.9	2.8	3.2	3.0	2.7	(14)
(15) Precipitation	PrecAvg	48.7	2.9	2.8	3.7	2.9	4.6	5.7	6.5	5.8	4.4	3.3	3.1	3.0	(15)
	PrecMax	56.7	7.1	7.2	8.5	5.3	8.7	9.2	13.2	10.7	9.2	6.8	8.1	8.5	(16)
	PrecMin	36.3	0.2	0.7	1.2	0.6	1.3	2.9	2.2	2.5	1.7	0.9	0.0	0.8	(17)
	PrecStd	5.1	1.9	1.6	2.1	1.1	1.9	1.6	2.8	1.9	1.9	1.4	1.7	1.7	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.6	56.6	65.8	77.3	83.8	89.9	91.4	90.4	81.8	74.7	67.0	56.6	(19)
		MCWB	44.8	44.8	50.7	58.6	64.4	69.5	70.6	69.4	65.2	59.7	53.6	46.8	(20)
	2%	DB	46.8	51.5	61.3	72.1	79.0	85.0	86.3	86.0	77.0	69.4	61.9	50.7	(21)
		MCWB	40.3	42.2	48.9	55.7	61.8	67.5	68.6	68.2	63.0	57.5	51.3	42.9	(22)
	5%	DB	41.7	47.8	56.4	67.6	74.8	81.1	82.4	81.8	73.2	65.6	57.6	45.4	(23)
		MCWB	38.1	40.2	46.2	53.4	59.5	65.4	66.8	66.5	61.2	55.2	48.9	40.9	(24)
	10%	DB	38.1	43.7	51.7	63.2	70.7	76.8	78.6	77.9	69.5	61.9	52.6	41.1	(25)
		MCWB	36.0	38.3	44.0	51.3	57.6	63.5	65.2	64.9	59.6	53.3	46.4	38.3	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.8	46.3	52.0	59.2	66.1	71.2	71.9	71.3	67.0	60.9	54.4	47.5	(27)
		MCDB	51.6	54.1	62.9	75.6	80.8	85.8	87.5	85.0	77.6	70.9	64.9	55.5	(28)
	2%	WB	41.0	43.1	49.5	56.4	63.1	68.7	69.7	69.2	64.5	58.4	51.7	44.3	(29)
		MCDB	45.1	50.1	59.3	70.4	75.6	81.8	83.3	82.3	74.2	67.2	60.5	49.1	(30)
	5%	WB	38.4	40.8	47.1	54.1	60.8	66.6	68.1	67.6	62.5	56.4	49.4	41.2	(31)
		MCDB	41.3	46.5	54.9	65.9	71.8	78.1	80.0	79.3	70.7	63.5	56.4	45.2	(32)
	10%	WB	36.1	38.7	44.7	52.0	58.6	64.6	66.3	65.8	60.5	54.6	47.0	38.4	(33)
		MCDB	37.9	43.2	50.6	61.7	68.8	74.7	76.3	75.9	67.6	60.6	52.0	41.1	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	12.9	15.5	17.5	19.6	19.3	19.1	19.6	20.2	18.6	18.7	14.1	12.3	(35)
		MCDBR	16.9	23.5	28.7	29.7	29.2	28.8	28.5	28.9	26.8	26.4	21.1	18.2	(36)
		MCWBR	12.1	14.9	16.6	15.0	13.4	12.5	12.0	12.4	13.8	15.0	12.5	12.4	(37)
	5% WB	MCDBR	15.0	20.1	25.9	27.3	25.9	26.1	25.5	26.3	24.4	23.7	19.7	16.9	(38)
		MCWBR	11.2	13.3	15.5	14.1	12.6	11.9	11.1	11.9	12.9	14.1	12.3	12.0	(39)
(40) Clear-Sky Solar Irradiance	taub		0.283	0.312	0.352	0.390	0.400	0.405	0.410	0.402	0.373	0.342	0.314	0.284	(40)
	taud		2.395	2.337	2.301	2.271	2.287	2.309	2.299	2.337	2.393	2.459	2.483	2.452	(41)
	Ebn at Noon		254	269	273	273	274	272	269	266	264	256	241	241	(42)
	Edh at Noon		22	28	35	39	40	40	40	36	31	25	20	18	(43)
(44) All-Sky Solar Radiation	RadAvg		369	650	976	1318	1522	1666	1655	1477	1068	723	398	302	(44)
	RadStd		43	81	112	147	175	140	155	167	137	72	55	42	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (104 neighbors)	+0.94	N/A	N/A	+1.40	+0.81	+0.72	-198	-256	+146	+72

Nomenclature: See separate page