

BAD AUSSEE, AustriaWMO: **113560**Lat: **47.611N**Lon: **13.758E**Elev: **2435**StdP: **13.45**Time Zone: **1.00 (EUC)**Period: **97-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	8.7	13.1	5.1	7.8	11.1	9.4	9.7	14.7	15.1	33.9	13.2	33.6	2.0	280	0.491

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.9	85.5	66.7	82.1	65.4	78.9	63.8	68.0	82.3	66.5	79.3	65.0	76.1	3.8	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.5	95.9	72.0	62.1	91.3	70.6	60.9	87.3	69.1	33.7	82.8	32.5	79.5	31.2	76.3	73.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.2	9.3	7.7	3.6	92.3	7.0	2.5	-1.5	94.1	-5.6	95.6	-9.5	97.0	-14.6	98.9		
(5)			2.3	71.3	6.8	1.3	-2.6	72.2	-6.5	73.0	-10.3	73.7	-15.2	74.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	47.6	28.4	32.0	39.0	48.0	55.6	61.9	64.6	64.3	56.7	49.2	38.9	31.2
	DBStd	14.56	7.30	7.58	6.84	7.48	7.15	7.31	6.27	6.33	6.41	6.76	7.60	6.88
	HDD50	2717	671	505	342	123	31	6	0	1	15	97	342	584
	HDD65	6572	1136	925	805	510	299	142	86	91	256	489	784	1049
	CDD50	1825	0	0	2	63	204	362	451	445	217	73	8	0
	CDD65	204	0	0	0	0	7	48	72	70	7	0	0	0
	CDH74	2026	0	0	0	14	136	528	690	587	70	1	0	0
	CDH80	524	0	0	0	1	21	144	199	152	7	0	0	0
Wind	WSAvg	2.8	3.1	3.1	3.0	3.3	2.8	2.5	2.4	2.5	2.4	2.9	3.1	2.9
Precipitation	PrecAvg	66.3	4.4	3.9	5.3	4.3	5.8	7.6	8.5	7.2	6.1	4.3	4.4	4.5
	PrecMax	76.6	10.2	8.0	11.9	7.3	10.0	12.8	16.3	13.0	11.7	8.2	10.4	10.4
	PrecMin	55.4	0.6	1.5	2.2	1.5	1.6	4.6	4.3	3.5	2.9	1.6	0.9	1.9
	PrecStd	5.6	2.3	1.7	2.6	1.4	2.1	1.9	2.9	2.0	2.2	1.7	2.0	1.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.9	53.6	64.3	75.6	83.2	89.2	90.0	88.7	80.2	72.3	63.7	53.3
		MCWB	44.1	42.9	49.7	57.7	63.3	68.0	68.5	68.2	64.0	58.1	51.5	44.2
	2%	DB	43.6	48.9	59.8	70.8	77.9	84.2	85.2	84.2	75.5	67.5	59.0	45.9
		MCWB	38.8	40.1	47.3	54.9	60.5	66.1	66.8	66.5	61.5	55.7	49.7	40.6
	5%	DB	39.5	45.0	55.0	66.5	73.8	80.2	81.5	80.6	72.1	63.8	54.1	42.2
		MCWB	36.6	38.6	44.8	52.5	58.6	64.0	65.6	65.3	60.1	53.7	47.2	39.3
	10%	DB	36.7	41.6	50.4	62.5	69.5	76.1	77.5	76.8	68.3	60.2	49.7	39.3
		MCWB	34.7	36.9	42.6	50.4	56.4	62.2	63.8	63.8	58.3	52.1	45.0	36.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.0	43.8	50.2	58.4	64.5	69.3	70.1	69.7	65.4	59.0	52.8	44.7
		MCDB	50.3	52.0	62.2	74.3	78.1	84.2	85.5	83.9	76.8	68.6	61.4	51.2
	2%	WB	39.4	41.1	47.8	55.5	61.9	67.1	67.9	67.7	62.9	56.8	50.1	42.0
		MCDB	42.7	47.0	58.0	69.4	75.3	81.1	82.3	81.2	72.5	64.4	57.8	45.1
	5%	WB	36.9	39.1	45.6	53.1	59.7	65.2	66.4	66.1	61.1	54.9	47.7	39.4
		MCDB	39.3	44.1	53.7	65.1	71.2	77.5	79.0	78.3	69.9	61.8	53.4	42.0
	10%	WB	35.0	37.3	43.3	51.0	57.5	63.3	64.8	64.5	59.4	53.2	45.4	37.0
		MCDB	36.5	41.3	49.5	60.9	67.7	73.8	75.2	74.8	66.6	59.1	49.5	39.1
Mean Daily Temperature Range	5% DB	MDBR	10.7	13.5	16.6	19.2	18.9	18.9	18.9	19.0	17.2	16.7	11.9	9.9
		MCDBR	12.5	20.2	26.5	28.4	28.6	28.3	27.5	26.3	24.4	23.1	18.5	13.0
		MCWBR	8.7	12.4	14.8	13.9	12.4	11.2	10.4	10.4	11.3	12.2	10.5	8.9
	5% WB	MCDBR	11.9	17.6	24.9	26.4	26.2	25.5	25.0	24.8	22.2	20.7	16.9	12.3
		MCWBR	8.5	11.2	14.3	13.1	11.7	10.3	9.8	10.1	10.4	11.2	10.0	8.8
Clear-Sky Solar Irradiance	taub	0.281	0.311	0.354	0.392	0.404	0.409	0.412	0.404	0.373	0.341	0.312	0.282	
	taud	2.385	2.309	2.265	2.248	2.263	2.291	2.284	2.325	2.387	2.451	2.470	2.442	
	Ebn at Noon	256	269	272	272	273	272	269	266	264	256	242	242	
	Edh at Noon	22	29	36	40	41	41	40	37	32	25	20	18	
All-Sky Solar Radiation	RadAvg	390	684	998	1306	1497	1648	1658	1478	1074	744	413	316	
	RadStd	48	85	116	157	177	162	161	175	143	76	63	49	